

926-2-138

E. LIVINGSTON, P. Eng.  
A. BAORY

**PACIFIC HYDROLOGY CONSULTANTS LTD.**  
CONSULTING GROUNDWATER GEOLOGISTS

204 - 1929 WEST BROADWAY  
VANCOUVER, B.C. V6J 1Z3  
TELEPHONE: (604) 738-9232

August 28, 1991

West and Associates  
20609 Logan Avenue  
LANGLEY, B.C. V3A 7A3

Attention: Mr. Tony West,  
President

---

Subject: Pumping Tests of Two Wells at the Faulkner Property at 1517 -  
224th Street in Langley

---

Dear Sirs:

This letter is in reply to a facsimile message from West and Associates and is further to a telephone discussion on August 27 between Tony West of West and Associates and Ed Livingston, P. Eng., of Pacific Hydrology, about analysis of data from pump tests carried out on two wells by Aquarius Drilling in July and August of this year.

The test of the drilled well, which the data show was started at an initial rate of 34 L/min for 10 minutes, continued at a rate of 31 L/min for the last 50 minutes of the 60 minute test; the drawdown at the end of the test was 18.30 ft. Recovery of the water level following the termination of pumping was very rapid; residual drawdown after two minutes was 6.90 ft and, after 10 minutes, it was 2.65 ft. Since this well is screened in a granular aquifer, since the test was carried out at a rate more than three times the required rate, since the drawdown was constant at the end of the test, and since the drawdown was only 52% of total available drawdown we have no hesitation in stating that the well capacity meets the Langley Subdivision Bylaw requirements.

.../2

West and Associates

Pumping Tests of Two Wells at the Faulkner Property at 1517 - 224th Street in  
Langley

August 28, 1991 - Page 2

---

The required Forms for the drilled well are included with this letter; for the well capacity calculation, we have assumed a pump setting of 36.3 m, which is about 0.3 m above the top of the well screen. This gives a "minimum available drawdown" of 6.95 metres, based on the assumption of a minimum required daily yield of 1.74 L/min. Obviously there is likely to be an higher capacity pump installed in the well but this does not affect the Form F-7 calculation, which is based on the minimum capacity required under the Langley Bylaw.

The data for the dug well have been calculated and are included with this letter. In examining these data, it must be kept in mind that the well was in use supplying the Faulkner home during the pumping and particularly during the recovery period. For the first four hours, the well was pumped at a rate 30% greater than the Langley Bylaw requirement; the constant rate was much higher than the required 24 hour capacity. The well was still drawing down at the end of the test and had used up 60% of the total available drawdown, assuming a static level of 2.74 m and allowing 0.5 m of water in the well at maximum drawdown. The fact that the well has been in use for many years without problems and was in use up to the time of the test and during the test, is an important indicator of the adequate capacity of the well.

The Langely Certification Forms are clearly not applicable to a dug well so we have not used them to analyze and/or record the data for the dug well. Plots of drawdown and recovery on appropriate semi-logarithmic graph paper are included, although they are also not strictly applicable in the case of large diameter dug wells.

In conclusion, the pump test data and other historical information on the experience with the use of the well show that the dug well on the Faulkner Property has sufficient capacity to meet the Langley Bylaw requirements.

West and Associates

Pumping Tests of Two Wells at the Faulkner Property at 1517 - 224th Street in  
Langley

August 28, 1991 - Page 3

---


We trust that this is the information you require. Please call if  
we can be of further assistance with this matter.

Yours truly,

PACIFIC HYDROLOGY CONSULTANTS LTD.

*E. Livingston*

E. Livingston, P. Eng.



Enclosures



# The Corporation of the Township of Langley

SCHEDULE "A"

## PRIVATE WELL CERTIFICATION

PURSUANT TO SCHEDULE "A" of the Subdivision and Development Control Bylaw, which requires that each lot to be created and/or each existing lot forming part of the proposed development can be serviced with potable water in accordance with the requirements of the Bylaw for the development of:

LEGAL DESCRIPTION: Lot 10, Sec. 7, Tp. 10, Plan 33459, N.W.D.

PROJECT NO.: \_\_\_\_\_

I certify that a quantity of not less than 2,500 litres per day has been proven for each existing or proposed lot in the development.

I certify that each well within the subdivision has been tested and is capable of continuously providing water at a rate of 9 litres/min. for a four hour period.

I certify that water quality tests have been conducted and that the "B.C. Drinking Water Standards, 1982" can be met for each existing or proposed lot in the development.

EDMUND LIVINGSTON, P. ENG.

Certified By (Name of Professional Engineer)

PACIFIC HYDROLOGY CONSULTANTS LTD.

Address


204 - 1929 West Broadway, VANCOUVER, B.C. V6J 1Z3

*E. Livingston*

PROFESSIONAL  
SEAL



See attachments as required pursuant to clause 2.2.18 of Schedule "A".



# The Corporation of the Township of Langley

SCHEDULE "A"

## WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Dave Faulkner WELL NO. 1 (Drilled)  
APPLICATION NO.: \_\_\_\_\_ DATE: 30 July 1991  
LOCATION: 1517 - 224 Street, Langley SHEET 1 OF 7  
TEST NO. 1

☒ Drawdown ☐ Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(MIN)	(L)	Lpm	
19:00	0	26.00					Static level; start pump.
	½	26.73	0.73	0.33	11.35	34	Discharge water brown.
	1	27.46	1.46				
	1½	27.99	1.99				
	2	28.38	2.38				
	2½	28.72	2.72				
	3½	29.35	3.35				
	4	29.515	3.515				
	4½	29.69	3.69				
	6	30.05	4.05				
	8	30.66	4.66				
	9	30.765	4.765				
	10	30.835	4.835				
	12	30.94	4.94	0.37	11.35	30.7	
	14	31.05	5.05				
	16	31.11	5.11				Discharge water clear; no odour.
	18	31.16	5.16				
	20	31.20	5.20				
	25	31.29	5.29	0.37	11.35	30.7	
	30	31.35	5.35				



WELL PUMP TEST - FIELD TEST

☒ Drawdown      ☐ Recovery

F-6



# The Corporation of the Township of Langley

SCHEDULE "A"

## WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Dave Faulkner WELL NO. 1 (Drilled)  
APPLICATION NO.: \_\_\_\_\_ DATE: 30 July 1991  
LOCATION: 1517 - 224 Street, Langley SHEET 3 OF 7  
TEST NO. 1

☐ Drawdown ☒ Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Time From Stop	t/t	Comments
	(Min)	(M)	(M)	(MIN)	(L)	Lpm	(Min)		
20:00	60	31.49	5.49						Stop pump.
	60½	30.06	4.06				½	121	
	61	29.45	3.45				1	61	
	61½	28.41	2.41				1½	41	
	62	28.02	2.02				2	31	
	62½	27.80	1.80				2½	25	
	63	27.70	1.70				3	21	
	63½	27.56	1.56				3½	18.1	
	64	27.45	1.45				4	16.0	
	64½	27.35	1.35				4½	14.3	
	65	27.26	1.26				5	13.0	
	66	27.11	1.11				6	11.0	
	67	26.98	0.98				7	9.6	
	68	26.88	0.88				8	8.5	
	69	26.80	0.80				9	7.7	
	70	26.72	0.72				10	7.0	
	72	26.63	0.63				12	6.0	
	74	26.56	0.56				14	5.3	
	76	26.48	0.48				16	4.75	
	78	26.44	0.44				18	4.3	



## WELL PUMP TEST - FIELD TEST

TEST NO. 1

☒ Recovery

F-6  
(modified)






# The Corporation of the Township of Langley

SCHEDULE "A"

## TIME-DRAWDOWN GRAPH FOR PUMP TEST

OWNER'S NAME: Dave Faulkner WELL No. 1 (Drilled)  
APPLICATION No: \_\_\_\_\_ DATE: 30 July 1991  
LOCATION: 1517 - 224 Street, Langley SHEET 5 OF 7  
DEPTH TO STATIC WATER LEVEL: 26.00 m (m) TEST No. 1



Qh = PUMPING RATE = 29.9 (Lpm)

Sh1 = DRAWDOWN AT 10 MIN. = 4.835 m.

Sh2 = DRAWDOWN AT 240 MIN. = 5.49 m.

CALCULATED DRAWDOWN VALUES: SL 1 =  $\frac{Q_h}{Q_h} \times Sh1 = 0.274$  m

SL 2 =  $\frac{Q_h}{Q_h} \times Sh2 = 0.319$  m

DRAWDOWN AT 30 DAYS (S<sub>30</sub>) = 0.35 m

ESTIMATED MINIMUM ADJUSTMENT FOR SEASONAL DECLINE (D): USE FOLLOWING FIGURES IF OTHER LOCAL DATA OR HYDROGEOLOGIST'S OPINION IS NOT AVAILABLE.

TESTS RUN IN AUG., SEPT. & OCT.: 2 m

TESTS RUN IN NOV., DEC., JAN., MAY, JUNE & JULY: 4 m

TESTS RUN IN FEB., MAR. & APRIL: 6 m

SAFETY FACTOR = SF = 1m

DEPTH TO PROPOSED PUMP SUCTION (D<sub>P</sub>) 36.3 m

CALCULATE MINIMUM AVAILABLE DRAWDOWN:  $D_P - (D_{TW} + S_{30} + D + SF) =$

36.3 - (26.0 + 0.35 + 2.0 + 1.0) = 6.95 m

IF ANSWER TO ABOVE CALCULATION IS NEGATIVE, THEN EITHER THE PUMP HAS TO BE SET LOWER OR THE WELL IS NOT CAPABLE OF SUPPLYING WATER FOR A HOUSE.


F-7



The Corporation of the Township of Langley  
SCHEDULE "A"

RECOVERY GRAPH FOR PUMP TEST

OWNER'S NAME: Dave Faulkner WELL NO. 1 (Drilled)  
APPLICATION NO.: \_\_\_\_\_ DATE: 30 July 1991  
LOCATION: 1517 - 224 Street, Langley SHEET 6 OF 7  
DEPTH TO STATIC WATER LEVEL: 26.00 (m) TEST NO. 1





# The Corporation of the Township of Langley

SCHEDULE "A"

## PUMP TEST SUMMARY

OWNER'S NAME: Dave Faulkner WELL NO. 1 (Drilled)  
APPLICATION NO.: \_\_\_\_\_ DATE: 30 July 1991  
LOCATION: 1517 - 224 Street, Langley SHEET 7 OF 7  
TEST NO. 1

WELL COMPLETION DATA		SCREEN DESIGN (mark one)		DESCRIPTION OF AQUIFER
Depth <u>38.1</u> (m)	<input type="checkbox"/> Open Hole	<input type="checkbox"/> Slotted Casing	sand with minor	
Diameter <u>150</u> (mm)	<input checked="" type="checkbox"/> Screen	<input type="checkbox"/> Gravel Pack	gravel between	
Static Water Level <u>26.0</u> (m)	<input type="checkbox"/> Other _____		<u>34.4 and 38.1 m</u>	
		Screen Interval <u>36.6 m to 38.1 m</u>		

PUMP TEST	
Start Date <u>30/07/91</u>	Time <u>7:00 p.m.</u>
<u>11/20/yr</u>	<u>hr/min</u>
Pump Type: <input checked="" type="checkbox"/> Electric submersible	<input type="checkbox"/> Jet <input type="checkbox"/> Air Lift
Other? Describe _____	
Test Pump Set at <u>32.9</u> m below ground	
Water level sounded by: <input checked="" type="checkbox"/> Electric tape	<input type="checkbox"/> Air bubbler <input type="checkbox"/> Steel tape
<input type="checkbox"/> Other? Describe _____	
Flow measured by: <input checked="" type="checkbox"/> Container & watch	<input type="checkbox"/> Flow meter
<input type="checkbox"/> Orifice & tube <input type="checkbox"/> Other? Describe _____	

TEST	
Constant rate of yield <u>final = 29.9</u> Lpm	Test duration <u>one</u> hours
Initial non-pumping level <u>26.0</u> m	
Drawdown in well at end of test <u>5.49</u> m	
Recommended pumping rate <u>30</u> Lpm	

WATER SAMPLES TAKEN DURING TEST	
Chemical Analysis <input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Bacterial Analysis <input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Water Temperature <u>-</u> °C	
Any particular gas smells noted <u>none</u>	
Comments on clarity of water <u>Discharge water was clear after 16 minutes of pumping</u>	
Other _____	
_____	
_____	

# PUMP TEST – DRAWDOWN DATA

PAGE 1 OF 5

CONTRACTOR Aquarius Drilling

10	August	1991
DAY	MONTH	YEAR

PROJECT DAVE FAULKNER

Location 1517 - 224 Street in Langley

Well Dug well Pumping Rate (Q) Constant at 12 L/min.

Datum Point Edge of concrete Elevation of Datum Point -

Static Water Level Assume 274 cm Screen Location n/a - Dug well with depth of 5.2 m

TIME		ELAPSED TIME t (MIN.)	DISTANCE TO WATER	DRAWDOWN (cm)			PUMPING RATE	REMARKS
HR.	MIN.						(L/min)	
10	00	0	274.3	0.3				Start pump.
		1	275.8	1.8				
		2	277.1	3.1			12	
		3	278.0	4.0				
		4	278.5	4.5				Discharge water clear;
								no odour.
		5	279.3	5.3				
		6	280.5	6.5				
		7	281.0	7.0				
		8	281.6	7.6				
		9	282.3	8.3				
		15	286.3	12.3				
		20	287.5	13.5				
		25	290.0	16.0				
10	30	30	292.5	18.5				
		35	295.0	21.0				
		40	297.5	23.5				
		45	300.7	26.7				
		50	303.1	29.1				
		55	305.7	31.7				
11	00	60	308.0	34.0				
		75	316.5	42.5				
		90	324.0	50.0				
		105	331.0	57.0				
12	00	120	338.0	64.0				
		135	346.0	72.0				
12	30	150	352.3	78.3				
		165	359.0	85.0				

### PUMP TEST - DRAWDOWN DATA

PAGE 2 OF 3

PROJECT DAVE FAULKNER

Well Dug well Static Water Level Assume 274 cm

10	August	1991
DAY	MONTH	YEAR

[illegible]

UMP TEST - RECOVERY DATA

PAGE 3 OF 5

PROJECT DAVE FAULKNER

10/11	August	1991
DAY	MONTH	YEAR


Well Dug Well

Datum Point Edge of concrete Elevation of Datum Point —

Static Water Level Assume 274 cm      Total Drawdown 117.1 cm

[illegible]

Semi-logarithmic Plot of Recovery of Water Level in F. Kner Dug Well



NO. 3401210 BETWEEN GRAY PAPER  
SEMI-LOGARITHMIC  
3 CYCLES X 10 DIVISIONS PER INDEX

DISCHARGE COORDINATION  
MADE IN U.S.A.

# Semi logarithmic Plot of Drawdown in Faulkner Well

4 of 5

