

78-092

1984 04 12

A & A Plumbing & Heating Ltd.
1502 Boundary
Burnaby, B.C.
V5K 4V4

ATTENTION: Mr. Jim Linn

SUBJECT: Test Pumping of Irrigation Well
(Test Well No. 2)
Eagle Ridge Hospital

Dear Sirs:

The well at the Eagle Ridge Hospital that is to be used for lawn irrigation was completed in October of 1979 and has been idle since that time. The results of pumping tests run when the well was drilled indicated an optimum pumping rate of 75 to 100 Igpm.

To determine the present capacity of the well, Mr. R.B. Erdman of this office ran a pumping test on April 5, 1984. The well had been measured by A & A personnel to be 112 feet deep. The original constructed depth of the well was 114 feet. The difference in the two figures may be caused by a difference in measuring points or there may be two feet of material in the bottom of the screen. The presence of two feet of material will not markedly reduce the productive capacity of the well.

Water level measurements taken before the start of pumping shows a static water level of twenty feet. The static water level when the well was constructed was twenty-one feet. The near same static water level would indicate that the aquifer is not being depleted.

At the start of pumping, a black coloured water was pumped from the well for less than one minute.

Continued...

Mr. Jim Linn
Test Pumping of Irrigation Well
(Test Well No. 2)
Eagle Ridge Hospital
Page 2

A plot of the drawdown information obtained from the April 5 test when the well was pumping at a rate of 100 Igpm indicates that no or very little deterioration has taken place in the well. After one hour of pumping, the water level in the well had reached a depth of 72.16 feet. The top of the well screens are at 94 feet so that there is an additional 22 feet that the water level could be lowered in the well.

It is recommended that the well not be pumped at more than 75 Igpm to allow ample safety for dry summer weather which, coupled with high usage will cause additional demands on the well.

The performance curve supplied with the pump shows that with a pressure of 50 psi at surface the pump will supply 75 Igpm. The gate valve should be used to maintain this pressure or to keep the well from being overpumped.

It is our understanding that three probes are to be placed in the well. A low level alarm probe, a cut-off probe and a restart probe. It is recommended that the low level alarm probe be set at 94 feet (at the top of the well screen). The cut-off probe should be set at 92 feet and the restart probe at approximately 60 feet. The alarm and cut-off probes are set above the well screen so that the water levels in the well will not be pumped down below the top of the well screen. The probes should be attached to the pump column otherwise the exact depth of their settings cannot be assured.


If any of the above needs clarification or amplification, please do not hesitate to contact us.

Yours very truly,

BROWN, ERDMAN & TURNER LTD.

W.L. Brown, P. Eng.

RBE/sy





BROWN, ERDMAN & ASSOCIATES LTD.
1401 BEWICKE AVENUE, NORTH VANCOUVER, BRITISH COLUMBIA V7M 2C7
TELEPHONE 986-1557

78-092

October 4, 1979

Paul Smith and Associates,
Architects,
2425 Quebec Street,
Vancouver, B.C.
V5T 4L6

Attention: Mr. Michael Weller

Subject: Eagle Ridge Hospital - Production Well

Dear Sirs:

The subject production well was drilled and tested during September and October, 1979. Enclosed are a well lithology and construction diagram, time drawdown plots of pumping tests, field data collected during pumping tests, and the chemical analysis of the groundwater.

During drilling, a series of sands and sand and gravels, underlying 33 feet of glacial till, was encountered to depths of 114 feet. Twenty feet of 8 inch telescopic stainless steel well screens were installed in sandy gravels occurring between 94 and 114 feet. The static water level for these gravels is 21 feet below ground surface. The well was then developed and pump tested on September 17, 1979. On analyzing the results of this pump test, it was thought that further development would enhance the yield of the well. The well was, therefore, re-developed and another short pump test conducted on October 2, 1979.

Results of these pump tests are shown on the enclosed time drawdown plots. In summary, these pump tests indicate that the aquifer encountered has a transmissivity of between 4,000 and 7,000 igpd/ft. and that the well has a specific capacity of between 1 and 2 igpm per foot of drawdown. In addition, the time-drawdown plots indicate that a negative hydraulic boundary was encountered during testing which shows that the migrating cone of depression reached the physical edge of the aquifer. The presence of this aquifer boundary naturally increases drawdown when compared to the response of an infinite aquifer. With an available drawdown of 70 feet and considering the values and conditions mentioned above, we consider that the production well has an optimum pumping rate of 75 to 100 igpm.

cont....2/



As can be seen from the enclosed chemical analysis, the groundwater is potable and all constituents tested are within acceptable concentrations. The temperature of the groundwater is 9.5°C. The borderline values of phosphate and manganese should not cause any problems.

Although no invoices have been received to date, the approximate cost of this production well is \$12,000.00. We recommend that one further attempt should be made to obtain your required volume of 375 igpm from groundwater sources. This would entail the drilling of a 250 feet, 8 inch production water well located in the South West corner of the property near the Ioco Road. This well would be designed to obtain groundwater from the shallower aquifer encountered in the present well and also from the deeper aquifer described in our letter of June 20, 1978. We estimate that the chances of drilling an entirely successful production well (i.e. one that would supply 250 to 300 igpm) are about 65%, while the chances for obtaining 150 to 200 igpm are about 90%. The approximate cost for this well would be:

Mobilization and Demobilization	\$ 250.00
Drill and case, 8 inch well, 250 feet @ \$40	10,000.00
Well screens, 40 feet @ \$80/ft.	3,200.00
Development, 25 hours @ \$55/hr.	1,375.00
Other hourly work, 10 hours @ \$85/hr.	850.00
Test pumping, 30 hours @ \$32/hr.	960.00
Mobilization and demobilization, test pump	<u>200.00</u>
TOTAL:	\$ 16,835.00
or about	\$ 17,000.00

If any of the above needs amplification or clarification, please do not hesitate to contact us.

Thank you for the opportunity to be involved in this project.

Yours truly,

BROWN, ERDMAN & ASSOCIATES LTD.

R.I.J. Vogwill
Sr. Hydrogeologist



BROWN, ERDMAN & ASSOCIATES LTD.
NORTH VANCOUVER, BRITISH COLUMBIA

FIRST PUMP TEST.

PAGE 1

WELL OWNER EAGLE RIDGE HOSPITAL
LOCATION PT. MOODY

WELL NO. 2
JOB NO. 78-092

DRAWDOWN
RECOVERY

DATE	TIME	ELAPSED TIME MINUTES	DEPTH TO WATER (FT)	Q <u>I</u> GPM	DRAWDOWN (FT)	REMARKS
Sept. 17/79	15:00	—	21.63			Static Water Level.
		0.5	46.37	125	24.74	Pump suction ± 87 ft; 3"x4" orifice
		1	50.62		28.99	
		1.5	54.38		32.75	
		2	59.22		37.59	
		2.5	59.85		38.22	
		3	62.84		41.21	
		3.5	63.76		42.13	
		4	65.39		43.76	
		4.5	66.88		45.25	
	15:05	5	68.22		46.59	
		6	70.28		48.65	
		7	72.61		50.98	
		8	74.54		52.91	
		9	75.95		54.32	
	15:10	10	77.28		55.65	
		12	79.46		57.83	
		14	81.36		59.73	
		16	83.15		61.52	
		18	84.56		62.93	
	15:20	20	86.92	125	65.29	Cut back discharge at 22 min.
		25	81.54	108	59.91	
	15:30	30	81.84		60.21	
		35	82.45		60.82	
	15:40	40	83.38		61.75	
		45	84.26		62.63	
	15:50	50	84.96		63.33	
	16:00	60	86.36	108	64.67	Cut back discharge at 65 min.
	16:10	70	81.34	96	59.71	
	16:20	80	80.51		58.88	
	16:30	90	80.57		58.94	



BROWN, ERDMAN & ASSOCIATES LTD.
NORTH VANCOUVER, BRITISH COLUMBIA

FIRST PUMP TEST

PAGE 2

WELL OWNER EAGLE RIDGE HOSPITAL
LOCATION PT. MOODY

WELL NO. 2 DRAWDOWN
JOB NO. 78-092 RECOVERY

DATE	TIME	ELAPSED TIME MINUTES	DEPTH TO WATER (FT)	Q <u>I</u> GPM	DRAWDOWN (FT.)	REMARKS
Sept. 17/79	16:50	110	80.96	96	59.33	
	17:00	120	81.30		59.67	
	17:10	130	81.46		59.83	
	17:20	140	81.67		60.04	
	17:30	150	81.89		60.26	
	18:20	200	82.75		61.12	
	19:10	250	83.53		61.90	
	20:00	300	84.08	96	62.45	Cut back discharge at 300 min.
	20:10	310	77.54	83.3	55.91	
	20:20	320	76.58		54.95	
	20:30	330	75.96		54.33	
	20:40	340	75.67		54.04	
	20:50	350	75.50		53.87	
	21:40	400	75.04		53.41	
	22:30	450	75.00		53.37	
	23:20	500	75.00		53.37	
Sept 18/79	00:10	550	75.00		53.37	
	01:00	600	74.95		53.32	
	01:50	650	74.94		53.31	
	02:40	700	75.06		53.37	
	03:30	750	74.99		53.36	
	04:20	800	75.16		53.47	
	05:10	850	75.18		53.55	
	06:00	900	75.29		53.66	
	06:50	950	75.31		53.68	
	07:40	1000	75.38		53.75	
	08:30	1050	75.43		53.80	
	09:20	1100	75.54		53.91	
	10:10	1150	75.63		54.00	
	11:00	1200	75.64	83.3	54.01	
	11:50	1250	75.63		54.00	



BROWN, ERDMAN & ASSOCIATES LTD.
NORTH VANCOUVER, BRITISH COLUMBIA

SECOND PUMP TEST


PAGE 1

WELL OWNER EAGLE RIDGE HOSPITAL
LOCATION PT. MOODY

WELL NO. 2
JOB NO. 78-092

DRAWDOWN
RECOVERY

DATE	TIME	ELAPSED TIME MINUTES	DEPTH TO WATER (FT)	Q I GPM	DRAWDOWN (FT.)	REMARKS
Oct. 2/79	9:10	—	22.85	—	—	STATIC WATER LEVEL; PUMP SUCTION ± 84 FT
	0.5	58.14	125	35.29	3" x 4" orifice	
	1	62.96		40.11		
	1.5	69.53		46.68		
	09:12	2	74.22		51.37	
		2.5	77.91		55.06	
		3	80.99		58.14	
		3.5	—		—	
		4	—		—	
		4.5	—		—	
	09:15	5	—	125	—	
		6	78.51	96	55.66	Cut back discharge at 6 mins.
		7	76.36		53.51	
		8	76.09		53.24	
	09:20	9	76.32		53.47	
	09:20	10	76.70		53.85	
		12	77.65		54.80	
		14	78.47		55.62	
		16	79.25		56.40	
		18	80.00		57.15	
	09:30	20	80.61		57.76	
		25	82.05		59.20	
	09:40	30	84.00		61.15	
		35	84.85		62.00	
	09:50	40	85.02	96	62.17	Cut back discharge at 40 mins.
	10:00	50	79.33	83.3	56.48	
	10:10	60	78.10		55.25	
	10:20	70	78.38		55.53	
	10:30	80	78.86		56.01	
	10:40	90	78.94		56.09	
	10:50	100	80.10		57.25	



b600-1860


PACIFIC WATER WELLS (1969) LTD. - JMP TEST

WELL OWNER: EAGLE RIDGE TEST DATE: OCT. 21/79 SIZE OF ORIFICE: 3"

LOCATION: 1000 STATIC LEVEL: 82.85 SIZE OF PIPE: 4"

TIME	DEPTH TO WATER	MIN PUMPED	US GPM	TIME	DEPTH TO WATER	MIN PUMPED	US GPM		REMARKS
9:10	22.85			12:30	81.63	200	100		
.5	58.14	.5	150	1:00	82.06	230			
9:11	62.96	1		1:30	82.34	260			
9:12	74.22	2							
.5	77.41	2.5							
9:13	80.99	3	150						
.5		3.5							
9:14	CHANGE	4							
.5	SETTING	4.5							
9:15		5							
9:16	78.51	6	115						
9:17	76.36	7							
9:18	76.09	8							
9:19	76.32	9							
9:20	76.70	10							
9:22	77.65	12							
9:24	78.47	14							
9:26	79.25	16							
9:28	80.00	18							
9:30	80.61	20							
9:35	82.05	25							
9:40	84.00	30							
9:45	84.85	35							
9:50	85.02	40	115						
10:00	79.33	50	100						
10:10	78.10	60							
10:20	78.38	70							
10:30	78.86	80							
10:40	78.94	90							
10:50	80.10	100							
11:40	80.67	150	100						

RIG No: DRILLER:



can test ltd.

1650 PANDORA STREET, VANCOUVER, B.C. V5L 1L6 • TELEPHONE 254-7278 • TELEX 04-54210

Report On Analysis of Water Samples File No. 2374 D
Report No. _____
Reported To Brown Erdman & Associates Ltd. P.O. # October 3, 1979
1401 Bewicke Avenue, Date _____
North Vancouver, B.C.
Attention: _____

We have tested the sample of water submitted by you on Sept. 18, 1979
and report as follows:

SAMPLE IDENTIFICATION:

The sample submitted was in a plastic bottle labelled:

Eagle Ridge Hospital
78-092
Pt. Moody
18/9/79 1260 mins 9.5°C

METHOD OF TESTING:

The analyses were carried out in accordance with procedures described in:

"Standard Methods for the Examination of Water and Wastewater (14th Edition)"
published by the American Public Health Association, 1975.

RESULTS OF TESTING:

TEST EAGLE RIDGE HOSPITAL

Physical Tests

pH		8.05
Conductance (umhos/cm)		117.
Colour (CU)		L5.
Turbidity (JTU)		0.13
Total Dissolved Solids (mg/L)		104.
Total Suspended Solids (mg/L)		L0.2

Dissolved Anions (mg/L)

Alkalinity		
Bicarbonate	HCO ₃	55.0
Carbonate	CO ₃	NIL
Chloride	Cl	L0.5
Sulfate	SO ₄	L5.
Nitrate & Nitrite	N	L0.001
Phosphate	PO ₄	0.36*
Fluoride	F	0.096
Silica	SiO ₂	27.8

Dissolved Cations (mg/L)

Total Hardness	CaCO ₃	38.1
Calcium	Ca	10.7
Magnesium	Mg	2.78
Sodium	Na	4.93
Potassium	K	1.88
Iron	Fe	0.030
Manganese	Mn	0.077
Cadmium	Cd	L0.001
Copper	Cu	0.002
Lead	Pb	L0.001
Zinc	Zn	0.003

Others (mg/L)

Total Iron	Fe	L0.030
Total Manganese	Mn	0.078

L = Less than, mg/L = milligrams per liter (or parts per million for drinking water)

* Rechecked and verified.

File No. 2374D
Page No. 3
October 3, 1979.


REMARKS:

The water represented by the sample submitted can be characterized as a moderately soft water, moderate with respect to dissolved mineralization. For the parameters tested the sample met the limits set by the Canadian Drinking Water Standards and Objectives, 1968 with the exception of dissolved phosphates (limit = 0.2mg/L) and dissolved manganese (limit = 0.05 mg/L).

Both of these parameters are limited for aesthetic reasons. Phosphates, especially in open reservoirs, may promote the growth of photosynthetic organisms (algae), which may then cause odour and taste problems. High manganese, especially in conjunction with high iron, may cause staining.

CAN TEST LTD.

Judi M. Mitchell, B.Sc.
Chemist



can test ltd.

1650 PANDORA STREET, VANCOUVER, B.C. V5L 1L6 • TELEPHONE 254-7278 • TELEX 04-54210

Report On Analysis of Water Samples File No. 2374 D
Report No. _____
Reported To Brown Erdman & Associates Ltd. P.O. # October 3, 1979
1401 Bewicke Avenue, Date _____
North Vancouver, B.C.
Attention: _____

We have tested the sample of water submitted by you on Sept. 18, 1979
and report as follows:

SAMPLE IDENTIFICATION:

The sample submitted was in a plastic bottle labelled:

Eagle Ridge Hospital
78-092
Pt. Moody
18/9/79 1260 mins 9.5°C

METHOD OF TESTING:

The analyses were carried out in accordance with procedures described in:

"Standard Methods for the Examination of Water and Wastewater (14th Edition)"
published by the American Public Health Association, 1975.

File No. 2374D
Page No. 2
October 3, 1979

RESULTS OF TESTING:

TEST

EAGLE RIDGE HOSPITAL

Physical Tests

pH		8.05
Conductance (umhos/cm)		117.
Colour (CU)		L5.
Turbidity (JTU)		0.13
Total Dissolved Solids (mg/L)		104.
Total Suspended Solids (mg/L)		L0.2

Dissolved Anions (mg/L)

Alkalinity		
Bicarbonate	HCO_3	55.0
Carbonate	CO_3	NIL
Chloride	Cl^-	L0.5
Sulfate	SO_4	L8.
Nitrate & Nitrite	N	L0.001
Phosphate	PO_4	0.36*
Fluoride	F	0.096
Silica	SiO_2	27.8

Dissolved Cations (mg/L)

Total Hardness	CaCO_3	58.1
Calcium	Ca	10.7
Magnesium	Mg	2.78
Sodium	Na	4.93
Potassium	K	1.88
Iron	Fe	0.030
Manganese	Mn	0.077
Cadmium	Cd	L0.001
Copper	Cu	0.002
Lead	Pb	L0.001
Zinc	Zn	0.003

Others (mg/L)

Total Iron	Fe	10.030
Total Manganese	Mn	0.078

L = Less than, mg/L = milligrams per liter (or parts per million for drinking water)

* Rechecked and verified.

File No. 2374D
Page No. 3
October 3, 1979.


REMARKS:

The water represented by the sample submitted can be characterized as a moderately soft water, moderate with respect to dissolved mineralization. For the parameters tested the sample met the limits set by the Canadian Drinking Water Standards and Objectives, 1968 with the exception of dissolved phosphates (limit = 0.2mg/L) and dissolved manganese (limit = 0.05 mg/L).

Both of these parameters are limited for aesthetic reasons. Phosphates, especially in open reservoirs, may promote the growth of photosynthetic organisms (algae), which may then cause odour and taste problems. High manganese, especially in conjunction with high iron, may cause staining.

CAN TEST LTD.

Judi M. Mitchell, B.Sc.
Chemist



M.I.T. GRAIN SIZE CLASSIFICATION		GRAIN SIZE ANALYSIS	
SILT	SAND	FINE	MEDIUM
		COARSE	COARSE
			GRAVEL


BROWN, ERDMAN & ASSOCIATES LTD.

EAGLE RIDGE HOSPITAL

PORT MOODY

BY: M.W.R. DATE: 8-9-79

JOB: 78-092 DWS:




SCREEN OPENING - INCHES		
FINE	MEDIUM	COARSE
SILT	SAND	GRAVEL

M.I.T. GRAIN SIZE CLASSIFICATION

BROWN, ERDMAN & ASSOCIATES LTD.



EAGLE RIDGE HOSPITAL	GRAIN SIZE ANALYSIS	DATE: 8-9-79
PORT MOODY	JOB: 78-092	DWG:




	FINE	MEDIUM	COARSE	FINE	MEDIUM	COARSE
SILT						
SAND						
	.002	.006	.01	.02	.06	.2

M.I.T. GRAIN SIZE CLASSIFICATION

EAGLE RIDGE HOSPITAL PORT MOODY	GRAIN SIZE ANALYSIS
------------------------------------	---------------------

BROWN, ERDMAN & ASSOCIATES LTD.

BY:	H.W.P.	DATE:	8-9-79
JOB:	78-092	DWG.:	




SILT	FINE	MEDIUM	COARSE	FINE	MEDIUM	COARSE

M.I.T. GRAIN SIZE CLASSIFICATION

BROWN, ERDMAN & ASSOCIATES LTD.



EAGLE RIDGE HOSPITAL	GRAIN SIZE ANALYSIS	
PORT MOODY	BY:	DATE:
	H.W.P.	8-9-79
	UNIT:	DWG.:
	78-092	



SCREEN OPENING - INCHES			
SILT	FINE	MEDIUM	COARSE
.002	.006	.016	.04
.004	.012	.025	.06
.006	.018	.035	.10
.008	.025	.05	.15
.01	.035	.07	.20
.015	.05	.10	.30
.02	.07	.15	.40
.03	.10	.20	.50
.05	.15	.30	.70
.08	.20	.40	1.00
.12	.25	.50	1.50
.20	.40	.80	2.50
.30	.50	1.00	4.00
.40	.60	1.20	5.00
.50	.70	1.40	6.00
.60	.80	1.60	7.00
.70	.90	1.80	8.00
.80	1.00	2.00	9.00
.90	1.10	2.20	10.00
1.00	1.20	2.40	11.00

M.I.T. GRAIN SIZE CLASSIFICATION

BROWN, ERDMAN & ASSOCIATES LTD.

EAGLE RIDGE HOSPITAL
PORT MOODY

BY:	DATE:
HWR	8-9-79
78-092	

GRAIN SIZE ANALYSIS

HOLE NO. <u>2</u>					HOLE NO. <u>2</u>				
SAMPLE NO. <u>90'</u>					SAMPLE NO. <u>90'</u>				
DEPTH <u>90'</u>					DEPTH <u>90'</u>				
TARE NO. <u>90</u>					TARE NO.				
SIEVE OPENING MM	U S STANDARD SIEVE	WEIGHT RETAINED G	WEIGHT RETAINED SUM	PERCENT RETAINED	SIEVE OPENING MM	U S STANDARD SIEVE	WEIGHT RETAINED G	WEIGHT RETAINED SUM	PERCENT RETAINED
	- Discard	3/4"	+ -						
8	5/16"	223.9	223.9	24.41	8	5/16"			
4	5	154.5	378.4	41.25	4	5			
2	10	136.3	514.7	56.11	2	10	- Discard	#10 + -	
1	18	74.4	589.1	64.22	1	18	74.4	74.4	18.5
0.500	35	67.5	656.6	71.58	0.500	35	67.5	141.9	35.2
0.250	60	168.7	825.3	89.97	0.250	60	168.7	310.6	77.1
0.125	120	71.7	897.0	97.79	0.125	120	71.7	382.3	95.0
PAN		20.3	917.3	100	PAN		20.3	402.6	100
TOTAL		917.3			TOTAL		402.6		

HOLE NO. <u>2</u>					HOLE NO. <u>2</u>				
SAMPLE NO. <u>95'</u>					SAMPLE NO. <u>95'</u>				
DEPTH <u>95'</u>					DEPTH <u>95'</u>				
TARE NO. <u>85</u>					TARE NO.				
SIEVE OPENING MM	U S STANDARD SIEVE	WEIGHT RETAINED G	WEIGHT RETAINED SUM	PERCENT RETAINED	SIEVE OPENING MM	U S STANDARD SIEVE	WEIGHT RETAINED G	WEIGHT RETAINED SUM	PERCENT RETAINED
	- Discard	3/4"	+ -						
8	5/16"	242.4	242.4	25.74	8	5/16"			
4	5	132.8	375.2	39.84	4	5			
2	10	97.1	472.3	50.15	2	10	- Discard	#10 + -	
1	18	65.1	537.4	57.06	1	18	65.1	65.1	13.87
0.500	35	134.5	671.9	71.34	0.500	35	134.5	199.6	42.51
0.250	60	199.3	871.2	92.50	0.250	60	199.3	328.9	84.96
0.125	120	57.5	928.7	98.61	0.125	120	57.5	456.4	97.21
PAN		13.1	941.8	100	PAN		13.1	469.5	100
TOTAL		941.8			TOTAL		469.5		



BROWN, ERDMAN & ASSOCIATES LTD.

EAGLE RIDGE HOSPITAL

PORT HOODY

GRAIN SIZE ANALYSIS

BY: HWR	DATE: 8-9-79
JOB: 28-092	DWG:

HOLE NO.	<u>2</u>			
SAMPLE NO.				
DEPTH	<u>98'</u>			
TARE NO.	<u>2</u>			
SIEVE OPENING MM	U S STANDARD SIEVE	WEIGHT RETAINED G	WEIGHT RETAINED SUM	PERCENT RETAINED
		— Discard	$\frac{3}{4}'' +$	
8	5/16"	157.2	157.2	18.27
4	5	71.0	228.2	26.52
2	10	46.3	274.5	31.90
1	18	44.4	318.9	37.06
0.500	35	103.6	422.5	49.11
0.250	60	236.6	659.1	76.60
0.125	120	150.8	809.9	94.13
PAN		50.5	860.4	100
TOTAL		860.4		

HOLE NO.	<u>2</u>			
SAMPLE NO.				
DEPTH	<u>105'</u>			
TARE NO.	<u>3</u>			
SIEVE OPENING MM	U S STANDARD SIEVE	WEIGHT RETAINED G	WEIGHT RETAINED SUM	PERCENT RETAINED
		— Discard	$\frac{5}{16}'' +$	
8	5/16"	5/16"	— Discard	$\frac{5}{16}'' +$
4	5	287.3	287.3	26.73
2	10	258.4	545.7	50.77
1	18	149.8	695.5	64.21
0.500	35	113.8	809.3	75.30
0.250	60	169.5	918.8	91.07
0.125	120	73.2	1052.0	97.88
PAN		22.8	1074.8	100
TOTAL		1074.8		

HOLE NO.	<u>2</u>			
SAMPLE NO.				
DEPTH	<u>105'</u>			
TARE NO.				
SIEVE OPENING MM	U S STANDARD SIEVE	WEIGHT RETAINED G	WEIGHT RETAINED SUM	PERCENT RETAINED
		— Discard	$\frac{3}{4}'' +$	
8	5/16"			
4	5			
2	10			
1	18	— Discard	$\frac{1}{8}'' +$	
0.500	35	113.8	113.8	30.00
0.250	60	169.5	283.3	74.69
0.125	120	73.2	356.5	93.99
PAN		22.8	379.3	100
TOTAL		379.3		

HOLE NO.	<u>2</u>			
SAMPLE NO.				
DEPTH	<u>110'</u>			
TARE NO.	<u>R</u>			
SIEVE OPENING MM	U S STANDARD SIEVE	WEIGHT RETAINED G	WEIGHT RETAINED SUM	PERCENT RETAINED
		— Discard	$\frac{3}{4}'' +$	
8	5/16"	108.4	108.4	10.11
4	5	274.2	382.6	35.68
2	10	228.9	611.5	57.03
1	18	141.1	752.6	70.19
0.500	35	118.0	820.6	81.20
0.250	60	109.3	919.9	91.39
0.125	120	50.7	1030.6	96.12
PAN		41.6	1072.2	100
TOTAL		1072.2		



BROWN, ERDMAN & ASSOCIATES LTD.

EAGLE RIDGE HOSPITAL


GRAIN SIZE ANALYSIS

BY: HWR DATE: 8-9-79
JOB: DWG:

78-092


PORT MOODY


WTN 71239



EAGLE RIDGE HOSPITAL
TEST WELL NO. 2

BROWN, ERDMAN & ASSOCIATES LTD.
4-10-79 . HWR 78-092







Province of British Columbia

Ministry of Environment

Water - Investigations Branch

WATER WELL RECORD

Date 1981-01-01

Legal Description & Address

Descriptive Location Crozier Vancouver Sections, Hospital District, 220 West Ninth AvenueOwners Name & Address Crozier Vancouver Sections, Hospital District, 220 West Ninth AvenueNTS MAP 100 UTM ZONE 10 ELEV 1000 WELL No. 100WELL ID 100 Date 1981-01-01

1. TYPE	1 <input type="checkbox"/> New Well	2 <input type="checkbox"/> Reconditioned	3 <input type="checkbox"/> Jettied	4 <input type="checkbox"/> Abandoned
2. WORK OF METHOD	1 <input type="checkbox"/> Cable tool	2 <input type="checkbox"/> Bored	3 <input type="checkbox"/> Air	4 <input type="checkbox"/> Reverse
3. WATER WELL USE	1 <input type="checkbox"/> Domestic	2 <input type="checkbox"/> Municipal	3 <input type="checkbox"/> Irrigation	4 <input type="checkbox"/> Commercial & Industrial
4. DRILLING ADDITIVES	5 <input type="checkbox"/> Other			

5. MEASUREMENTS from 1 ground level 2 top of casing SWL 1000FROM 40 TO 60 ft

6. WELL LOG DESCRIPTION

FROM	TO	Material	SWL
0	33	Bricklaying tile	
33	60	Very coarse sand gravel & boulders	

60	63	Medium coarse sand	SWL
63	65	Medium sand gravel & boulders	
65	68	Coarse sand gravel & boulders	
68	71	Medium to coarse sand	
71	75	Medium to coarse sand	
75	80	Very fine medium sand	
80	85	Medium to coarse sand	
85	90	Medium to coarse sand	
90	95	Medium to coarse sand	
95	100	Medium to coarse sand	

7. CONSULTANT _____

Address _____

8. WELL LOCATION SKETCH

1. CASING:	1 <input type="checkbox"/> Steel	2 <input type="checkbox"/> Galvanized	3 <input type="checkbox"/> Wood
Materials	4 <input type="checkbox"/> Plastic	5 <input type="checkbox"/> Concrete	6 <input type="checkbox"/> Other
Hole Diameter	S		
from	0		
to	21		
Thickness	.200		
Weight	200 lb		

9. PITLESS UNIT 1000 ft 1 above 2 below ground level1 Welded 2 Cemented 3 Threaded 4 New 5 Used

Perforations: _____

Shoe(s): cutOpen hole, from 0 to 1000 ftDiameter 10 ins

Grout: _____

10. SCREEN: 1 Nominal 2 Pipe SizeType 1 Continuous Slot 2 Perforated 3 Louvre4 OtherMaterial 1 Stainless Steel 2 Plastic 3 OtherSet from 0 to 1000 ft below ground level

SCREEN & BLANKS

Length _____

Diam. ID _____

Slot Size 2 mils .010 in 10 ftRate 100 USgpm Temp 50 °C SWL before test 1000 ftft after test of 26 hrsBottom 500 ft

Gravel Pack _____

11. DEVELOPED BY: 1 Surging 2 Jetting 3 Air4 Boiling 5 Pumping 6 Other12. TEST: 1 Pump 2 SoilDate 1981-01-01 min 0 hr 0 sec

TIME in mins & DRAWDOWN in ft RECOVERY in ft

13. RECOMMENDED PUMP TYPE: 1000 USgpm SETTING: 1000 ft

TIME in mins & DRAWDOWN in ft RECOMMENDED PUMPING RATE

14. WATER TYPE: 1 Fresh 2 Salty 3 Clear 4 Cloudycolour clear smell none; gas 1 yes 2 no15. WATER ANALYSIS: 1 Hardness 100 mg/l2 Iron 100 mg/l 3 Chloride 100 mg/l4 pH 7.5 Field Date 1981-01-01Well Head Completion ScreenedSite ID No. 100 Lab Date 1981-01-01

16. FINAL WELL COMPLETION DATA

Well Depth 1000 ft Water Flowing 1000 USgpmStatic Water Level 721 ft Pressure Head 100 ftBore filled noWell Head Completion Screened

Signature _____

Member, BCWWD yes no no17. DRILLER: PLEASE PRINT SURNAME RURAL WELL DRILLERS LTD. FIRST NAME RURALADDRESS 13117-116th AVE.CITY SURREY, PROV. B.C.POSTAL CODE V3R 2S8

The Province of British Columbia accepts no responsibility for the contents or accuracy of this record.