

BROWN, ERDMAN & TURNER LTD.

1409 BEWICKE AVENUE, NORTH VANCOUVER, BRITISH COLUMBIA V7M 3C7
TELEPHONE 988-1657

**HYDROGEOLOGIC EVALUATION
FOR PHASE 1 OF
SUBDIVISION ADJOINING
238A STREET & 62ND AVENUE
LANGLEY, BRITISH COLUMBIA**

FOR

J.G. NEUFELD

C/O GOODBRAND INTERNATIONAL INC.

Subdivision Application No. 87-111

Legal Description

Lot B of 2 and 3, Plan 13274 and Parcel A
(Reference Plan 8562) of Lots 2, 3 and 4, Except
Plan 17067, Plan 23779 and part of Lot 31, Plan
54464, all of North East 1/4 of Section 9, Township 11, N.W.D.

W.L. Brown, P.Eng

July, 1988

1.0 INTRODUCTION

- 1.1 This Hydrogeologic Evaluation of Phase 1 of the subject subdivision is based upon Analyses of:
 - 1.1.1 Two-hour constant rate pumping tests followed by two hours of recovery readings that were run on each of the domestic wells located on the 12 lots of Phase 1 of the subject Subdivision. A well was not drilled on Lot 9.
 - 1.1.2 Existing maps and reports of the general area.
 - 1.1.3 Available records of wells on adjacent properties.
 - 1.1.4 Chemical and bacteriological analyses of water samples collected near the end of the pumping period on each well. Analysis of water samples were conducted by ASL, Consulting Chemists and Analysts, of Vancouver, B.C.
- 1.2 As such this report is written to fulfill the requirements of Section 2.2.18 "Private Wells" of the Corporation of the Township of Langley subdivision guidelines dated 87.06.09. Corporation forms F-5, 6, 7 and 8 have been completed for each domestic well.
- 1.3 The wells were designed and constructed by Walsh Well Drilling of Aldergrove, B.C.

2.0 HYDROGEOLOGY

- 2.1 Location - The subdivision is located in the central part of the Township on a terrace that lies above the north bank of the Salmon River Valley. Terrace elevations range between 50 and 60 metres above sea level which is approximately 20 m above the Salmon River Valley floor. Please see attached map Figure 1.
- 2.2 Geology - The attached Surficial Geology Map, Figure 1a shows that the site is underlain by glacial and deltaic sediments of the Fort Langley Formation. These sediments are composed of deltaic sands and gravels

deposited by rivers flowing off the front of a glacier.

The details of this sedimentary deposit are shown on the geologic sections, Figures 3 and 4. These sections are based upon the driller's logs of the various domestic wells. The lower part of the deposits to a depth of approximately 45 metres is underlain by glacial tills with gravel, sand and clay interbeds. The lower sand and gravel beds that have been screened in the wells are areally extensive beneath the subdivision and have static water levels that lie at an approximate elevation of 30 meters above sea level. Impermeable clay and till units overlie the screened intervals across the site. A deltaic sand and gravel unit caps the section from ground surface downwards to the top of the clay. As can be seen these near surface sands and gravels lie in old buried river channels cut into the clay.

- 2.3 Hydrology - The pump test data indicate that the aquifers screened in the wells are artesian, areally extensive and moderately productive. Well spacing ranges from 30 to 50 metres. Calculations based upon transmissivity values obtained from the pumping tests, an assumed storativity factor for this artesian system, the general recommended pumping rate of 10 lpm (2.5 U.S. gpm) for each well and an assumed drought of 100 days show that well interference should range from 0.09 to 0.61 metres.

Reference to from F-7 of each well will show that a 2 to 4 meter drop below the static water level measured when the pump tests were run has been assumed in rating the productive capacity (pumping rate) of each well. The pumping rate of each well on this basis will still allow for the 0.09 to 0.61 metres of interference between wells under the stringent 100-day drought conditions used in these calculations.

Precipitation records from the Abbotsford weather station (local Langley stations have been closed) show the following patterns:

<u>Month 1988</u>	<u>Precipitation mm</u>	<u>% of 1951-80 Normal</u>
January	110.8	53
February	107.5	67
March	154.7	110
April	161.8	158
May	165.6	211
June	49.7	77

The relatively deep depth of the screened aquifer of generally 30 m (100 feet) and the impervious caps of clay and till indicate that there will be a considerable time lag between the fluctuation of the water level in the aquifer and the fluctuations of the weather. The pump tests were conducted in the latter part of the May and in the first half of June (Well 13 was tested at the end of June). The effect of the "dry" winter of 1987-88 would most probably have caused low water levels in the wells when the pump tests were run.

Available information on neighbouring wells to the north and south-east of the subdivision indicates that the existing wells are either shallow (less than 10 m) or deep (over 50 m). As such these wells are most probably using aquifers that are not directly connected to the aquifer used by the subdivision wells.

Also, the closest neighbouring wells are over 80 m away from the subdivision wells so that even if the aquifers of the wells were interconnected interference would be negligible.

A well summary table is attached for convenience. It will be noted that 8 wells have a recommended pumping rate of 10 Lpm (2.5 U.S. gpm), 2 have a pumping rate of 5 Lpm and 2 have a recommended pumping rate of 2 Lpm. The recommended pumping rates are all above the minimum rate of 1.74 Lpm (2,500 litres per day) set by the Township of Langley Guidelines.

- 2.4 Water Quality - The laboratory results of the chemical and bacteriological analyses conducted on water samples collected near the end of each pump test are attached. It will be noted that the water meets the acceptable

W E L L S U M M A R Y T A B L E

Well No.	Depth Metres	Static Water M	Screened Interval M	Available Drawdown M	Recommended Pump Setting M	Recommended Pumping Rate Lpm	Recommended Pumping Rate U.S. gpm	Chemical Bacteriologic
1	32.61 ¹⁰⁶	14.4	30.94-31.85	16.54	30	10	(2.6)	OK
2	21.64 ⁷¹	15.54	20.24-21.64	4.70	20	2	(0.5)	OK
3	45.42 ¹⁴⁹	19.07	43.99-45.42	24.92	30	10	(2.6)	OK
4	36.58 ¹²⁰	20.10	35.15-36.58	15.05	30	10	(2.6)	OK
5	34.11 ¹¹²	20.88	32.61-34.14	11.73	30	10	(2.6)	OK
6	24.08 ⁷⁹	17.97	22.66-24.08	4.69	22	5	(2.6)	OK
7	36.88 ¹²¹	15.61	35.46-36.88	19.85	35	10	(2.6)	OK
8	29.57 ⁹⁷	15.89	27.83-29.26	11.94	27	10	(2.6)	OK
9	NOT DRILLED							
10	22.86 ⁷⁵	18.22	21.43-22.86	3.21	21	2	(1.3)	OK
11	25.30 ⁸⁸	16.65	23.87-25.45	7.22	23	5	(1.3)	OK
12	42.37 ¹³⁹	21.23	40.94-41.30	19.71	40	10	(2.6)	OK
13	45.42 ¹⁴⁹	20.86	43.98-45.42	23.12	40	10	(2.6)	OK



The Corporation of the Township of Langley

SCHEDULE "A"

PRIVATE WELL CERTIFICATION

PURSUANT TO SCHEDULE "A" of the Subdivision and Development Control Bylaw, I hereby certify that each lot to be created and/or each existing lot forming part of the proposed development can be serviced with potable water in accordance with the requirements of the Bylaw for the development of:

LEGAL DESCRIPTION: Lot 1 (Phase 1)

PROJECT NO.: 87-111

I certify that a quantity of not less than 2,500 litres per day has been proven for each existing or proposed lot in the development.

I certify that water quality tests have been conducted and that the "B.C. Drinking Water Standards, 1982" can be met for each existing or proposed lot in the development.

R. L. Brown

Certified By (Name of Professional Engineer)

1409 Bewick Ave

Address

North Vancouver B.C. V7M 3C7

PROFESSIONAL
SEAL

See attachments as required pursuant to clause 2.2.18 of Schedule "A".

Subdivision Application No. 87-111
Lot B of Lots 2 and 3, Plan 13274 and Parcel A
(Reference Plan 8562) of Lots 2, 3 and 4, Except
Plan 17067, Plan 23779 and part of Lot 31, Plan
54464, all of North East 1/4 of Section 9, Township 11, N.W.D.

WTN 108020

GOODBRAND DEVELOPMENT CORPORATION
62ND AVE., LANGLEY, BRITISH COLUMBIA


Well on Lot 1 (S.E. Corner) (Phase 1)

Depth (Below Ground Surface)				Description
Metres	Feet			
0.00 - 0.61	0 - 2			Soil sandy loam
0.61 - 1.83	2 - 6			Sand, brown
1.83 - 3.66	6 - 12			Sand and gravel silty tight
3.66 - 5.79	12 - 19			Clay, sandy, pebbly
5.79 - 6.71	19 - 22			Sand, silty some water
6.71 - 7.62	22 - 25			Sand, brown, hard packed
7.62 - 8.84	25 - 29			Sand and gravel dry
8.84 - 11.28	29 - 37			Clay, sandy, pebbly
11.28 - 11.89	37 - 39			Sand, silty
11.89 - 14.02	39 - 46			Sand brown dry
14.02 - 15.85	46 - 52			Sand and gravel, <u>water-bearing</u>
15.85 - 29.87	52 - 98			Clay, silty, grey with sand and gravel interbeds
29.87 - 31.88	98 - 104.5			Sand and gravel, <u>water-bearing</u>
31.88 - 32.61	104.5 - 107			Clay, grey

Construction details - below ground surface

	Metres	Feet
152 mm (6-inch) diameter casing	+ 0.46 - 30.78	+ 1.5 - 101.0
152 mm (6-inch) telescopic diameter screen	30.94 - 31.85	101.5 - 104.5

Screen - stainless steel, 20 slot with K-packer
Thick Bentonite Slurry seal around top 3m (10 feet) of casing



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 1 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 06 16

LOCATION: 238A Street & 62 Ave.


SHEET 1 of 6

Township of Langley

TEST NO. 2

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
1	0	14.86	0				Static Water Level below MPT
2	.5	16.29	1.43				Measuring Point - Top of
3	1.0	17.05	2.19				Casing 0.46 m above ground.
4	1.5	.87	3.01				
5	2.0	18.46	.60				Discharge 30 m from well
6	2.5	19.10	4.24				
7	3.0	.42	.56				
8	3.5	.91	5.05				
9	4.0	20.18	.32	0.5	20	40	Water clear and clean
10	4.5	.42	.56				
11	5.0	.68	.82				
12	6.0	21.00	6.14				
13	7.0	.15	.29				
14	8.0	.39	.53				
15	9.0	.46	6.60				
16	10	.62	.76				
17	12	.76	.90				
18	14	.86	7.00				
19	16	.92	.06				
20	18	22.01	.15				
21	20	.01	.15				
22	25	.03	.17				
23	30	.18	.32				
24	35	.21	.35				
25	40	.27	.41				
26	45	22.32	7.46				



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 1 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 06 16

LOCATION: 238A Street & 62 Ave.


SHEET 2 of 6

Township of Langley

TEST NO. 2

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
	(Min)	(M)	(M)	(Min)	L	LPM	
27	50	.35	.49				
28	60	.41	.58				
29	70	.46	.60				
30	80	.48	.62				
31	90	.56	.70				
32	100	.57	.71				
33	110	.66	.80				Water Samples collected
34	120	.67	.81				



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 1 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 06 16

LOCATION: 238A Street & 62 Ave.


SHEET 3 of 6

Township of Langley

TEST NO. 2

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
1	0	22.67	7.81				Pump off
2	.5	21.48	6.62				
3	1.0	20.60	5.74				
4	1.5	19.80	4.94				
5	2.0	.16	.30				
6	2.5	18.71	3.85				
7	3.0	.29	.43				
8	3.5	17.93	.07				
9	4.0	.59	2.73				
10	4.5	.30	.44				
11	5.0	.10	.24				
12	6.0	16.82	1.96				
13	2.0	.51	.65				
14	8.0	.37	.51				
15	9.0	.22	.36				
16	10	.07	.21				
17	12	15.92	.06				
18	14	.82	0.96				
19	16	.75	.89				
20	18	.69	.83				
21	20	.64	.78				
22	25	.58	.72				
23	30	.50	.64				
24	35	.44	.58				
25	40	.41	.55				
26	45	15.37	0.51				



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 1 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 06 16

LOCATION: 238A Street & 62 Ave.


SHEET 4 of 6

Township of Langley

TEST NO. 2



Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data		Comments
	(Min)	(M)		(Min)	L LPM	
27	50	.34	.48			
28	60	.29	.43			
29	70	.24	.38			
30	80	.19	.33			
31	90	.17	.31			
32	100	.15	.29			
33	110	.13	.27			
34	120	.11	.25			



TIME - DRAWDOWN GRAPH FOR PUMP TEST

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 1 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 06 16
 LOCATION: 238A & 62nd Ave. SHEET 5 OF 6
 DEPTH TO STATIC WATER LEVEL: 14.40 (m) TEST NO. 2
 Below existing ground



Pumping rate 1.0 Lpm Drawdown at 30 days (S_{30}) $9.6 \times 10/4(m) = 2.4$

Estimated minimum adjustment for seasonal decline (D); Use following figures if other local data or hydrogeologist's opinion is not available.


Tests run in summer time: 2 m
 Tests run in winter time: 6 m
 Tests run in fall and spring: use intermediate values 2 m to 6 m

Depth to proposed pump suction (D_p) 30 m

Calculate minimum available drawdown: $D_p - (D_{TW} + S_{30} + D) =$

$$30 - (14.40 + 2.4 + 4) = 9.2$$

If answer to above calculation is negative, then either the pump has to be set lower or the well is not capable of supplying water for a house.



The Corporation of the Township of Langley

SCHEDULE "A"

PUMP TEST SUMMARY

OWNER'S NAME: Goodbrand Development WELL NO. 1 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 06 16
 LOCATION: 238A & 62nd Ave. SHEET 6 OF 6
Township of Langley TEST NO. 2

WELL COMPLETION DATA		SCREEN DESIGN (mark one)	DESCRIPTION OF AQUIFER
Depth <u>32.61</u> (m)	<input type="checkbox"/> Open Hole	<input type="checkbox"/> Slotted Casing	<u>Sand & Gravel</u>
Diameter <u>152</u> (mm)	<input checked="" type="checkbox"/> Screen	<input type="checkbox"/> Gravel Pack	
Static Water Level <u>14.4</u> (m)	<input type="checkbox"/> Other _____		
	Screen interval <u>30.94</u> m to <u>31.85</u> m		
PUMP TEST			
Start: Date <u>16 06 1988</u>	Time <u>0855</u>		
	<u>d/mo/yr</u>	<u>hr/min</u>	
Pump Type: <input checked="" type="checkbox"/> Electric submersible	<input type="checkbox"/> Jet	<input type="checkbox"/> Air Lift	
Other? Describe _____			
Test Pump Set at <u>30</u> m below ground			
Water level sounded by: <input checked="" type="checkbox"/> Electric tape	<input type="checkbox"/> Air bubbler	<input type="checkbox"/> Steel tape	
<input type="checkbox"/> Other? Describe _____			
Flow measured by: <input checked="" type="checkbox"/> Container & watch	<input type="checkbox"/> Flow meter		
<input type="checkbox"/> Orifice & lube	<input type="checkbox"/> Other? Describe _____		
TEST			
Constant rate of yield <u>40</u> Lpm	Test duration <u>2</u> hours		
Initial non-pumping level <u>14.4</u> m			
Drawdown in well at end of test <u>7.81</u> m			
Recommended pumping rate <u>10</u> Lpm			
WATER SAMPLES TAKEN DURING TEST			
Chemical Analysis <input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		
Bacterial Analysis <input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		
Water Temperature <u>9</u> °C			
Any particular gas smells noted <u>None</u>			
Comments on clarity of water <u>Clear and Clean</u>			
Other _____			



The Corporation of the Township of Langley

SCHEDULE "A"

PRIVATE WELL CERTIFICATION

PURSUANT TO SCHEDULE "A" of the Subdivision and Development Control Bylaw, I hereby certify that each lot to be created and/or each existing lot forming part of the proposed development can be serviced with potable water in accordance with the requirements of the Bylaw for the development of:

LEGAL DESCRIPTION: Lot 2 (Phase 1)

PROJECT NO.: 87-111

I certify that a quantity of not less than 2,500 litres per day has been proven for each existing or proposed lot in the development.

I certify that water quality tests have been conducted and that the "B.C. Drinking Water Standards, 1982" can be met for each existing or proposed lot in the development.

B.L. Brown
Certified By (Name of Professional Engineer)

1409 Bewick Ave.
Address

North Vancouver, B.C. V7M 3C7

PROFESSIONAL
SEAL

See attachments as required pursuant to clause 2.2.18 of Schedule "A".

Subdivision Application No. 87-111
Lot B of Lots 2 and 3, Plan 13274 and Parcel A
(Reference Plan 8562) of Lots 2, 3 and 4, Except
Plan 17067, Plan 23779 and part of Lot 31, Plan
54464, all of North East 1/4 of Section 9, Township 11, N.W.D.

WTN 108021

GOODBRAND DEVELOPMENT CORPORATION
62ND AVE., LANGLEY, BRITISH COLUMBIA


Well on Lot 2 (S.E. Corner) (Phase 1)

Depth (Below Ground Surface)				Description
Metres		Feet		
0.00 - 0.31	0	-	1	Soil sandy loam
0.31 - 1.83	1	-	6	Sand and gravel, brown
1.83 - 5.18	6	-	17	Sand, brown, silty
5.18 - 11.28	17	-	37	Clay, sandy, pebbly
11.28 - 11.43	37	-	37.5	Sand and gravel, <u>water bearing</u>
11.43 - 18.29	37.5	-	60	Clay, sandy, pebbly
18.29 - 19.81	60	-	65	Sand, silty, grey
19.81 - 21.64	65	-	71	Sand and gravel, <u>water bearing</u>
21.64 -	71			Till

Construction details - below ground surface

	Metres	Feet
152 mm (6-inch) diameter casing	+ 0.46 - 20.57	+ 1.5 - 67.5
152 mm (6-inch) telescopic diameter screen	20.24 - 21.64	66.4 - 71

Screen - stainless steel, 25 slot with K-packer
Top 3 m (10 feet) sealed with thick bentonite slurry outside of casing



The Corporation of the Township of Langley


SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 2 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 05 24
 LOCATION: 238A St. & 62 Ave. SHEET 1 OF 6
Township of Langley TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
1	0	16.00	0				Static Water Level below MPT
2	.5	.60	0.60				Measuring Point-Top of casing
3	1.0	.95	0.95	1	20	20	0.46 m above ground
4	1.5	17.20	1.20				Discharge 40 m from well
5	2.0	.49	1.49				
6	2.5	.71	1.71				
7	3.0	.82	1.82				
8	3.5	.81	1.81				
9	4.0	.89	1.89				
10	4.5	.92	1.92				
11	5.0	.93	1.93				
12	6.0	.98	1.98				
13	7.0	18.01	2.01				
14	8.0	.02	2.02				
15	9.0	.03	2.03				
16	10	.04	2.04				
17	12	.05	2.05				
18	14	.07	2.07				
19	16	.07	2.07				
20	18	.08	2.08	1	20	20	Water clear and clean
21	20	.09	2.09				
22	25	.11	2.11				
23	30	.12	2.12				
24	35	.13	2.13				
25	40	.14	2.14				
26	45	.15	2.15				



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 2 (Phase 1)
APPLICATION NO.: 87-111 DATE: 1988 05 24
LOCATION: 238 A St. & 62 Ave. SHEET 2 OF 6
Township of Langley TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
27	50	18.16	2.16				
28	60	.17	2.17				
29	70	.18	2.18				
30	80	.19	2.19				
31	90	.18	2.18				
32	100	.20	2.20	1	20	20	Water clear, clean & tasteless
33	110	.21	2.21				Water samples collected
34	120	.21	2.21				



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 2 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 05 24
 LOCATION: 238 A St. & 62 Ave. SHEET 3 OF 6
Township of Langley TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
	(Min)	(M)	(M)	(Min)	L	LPM	
1	0	18.21	2.21				Pump off
2	.5	17.88	1.44				
3	1.0	.38	1.38				
4	1.5	.09	1.09				
5	2.0	16.88	.88				
6	2.5	.72	.72				
7	3.0	.59	.59				
8	3.5	.50	.50				
9	4.0	.44	.44				
10	4.5	.38	.38				
11	5.0	.35	.35				
12	6.0	.28	.28				
13	7.0	.26	.26				
14	8.0	.22	.22				
15	9.0	.20	.20				
16	10	.18	.18				
17	12	.17	.17				
18	14	.16	.16				
19	16	.14	.14				
20	18	.13	.13				
21	20	.12	.12				
22	25	.10	.10				
23	30	.11	.11				
24	35	.08	.08				
25	40	.08	.08				
26	45	.08	.08				



The Corporation of the Township of Langley


SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 2 (Phase 1)
APPLICATION NO.: 87-111 DATE: 1988 05 24
LOCATION: 238 A St. & 62 Ave. SHEET 4 OF 6
Township of Langley TEST NO. _____

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down (M)	Flow Measurement Data			Comments
	(Min)	(M)		(Min)	L	LPM	
27	50	16.07	.07				
28	60	.07	.07				
29	70	.05	.05				
30	80	.05	.05				
31	90	.05	.05				
32	100	.04	.04				
33	110	.03	.03				
34	120	.03	.03				



The Corporation of the Township of Langley

SCHEDULE "A"

TIME - DRAWDOWN GRAPH FOR PUMP TEST


OWNER'S NAME: Goodbrand Development Corp. WELL NO. 2.(Phase 1)

APPLICATION NO.: 87-111 DATE: 1988 05 24

LOCATION: 238 A St. & 62 Ave. SHEET 5 OF 6

DEPTH TO STATIC WATER LEVEL: 16.00* or 15.54** TEST NO. _____

* Below Top Casing ** Below Ground



Pumping rate 2 Lpm Drawdown at 30 days (S_{30}) .30 (m)


Estimated minimum adjustment for seasonal decline (D): Use following figures if other local data or hydrogeologist's opinion is not available.

- Tests run in summer time: 2 m
- Tests run in winter time: 6 m
- Tests run in fall and spring: use intermediate values 2 m to 6 m

Depth to proposed pump suction (D_p) 20 m

Calculate minimum available drawdown: $D_p - (D_{TW} + S_{30} + D) =$
20 - (15.54 + .30 + 3') = 1.16

If answer to above calculation is negative, then either the pump has to be set lower or the well is not capable of supplying water for a house.



The Corporation of the Township of Langley

SCHEDULE "A"

PUMP TEST SUMMARY

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 2 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 05 24
 LOCATION: 238A St. & 62 Ave. SHEET 6 OF 6
Township of Langley TEST NO. 1

WELL COMPLETION DATA		SCREEN DESIGN (mark one)		DESCRIPTION OF AQUIFER
Depth	<u>21.64</u> (m)	<input type="checkbox"/> Open Hole	<input type="checkbox"/> Slotted Casing	<u>Sand & Gravel</u>
Diameter	<u>152</u> (mm)	<input checked="" type="checkbox"/> Screen	<input type="checkbox"/> Gravel Pack	
Static Water Level	<u>15.54</u> (m)	<input type="checkbox"/> Other		
		Screen interval <u>20.24</u> to <u>21.64</u>		
PUMP TEST				
Start: Date	<u>24 05 1988</u>	Time	<u>1310</u>	
	d/mo/yr		hr/min	
Pump Type:	<input checked="" type="checkbox"/> Electric submersible	<input type="checkbox"/> Jet	<input type="checkbox"/> Air Lift	
	Other? Describe _____			
Test Pump Set at	<u>20</u> m below ground			
Water level sounded by:	<input checked="" type="checkbox"/> Electric tape	<input type="checkbox"/> Air bubbler	<input type="checkbox"/> Steel tape	
	Other? Describe _____			
Flow measured by:	<input checked="" type="checkbox"/> Container & watch	<input type="checkbox"/> Flow meter		
	<input type="checkbox"/> Orifice & tube	<input type="checkbox"/> Other? Describe _____		
TEST				
Constant rate of yield	<u>20</u> Lpm	Test duration	<u>2</u> hours	
Initial non-pumping level	<u>15.54</u> m			
Drawdown in well at end of test	<u>2.21</u> m			
Recommended pumping rate	<u>2</u> Lpm			
WATER SAMPLES TAKEN DURING TEST				
Chemical Analysis	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		
Bacterial Analysis	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		
Water Temperature	<u>9</u> °C			
Any particular gas smells noted	<u>None</u>			
Comments on clarity of water	<u>Clear and clean</u>			
Other	_____			



The Corporation of the Township of Langley

SCHEDULE "A"

PRIVATE WELL CERTIFICATION

PURSUANT TO SCHEDULE "A" of the Subdivision and Development Control Bylaw, I hereby certify that each lot to be created and/or each existing lot forming part of the proposed development can be serviced with potable water in accordance with the requirements of the Bylaw for the development of:

LEGAL DESCRIPTION: Lot 3 (Phase 1)

PROJECT NO.: 87-111

I certify that a quantity of not less than 2,500 litres per day has been proven for each existing or proposed lot in the development.

I certify that water quality tests have been conducted and that the "B.C. Drinking Water Standards, 1982" can be met for each existing or proposed lot in the development.

W.L. Brown
Certified By (Name of Professional Engineer)

1909 Brewster Ave
Address

North Vancouver BC V7M 3C7

PROFESSIONAL
SEAL

See attachments as required pursuant to clause 2.2.18 of Schedule "A".

Subdivision Application No. 87-111
Lot B of Lots 2 and 3, Plan 13274 and Parcel A
(Reference Plan 8562) of Lots 2, 3 and 4, Except
Plan 17067, Plan 23779 and part of Lot 31, Plan
54464, all of North East 1/4 of Section 9, Township 11, N.W.D.

GOODBRAND DEVELOPMENT CORPORATION
62ND AVE., LANGLEY, BRITISH COLUMBIA


Well on Lot 3 (S.E. Corner) (Phase 1)

Depth (Below Ground Surface)		Description
Metres	Feet	
0.00 - 0.61	0 - 2	Soil sandy loam
0.61 - 3.66	2 - 12	Sand and gravel, brown
3.66 - 5.49	12 - 18	Sand and gravel, silty, grey little water
5.49 - 11.89	18 - 39	Sand, silty, brown
11.89 - 14.63	39 - 48	Clay, some pebbles, grey
14.63 - 17.98	48 - 59	Sand, silty, some pebbles
17.98 - 20.42	59 - 67	Sand, brown, "dry"
20.42 - 38.40	67 - 126	Till, clayey, some water
38.40 - 40.23	126 - 132	Sand, fine grained, silty, grey
40.23 - 43.59	132 - 143	Clay, grey
43.59 - 45.42	143 - 149	Sand and gravel, <u>water-bearing</u>

Construction details - below ground surface

	Metres	Feet
152 mm (6-inch) diameter casing	+ 0.46 - 44.35	+ 1.5 - 145.5
152 mm (6-inch) telescopic diameter screen	43.99 - 45.42	144.33 - 149

Screen - stainless steel, 30 slot with K-packer
Top 3 m (10 feet) sealed with thick bentonite slurry outside of casing



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 3 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 05 25

LOCATION: 238A Street & 62 Ave.


SHEET 1 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start (Min)	Depth To Water (M)	Draw Down (M)	Flow Measurement Data			Comments
				(Min)	L	LPM	
1	0	19.53	0				Static water level below MPT.
2	.5	20.45	0.92	0.5	20	40	S.W.L. Lot 4 20.52 m
3	1.0	.94	1.41				Measuring point - top of casing 0.46 m above ground
4	1.5	21.43	.90				
5	2.0	.56	2.03				Discharge 30 m away from Well No. 3
6	2.5	.72	.19				
7	3.0	.79	.26				
8	3.5	.85	.32				
9	4.0	.88	.35				
10	4.5	.89	.36				Water clean, clear good taste
11	5.0	.91	.38				
12	6.0	.92	.39				
13	7.0	.92	.39				
14	8.0	.93	.40				
15	9.0	.93	.40				
16	10	.93	.40				
17	12	.95	.41				
18	14	.95	.41				
19	16	.95	.41				
20	18	.94	.41				
21	20	.94	.41				
22	25	.96	.43				Water level Lot 4 20.56 m
23	30	.96	.43				
24	35	.96	.43				
25	40	.96	.43				
26	45	.95	.42				



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 3 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 05 25

LOCATION: 238A Street & 62 Ave.


SHEET 3 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
1	0	21.96	2.43				Pump off
2	.5	20.83	1.30				
3	1.0	.37	0.84				
4	1.5	.19	.66				
5	2.0	19.99	.46				
6	2.5	.83	.30				
7	3.0	.83	.30				
8	3.5	.69	.16				
9	4.0	.66	.13				
10	4.5	.58	.05				
11	5.0	.65	.12				
12	6.0	.56	.03				
13	7.0	.53	.00				
14	8.0	.54	.01				
15	9.0	.53	.00				
16	10	.51	-.02				
17	12	.52	-.01				
18	14	.53	.00				
19	16	.53	.00				
20	18	.53	.00				
21	20	.53	0.00				
22	25	.52	-.01				
23	30	.54	.01				
24	35	.53	.00				
25	40	.53	.00				
26	45	.52	-.01				



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 3 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 05 25

LOCATION: 238A Street & 62 Ave.


SHEET 4 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
27	50	19.50	-.03				
28	60	.49	-.04				
29	70	.50	-.03				Water Level Lot 4 20.44 m
30	80	.49	-.04				
31	90	.50	-.03				
32	100	.51	-.02				
33	110	.50	-.03				
34	120	.50	-.03				





The Corporation of the Township of Langley

SCHEDULE "A"

TIME - DRAWDOWN GRAPH FOR PUMP TEST

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 3 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 05 25
 LOCATION: 238A Street & 62nd Ave. SHEET 5 OF 6
 DEPTH TO STATIC WATER LEVEL: 19.07 (m) TEST NO. 1

Below existing ground



Pumping rate 10 Lpm Drawdown at 30 days (S_{30}) $2,44 \times 10/40 = 0.61$ (m)

Estimated minimum adjustment for seasonal decline (D): Use following figures if other local data or hydrogeologist's opinion is not available.


- Tests run in summer time: 2 m
- Tests run in winter time: 6 m
- Tests run in fall and spring: use intermediate values 2 m to 6 m

Depth to proposed pump suction (D_p) 30 m

Calculate minimum available drawdown: $D_p - (D_{TW} + S_{30} + D) =$

$$30 - (19.07 + 0.61 + 4) = 6.32$$

If answer to above calculation is negative, then either the pump has to be set lower or the well is not capable of supplying water for a house.



The Corporation of the Township of Langley

SCHEDULE "A"

PUMP TEST SUMMARY

OWNER'S NAME: Goodbrand Development WELL NO. 3 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 05 25
 LOCATION: 238A Street & 62nd Ave. SHEET 6 OF 6
Township of Langley TEST NO. 1

WELL COMPLETION DATA

Depth 45.42 (m)
 Diameter 152 (mm)
 Static Water Level 19.07

SCREEN DESIGN (mark one)

Open Hole Slotted Casing
 Screen Gravel Pack
 Other _____

DESCRIPTION OF AQUIFER
Sand & Gravel

Screen interval 43.98 to 45.42

PUMP TEST

Start: Date 25 05 1988 Time 0810
d/mo/yr hr/min

Pump Type: Electric submersible Jet Air Lift
 Other? Describe _____

Test Pump Set at 40 m below ground

Water level sounded by: Electric tape Air bubbler Steel tape
 Other? Describe _____

Flow measured by: Container & watch Flow meter
 Orifice & tube Other? Describe _____

TEST

Constant rate of yield 40 Lpm Test duration 2 hours
 Initial non-pumping level 19.07 m
 Drawdown in well at end of test 2.43 m
 Recommended pumping rate 10 Lpm

WATER SAMPLES TAKEN DURING TEST

Chemical Analysis Yes No
 Bacterial Analysis Yes No

Water Temperature 9 oc

Any particular gas smells noted None

Comments on clarity of water Clear and Clean

Other _____



The Corporation of the Township of Langley

SCHEDULE "A"

PRIVATE WELL CERTIFICATION

PURSUANT TO SCHEDULE "A" of the Subdivision and Development Control Bylaw, I hereby certify that each lot to be created and/or each existing lot forming part of the proposed development can be serviced with potable water in accordance with the requirements of the Bylaw for the development of:

LEGAL DESCRIPTION: Lot 4 (Phase 1)

PROJECT NO.: 87-111

I certify that a quantity of not less than 2,500 litres per day has been proven for each existing or proposed lot in the development.

I certify that water quality tests have been conducted and that the "B.C. Drinking Water Standards, 1982" can be met for each existing or proposed lot in the development.

W.L. Brown
Certified By (Name of Professional Engineer)

1909 Brewster Ave
Address

PROFESSIONAL
SEAL

North Vancouver, BC V7M 3C7

See attachments as required pursuant to clause 2.2.18 of Schedule "A".

Subdivision Application No. 87-111
Lot B of Lots 2 and 3, Plan 13274 and Parcel A
(Reference Plan 8562) of Lots 2, 3 and 4, Except
Plan 17067, Plan 23779 and part of Lot 31, Plan
54464, all of North East 1/4 of Section 9, Township 11, N.W.D.

GOODBRAND DEVELOPMENT CORPORATION
62ND AVE., LANGLEY, BRITISH COLUMBIA


Well on Lot 4 (S.E. Corner) (Phase 1)

Depth (Below Ground Surface)		Description
Metres	Feet	
0.00 - 0.61	0 - 2	Soil sandy loam
0.61 - 6.40	2 - 21	Sand and gravel, silty
6.40 - 9.14	21 - 30	Sand and gravel, clean, loose
9.14 - 10.36	30 - 34	Sandy, silty, brown
10.36 - 11.28	34 - 37	Sand and gravel
11.28 - 11.89	37 - 39	Sand, little water
11.89 - 13.11	39 - 43	Interbedded sand, gravel, clay
13.11 - 16.76	43 - 55	Sand, silty, little water
16.76 - 17.68	55 - 58	Clay, sandy
17.68 - 19.81	58 - 65	Interbedded, sand, gravel, clay
19.81 - 20.73	65 - 68	Clay, pebbly
20.73 - 33.53	68 - 110	Clay, grey (drilled open hole)
33.53 - 35.36	110 - 116	Sand and gravel, silty, "dry"
35.36 - 36.58	116 - 120	Sand and gravel, <u>water-bearing</u>

Construction details - below ground surface

	Metres	Feet
152 mm (6-inch) diameter casing	+ 0.46 - 21.03	+ 1.5 - 69
152 mm (6-inch) telescopic diameter screen	35.15 - 36.58	115.33 - 120

Screen - stainless steel, 25 slot with K-packer
Top 3 m (10 feet) sealed with thick bentonite slurry outside of casing



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 4 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 05 25

LOCATION: 238A Street & 62 Ave.


SHEET 1 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
1	0	20.56	0				Static water level below MPT
2	.5	21.26	0.70	0.5	20	40	Measuring point - top of casing 0.46 m above ground
3	1.0	.92	1.36				
4	1.5	22.34	.78				
5	2.0	.60	2.04				Discharge 35 m away from Well No. 4
6	2.5	.75	.19				
7	3.0	.85	.29				
8	3.5	.98	.32				
9	4.0	.99	.43				
10	4.5	23.06	.50				
11	5.0	.07	.51				
12	6.0	.07	.51				
13	7.0	.10	.54				
14	8.0	.07	.51				
15	9.0	.06	.50				
16	10	.07	.51				
17	12	.09	.53				
18	14	.07	.51				
19	16	.07	.51				
20	18	.05	.49				
21	20	.05	.49				
22	25	.07	.51				
23	30	.06	.50				
24	35	.07	.51				
25	40	.08	.52				Water clear and clean
26	45	.08	.52				



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 4 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 05 25

LOCATION: 238A Street & 62 Ave.

SHEET 2 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
	(Min)	(M)	(M)	(Min)	L	LPM	
27	50	23.07	2.51				
28	60	.08	.52				
29	70	.09	.53				
30	80	.08	.52				
31	90	.08	.52				
32	100	.09	.53	0.5	20	40	
33	110	.09	.53				Water samples collected
34	120	.09	.53				



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 4 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 05 25

LOCATION: 238A Street & 62 Ave.


SHEET 3 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
1	0	23.09	2.53				Pump off
2	.5	22.11	1.55				
3	1.0	21.56	1.00				
4	1.5	.06	0.50				
5	2.0	20.86	.30				
6	2.5	-	-				
7	3.0	.75	.19				
8	3.5	.70	.14				
9	4.0	.67	.11				
10	4.5	.62	.06				
11	5.0	.61	.05				
12	6.0	.60	.04				
13	7.0	.57	.01				
14	8.0	.60	.04				
15	9.0	.59	.03				
16	10	.60	.04				
17	12	.57	.01				
18	14	.59	.03				
19	16	.59	.03				
20	18	.58	.03				
21	20	.58	.02				
22	25	.58	.02				
23	30	.57	.01				
24	35	.57	.01				
25	40	.56	.00				
26	45	.57	.01				



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 4 (Phase 1)


APPLICATION NO. 87-111 DATE: 1988 05 25

LOCATION: 238A Street & 62 Ave. SHEET 4 of 6

Township of Langley TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down (M)	Flow Measurement Data			Comments
	(Min)	(M)		(Min)	L	LPM	
27	50	20.57	0.01				
28	60	.56	.00				
29	70	.57	.01				
30	80	.56	.00				
31	90	.56	.00				
32	100	.57	.01				
33	110	.58	.02				
34	120	.58	.02				





The Corporation of the Township of Langley

SCHEDULE "A"

TIME - DRAWDOWN GRAPH FOR PUMP TEST

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 4 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 05 25
 LOCATION: 238A Street & 62nd Ave. SHEET 5 OF 6
 DEPTH TO STATIC WATER LEVEL: 20.10 (m) TEST NO. 1
 Below existing ground



Pumping rate 10 Lpm Drawdown at 30 days (S_{30}) $\frac{2.58 \times 10}{40} = 0.65$ (m)


Estimated minimum adjustment for seasonal decline (D): Use following figures if other local data or hydrogeologist's opinion is not available.

Tests run in summer time: 2 m
 Tests run in winter time: 6 m
 Tests run in fall and spring: use intermediate values 2 m to 6 m
 30

Depth to proposed pump suction (D_p) _____ m

Calculate minimum available drawdown: $O_p - (O_{TW} + S_{30} + D) =$
 $30 - (20.10 + 0.65 + 4) = 5.25$

If answer to above calculation is negative, then either the pump has to be set lower or the well is not capable of supplying water for a house.



The Corporation of the Township of Langley

SCHEDULE "A"

PUMP TEST SUMMARY

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 4 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 05 25
 LOCATION: 238A Street & 62 Ave. SHEET 6 OF 6
Township of Langley TEST NO. 1

WELL COMPLETION DATA		SCREEN DESIGN (mark one)		DESCRIPTION OF AQUIFER
Depth	<u>36.58</u> (m)	<input type="checkbox"/> Open Hole	<input type="checkbox"/> Slotted Casing	<u>Sand & Gravel</u>
Diameter	<u>152</u> (mm)	<input checked="" type="checkbox"/> Screen	<input type="checkbox"/> Gravel Pack	
Static Water Level	<u>20.10</u> (m)	<input type="checkbox"/> Other _____	Screen interval <u>35.15</u> m to <u>36.58</u> m	
PUMP TEST		Start: Date <u>25 05 1988</u> time <u>1330</u>		
Pump Type:		<input checked="" type="checkbox"/> Electric submersible <input type="checkbox"/> Jet <input type="checkbox"/> Air Lift		
Test Pump Set at _____ m below ground		Other? Describe _____		
Water level sounded by:		<input type="checkbox"/> Electric tape <input type="checkbox"/> Air bubbler <input type="checkbox"/> Steel tape		
Flow measured by:		<input checked="" type="checkbox"/> Container & watch <input type="checkbox"/> Flow meter		
		<input type="checkbox"/> Orifice & tube <input type="checkbox"/> Other? Describe _____		
TEST		Constant rate of yield <u>40</u> Lpm		Test duration <u>2</u> hours
		Initial non-pumping level <u>20.10</u> m		
		Drawdown in well at end of test <u>2.53</u> m		
		Recommended pumping rate <u>10</u> Lpm		
WATER SAMPLES TAKEN DURING TEST				
Chemical Analysis	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		
Bacterial Analysis	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		
Water Temperature	<u>9</u>	oc		
Any particular gas smells noted	<u>None</u>			
Comments on clarity of water	<u>Clear and Clean</u>			
Other	_____			



The Corporation of the Township of Langley

SCHEDULE "A"

PRIVATE WELL CERTIFICATION

PURSUANT TO SCHEDULE "A" of the Subdivision and Development Control Bylaw, I hereby certify that each lot to be created and/or each existing lot forming part of the proposed development can be serviced with potable water in accordance with the requirements of the Bylaw for the development of:

LEGAL DESCRIPTION: Lot 5 (Phase 1)

PROJECT NO.: 87-111

I certify that a quantity of not less than 2,500 litres per day has been proven for each existing or proposed lot in the development.

I certify that water quality tests have been conducted and that the "B.C. Drinking Water Standards, 1982" can be met for each existing or proposed lot in the development.

W.L. Brown
Certified By (Name of Professional Engineer)

1409 Brewster Ave
Address

North Vancouver, BC V7M 3C7

PROFESSIONAL
SEAL

See attachments as required pursuant to clause 2.2.18 of Schedule "A".

Subdivision Application No. 87-111
Lot B of Lots 2 and 3, Plan 13274 and Parcel A
(Reference Plan 8562) of Lots 2, 3 and 4, Except
Plan 17067, Plan 23779 and part of Lot 31, Plan
54464, all of North East 1/4 of Section 9, Township 11, N.W.D.

WTN 108024

GOODBRAND DEVELOPMENT CORPORATION
62ND AVE., LANGLEY, BRITISH COLUMBIA

Well on Lot 5 (S.E. Corner) (Phase 1)


Depth (Below Ground Surface)		Description
Metres	Feet	
0.00 - 0.30	0 - 1	Soil sandy loam
0.30 - 3.05	1 - 10	Sand and gravel, brown
3.05 - 5.18	10 - 17	Sand and gravel, silty
5.18 - 6.71	17 - 22	Sand and gravel, coarse
6.71 - 8.53	22 - 28	Sand and gravel, silty
8.53 - 11.89	28 - 39	Sand, brown
11.89 - 17.37	39 - 57	Clay, sandy
17.37 - 20.12	57 - 66	Sand, silty dry
20.12 - 21.64	66 - 71	Sand and gravel, <u>water bearing</u>
21.64 - 31.39	71 - 103	Till-like
31.39 - 34.14	103 - 112	Sand and gravel, <u>water bearing</u>

Construction details - below ground surface

	Metres	Feet
152 mm (6-inch) diameter casing	+ 0.46 - 33.07	+ 1.5 - 108.5
152 mm (6-inch) telescopic diameter screen	32.61 - 34.14	107 - 112

Screen - stainless steel, 15 slot with K-packer

Top 3 m (10 feet) sealed with thick bentonite slurry outside of casing



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 5 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 06 16

LOCATION: 238A Street & 62 Ave.


SHEET 1 of 6

Township of Langley

TEST NO. 2

Drawdown Recovery

Rdg #	Time From Start (Min)	Depth To Water (M)	Draw Down (M)	Flow Measurement Data			Comments
				(Min)	L	LPM	
1	0	21.34	0				Static Water Level below MPT Measuring Point - top of Casing 0.46 m above ground
2	.5	22.37	1.03				
3	1.0	23.27	.93				
4	1.5	.91	2.57				Discharge 40 m away from well
5	2.0	24.38	3.04				
6	2.5	.82	.48				
7	3.0	25.12	.78				
8	3.5	.32	.98				
9	4.0	.58	4.24				
10	4.5	.72	.38				
11	5.0	.86	.52				
12	6	26.03	.69	.05	20	40	
13	7	.15	.81				
14	8	.23	.89				
15	9	.29	.95				
16	10	.31	.97				
17	12	.34	5.00				
18	14	.37	.03				
19	16	.38	.04				
20	18	.38	.04				
21	20	.39	.05				
22	25	.39	.05				
23	30	.40	.06				
24	35	.38	.04				
25	40	.40	.06				
26	45	26.40	5.06				



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 5 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 06 16

LOCATION: 238A Street & 62 Ave.

SHEET 2 of 6

Township of Langley

TEST NO. 2

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data		Comments
				(Min)	L LPM	
27	50	.41	.07			
28	60	.43	.09			
29	70	.44	.10			
30	80	.42	.08			
31	90	.42	.08			
32	100	.43	.09			
33	110	.40	.06			Water Samples collected
34	120	.42	.08			



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 5 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 06 16

LOCATION: 238A Street & 62 Ave.

SHEET 3 of 6

Township of Langley

TEST NO. 2

Drawdown Recovery

Rdg #	Time From Start (Min)	Depth To Water (M)	Draw Down (M)	Flow Measurement Data			Comments
				(Min)	L	LPM	
1	0	26.42	5.08				Pump off
2	.5						
3	1.0						
4	1.5	23.85	2.51				
5	2.0	.31	1.97				
6	2.5	22.86	.52				
7	3.0	.53	.19				
8	3.5	.24	0.09				
9	4.0						
10	4.5						
11	5.0						
12	6.0						
13	7.0	21.52	0.18				
14	8.0	.45	.11				
15	9.0	.38	.04				
16	10	.34	0.00				
17	12						
18	14						
19	16						
20	18						
21	20	.34	.00				
22	25						
23	30						
21	35						
25	40	.34	.00				
26	45	21.34	0.00				



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 5 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 06 16

LOCATION: 238A Street & 62 Ave.


SHEET 4 of 6

Township of Langley

TEST NO. 2



Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
	(Min)	(M)		(Min)	L	LPM	
27	50						
28	60						
29	70						
30	80						
31	90	.34	.00				
32	100						
33	110						
34	120	.34	.00				



TIME - DRAWDOWN GRAPH FOR PUMP TEST

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 5 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 06 17
 LOCATION: 238A Street & 62nd Ave. SHEET 5 OF 6
 DEPTH TO STATIC WATER LEVEL: 20.88 (m) TEST NO. 2
 Below existing ground



Pumping rate 10 Lpm Drawdown at 30 days (S_{30}) $\frac{5.4 \times 10/40}{(m)} = 1.4$


Estimated minimum adjustment for seasonal decline (D): Use following figures if other local data or hydrogeologist's opinion is not available.

- Tests run in summer time: 2 m
- Tests run in winter time: 6 m
- Tests run in fall and spring: use intermediate values 2 m to 6 m

Depth to proposed pump suction (D_p) 30 m

Calculate minimum available drawdown: $D_p - (DTW + S_{30} + D) =$
 $30 - (20.88 + 1.4 + 4) = 3.72$

If answer to above calculation is negative, then either the pump has to be set lower or the well is not capable of supplying water for a house.



The Corporation of the Township of Langley

SCHEDULE "A"

PUMP TEST SUMMARY

OWNER'S NAME: Goodbrand Development WELL NO. 5 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 06 17
 LOCATION: 238A Street & 62nd Ave. SHEET 6 OF 6
Township of Langley TEST NO. 2

WELL COMPLETION DATA		SCREEN DESIGN (mark one)	DESCRIPTION OF AQUIFER
Depth <u>34.14</u> (m)	<input type="checkbox"/> Open Hole	<input type="checkbox"/> Slotted Casing	<u>Sand & Gravel</u>
Diameter <u>152</u> (mm)	<input checked="" type="checkbox"/> Screen	<input type="checkbox"/> Gravel Pack	
Static Water Level <u>20.88</u> (m)	<input type="checkbox"/> Other _____		
	Screen interval <u>32.61</u> m to <u>34.14</u> m		
PUMP TEST			
Start: Date <u>17 06 1988</u>	Time <u>0710</u>		
	<small>d/m/y</small>	<small>hr/min</small>	
Pump Type: <input checked="" type="checkbox"/> Electric submersible	<input type="checkbox"/> Jet	<input type="checkbox"/> Air Lift	
Other? Describe _____			
Test Pump Set at <u>30</u> m below ground			
Water level sounded by: <input checked="" type="checkbox"/> Electric tape	<input type="checkbox"/> Air bubbler	<input type="checkbox"/> Steel tape	
Other? Describe _____			
Flow measured by: <input checked="" type="checkbox"/> Container & watch	<input type="checkbox"/> Flow meter		
<input type="checkbox"/> Orifice & tube	<input type="checkbox"/> Other? Describe _____		
TEST			
Constant rate of yield <u>40</u> Lpm	Test duration <u>2</u> hours		
Initial non-pumping level <u>20.88</u> m			
Drawdown in well at end of test <u>5.08</u> m			
Recommended pumping rate <u>10</u> Lpm			
WATER SAMPLES TAKEN DURING TEST			
Chemical Analysis <input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		
Bacterial Analysis <input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		
Water Temperature <u>9</u> °C			
Any particular gas smells noted <u>None</u>			
Comments on clarity of water <u>Clear and Clean</u>			
Other _____			



The Corporation of the Township of Langley

SCHEDULE "A"

PRIVATE WELL CERTIFICATION

PURSUANT TO SCHEDULE "A" of the Subdivision and Development Control Bylaw, I hereby certify that each lot to be created and/or each existing lot forming part of the proposed development can be serviced with potable water in accordance with the requirements of the Bylaw for the development of:

LEGAL DESCRIPTION: Lot 6 (Phase 1)

PROJECT NO.: 87-111

I certify that a quantity of not less than 2,500 litres per day has been proven for each existing or proposed lot in the development.

I certify that water quality tests have been conducted and that the "B.C. Drinking Water Standards, 1982" can be met for each existing or proposed lot in the development.

Prof. Brown
Certified By (Name of Professional Engineer)

1409 Brewster Ave
Address

North Vancouver, B.C.

PROFESSIONAL
SEAL

See attachments as required pursuant to clause 2.2.18 of Schedule "A".

Subdivision Application No. 87-111
Lot B of Lots 2 and 3, Plan 13274 and Parcel A
(Reference Plan 8562) of Lots 2, 3 and 4, Except
Plan 17067, Plan 23779 and part of Lot 31, Plan
54464, all of North East 1/4 of Section 9, Township 11, N.W.D.

WTN 108025

GOODBRAND DEVELOPMENT CORPORATION
62ND AVE., LANGLEY, BRITISH COLUMBIA


Well on Lot 6 (S.E. Curve) (Phase 1)

Depth (Below Ground Surface)		Description
Metres	Feet	
0.00 - 0.30	0 - 1	Soil sandy loam
0.30 - 3.66	1 - 12	Sand and gravel, silty, brown
3.66 - 4.88	12 - 16	Sand and gravel, grey
4.88 - 7.32	16 - 24	Sand and gravel, brown
7.32 - 8.23	24 - 27	Sand, brown
8.23 - 10.06	27 - 33	Gravel
10.06 - 16.15	33 - 53	Interbedded sand and clay
16.15 - 21.03	53 - 69	Sand and gravel, silty, hard packed
21.03 - 24.08	69 - 79	Sand and gravel, <u>water-bearing</u>

Construction details - below ground surface

	Metres	Feet
152 mm (6-inch) diameter casing	+ 0.46 - 23.01	+ 1.5 - 75.5
152 mm (6-inch) telescopic diameter screen	22.66 - 24.08	74.3 - 79.0

Screen - stainless steel, 18 slot with K-packer
Thick Bentonite Slurry seal around top 3m (10 feet) of casing



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 6 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 05 27

LOCATION: 238A Street & 62 Ave.


SHEET 1 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
1	0	18.43	0				Static Water Level below MPt. Measuring Point - top of casing 0.46 above ground
2	.5	19.30	0.87				
3	1.0	.72	1.29				
4	1.5	.91	.48				Water level Lot 10 18.62 m
5	2.0	20.00	.57				Discharge 35 m away from Well
6	2.5	.06	.63				
7	3.0	.08	.65				
8	3.5	.10	.67				
9	4.0	.11	.68				
10	4.5	.13	.70				
11	5.0	.14	.71				
12	6.0	.13	.70				
13	7.0	.13	.70				
14	8.0	.14	.71				
15	9.0	.15	.72				
16	10	.15	.72	0.5	20	40	
17	12	.14	.71				
18	14	.14	.71				
19	15	.16	.73				
20	18	.14	.71				
21	20	.14	.71				
22	25	.14	.71				
23	30	.14	.71				Water Level Lot 10 - 18.62 m
24	35	.15	.72				
25	40	.14	.71				
26	45	.15	.72				



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 6 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 05 26

LOCATION: 238A Street & 62 Ave.


SHEET 2 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
27	50	20.15	1.72				
28	60	.15	.72				Water Level Lot 10 - 18.64 m
29	70	.18	.75				
30	80	.18	.75				Water Level Lot 10 - 18.64 m
31	90	.19	.76				
32	100	.19	.76				Water Level Lot 10 18.64 m
33	110	.19	.76				Water Samples Collected
34	120	.19	.76				Water Level Lot 10 - 18.64



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 6 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 05 27

LOCATION: 238A Street & 62 Ave.


SHEET 3 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
1	0	20.19	1.76				Pump off
2	.5	19.31	0.88				
3	1.0	18.90	.47				
4	1.5	.69	.26				
5	2.0	.59	.16				
6	2.5	.53	.10				
7	3.0	.50	.07				
8	3.5	.50	.07				
9	4.0	.49	.06				
10	4.5	.48	.05				
11	5.0	.48	.05				
12	6.0	.47	.04				
13	7.0	.47	.04				
14	8.0	.47	.04				
15	9.0	.47	.04				
16	10	.47	.04				
17	12	.47	.04				
18	14	.47	.04				
19	16	.47	.04				
20	18	.47	.04				
21	20	.47	.04				
22	25	.47	.04				
23	30	.46	.03				
24	35	.46	.03				
25	40	.46	.03				
26	45	.46	.03				



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 6 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 05 27

LOCATION: 238A Street & 62 Ave.

SHEET 4 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
27	50	18.46	0.03				
28	60	.45	.02				
29	70	.45	.02				
30	80	.44	.01				
31	90	.44	.01				
32	100	.43	.00				
33	110	.43	.00				
34	120	.43	.00				



The Corporation of the Township of Langley

SCHEDULE "A"

PUMP TEST SUMMARY

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 6 (Phase 1)
APPLICATION NO.: 87-111 DATE: 1988 05 27
LOCATION: 238A Street & 62 Ave. SHEET 6 OF 6
Township of Langley TEST NO. 1

WELL COMPLETION DATA		SCREEN DESIGN (mark one)	DESCRIPTION OF AQUIFER
Depth <u>24.08</u> (m)	<input type="checkbox"/> Open Hole	<input type="checkbox"/> Slotted Casing	<u>Sand & Gravel</u>
Diameter <u>152</u> (mm)	<input checked="" type="checkbox"/> Screen	<input type="checkbox"/> Gravel Pack	
Static Water Level <u>17.79</u> (m)	<input type="checkbox"/> Other _____		
	Screen interval <u>22.66</u> m to <u>24.08</u> m		
PUMP TEST			
Start: Date <u>27 05 1988</u> Time <u>0830</u>			
	<small>d/mo/yr</small> <small>hr/min</small>		
Pump Type: <input checked="" type="checkbox"/> Electric submersible	<input type="checkbox"/> Jet	<input type="checkbox"/> Air Lift	
	Other? Describe _____		
Test Pump Set at <u>22</u> m below ground			
Water level sounded by: <input checked="" type="checkbox"/> Electric tape	<input type="checkbox"/> Air bubbler	<input type="checkbox"/> Steel tape	
	<input type="checkbox"/> Other? Describe _____		
Flow measured by: <input checked="" type="checkbox"/> Container & watch	<input type="checkbox"/> Flow meter		
	<input type="checkbox"/> Orifice & tube <input type="checkbox"/> Other? Describe _____		
TEST			
Constant rate of yield <u>40</u> Lpm	Test duration <u>2</u> hours		
Initial non-pumping level <u>17.79</u> m			
Drawdown in well at end of test <u>1.76</u> m			
Recommended pumping rate <u>5</u> Lpm			
WATER SAMPLES TAKEN DURING TEST			
Chemical Analysis <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Bacterial Analysis <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Water Temperature <u>9</u> °C			
Any particular gas smells noted <u>None</u>			
Comments on clarity of water <u>Clear and Clean</u>			
Other _____			



The Corporation of the Township of Langley

SCHEDULE "A"

PRIVATE WELL CERTIFICATION

PURSUANT TO SCHEDULE "A" of the Subdivision and Development Control Bylaw, I hereby certify that each lot to be created and/or each existing lot forming part of the proposed development can be serviced with potable water in accordance with the requirements of the Bylaw for the development of:

LEGAL DESCRIPTION: Lot 7 (Phase 1)

PROJECT NO.: 87-111

I certify that a quantity of not less than 2,500 litres per day has been proven for each existing or proposed lot in the development.

I certify that water quality tests have been conducted and that the "B.C. Drinking Water Standards, 1982" can be met for each existing or proposed lot in the development.

Prof. Brown
Certified By (Name of Professional Engineer)

1409 Brewster Ave
Address

PROFESSIONAL
SEAL

North Vancouver, B.C. V7M 3C7

See attachments as required pursuant to clause 2.2.18 of Schedule "A".

Subdivision Application No. 87-111
Lot B of Lots 2 and 3, Plan 13274 and Parcel A
(Reference Plan 8562) of Lots 2, 3 and 4, Except
Plan 17067, Plan 23779 and part of Lot 31, Plan
54464, all of North East 1/4 of Section 9, Township 11, N.W.D.

WTN 108026

GOODBRAND DEVELOPMENT CORPORATION
62ND AVE., LANGLEY, BRITISH COLUMBIA


Well on Lot 7 (South Central Area) (Phase 1)

Depth (Below Ground Surface)		Description
Metres	Feet	
0.00 - 0.31	0 - 1	Soil sandy loam
0.31 - 2.13	1 - 7	Sand and gravel, silty
2.13 - 12.80	7 - 42	Sand, silt, minor pebble
12.80 - 17.37	42 - 57	Sand, brown, dry
17.37 - 18.59	57 - 61	Gravel, coarse
18.59 - 19.81	61 - 65	Sand, brown, <u>water-bearing</u> low static water level
19.81 - 22.86	65 - 75	Sand and gravel, <u>water-bearing</u> low static water level
22.86 - 32.00	75 - 105	Clay, sandy some pebble, grey
32.00 - 33.53	105 - 110	Sand and clay, interbedded
33.53 - 35.36	110 - 116	Sand, silty, fine grained
35.36 - 35.66	116 - 117	Clay, grey
35.66 - 36.88	117 - 121	Sand and gravel, <u>water-bearing</u>

Construction details - below ground surface

	Metres	Feet
152 mm (6-inch) diameter casing	+ 0.46 - 35.66	+ 1.5 - 117
152 mm (6-inch) telescopic diameter screen	35.46 - 36.88	116.3 - 121

Screen - stainless steel, 20 slot with K-packer
Top 3 m (10 feet) sealed with thick bentonite slurry outside of casing.



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 7 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 06 07

LOCATION: 238A Street & 62 Ave.


SHEET 1 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
1	0	16.07	0				Static Water Level below M Pt.
2	.5	17.11	1.04				Measuring Point - Top of casing 0.46 m above ground
3	1.0	.91	1.84				
4	1.5	18.44	2.37				
5	2.0	.80	.73				
6	2.5	19.07	3.00				
7	3.0	.25	.18				
8	3.5	.42	.35				
9	4.0	.53	.46				
10	4.5	.61	.54				
11	5.0	.67	.60				
12	6.0	.72	.65				
13	7.0	.74	.67				
14	8.0	.76	.69				
15	9.0	.77	.70				
16	10	.78	.71				
17	12	.79	.72				
18	14	.80	.73				
19	16	.81	.74				
20	18	.81	.74				
21	20	.81	.74				
22	25	.81	.74				
23	30	.81	.74				
24	35	.81	.74				
25	40	.81	.74				
26	45	.81	.74				



The Corporation of the Township of Langley


SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 7 (Phase 1)
 APPLICATION NO. 87-111 DATE: 1988 06 07
 LOCATION: 238A Street & 62 Ave. SHEET 2 of 6
Township of Langley TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down (M)	Flow Measurement Data			Comments
	(Min)	(M)		(Min)	L	LPM	
27	50	19.78	3.71	0.5	20	40	Check Flow
28	60	.80	.73	0.5	20	40	
29	70	.81	.74	0.5	20	40	
30	80	.80	.73	0.5	20	40	
31	90	.83	.76	0.5	20	40	
32	100	.82	.75				
33	110	.81	.74				Water clear and clean
34	120	.81	.74				Water Samples Collected
							Pump off



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 7 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 06 07

LOCATION: 238A Street & 62 Ave.

SHEET 3 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
	(Min)	(M)	(M)	(Min)	L	LPM	
1	0	19.81	3.74				Pump off
2	.5	18.90	2.83				
3	1.0	.14	.07				
4	1.5	17.56	1.49				
5	2.0	.13	.06				
6	2.5	16.85	0.78				
7	3.0	.68	.61				
8	3.5	.51	.44				
9	4.0	.39	.32				
10	4.5	.32	.25				
11	5.0	.26	.19				
12	6.0	.19	.12				
13	7.0	.15	.08				
14	8.0	.13	.06				
15	9.0	.11	.04				
16	10	.11	.04				
17	12	.09	.02				
18	14	.09	.02				
19	16	.09	.02				
20	18	.09	.02				
21	20	.08	.01				
22	25	.08	.01				
23	30	.08	.01				
24	35	.08	.01				
25	40	.07	.00				
26	45	.08	.01				





The Corporation of the Township of Langley

SCHEDULE "A"

TIME - DRAWDOWN GRAPH FOR PUMP TEST

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 7 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 06 07
 LOCATION: 238A St. & 62nd Ave. SHEET 5 OF 6
 DEPTH TO STATIC WATER LEVEL: 15.61 (m) TEST NO. 1

Below existing ground



Pumping rate 10 Lpm Drawdown at 30 days (S_{30}) $\frac{3.83 \times 10/40}{(m)} = 0.96$


Estimated minimum adjustment for seasonal decline (D): Use following figures if other local data or hydrogeologist's opinion is not available.

- Tests run in summer time: 2 m
- Tests run in winter time: 6 m
- Tests run in fall and spring: use intermediate values 2 m to 6 m

Depth to proposed pump suction (D_p) 35 m

Calculate minimum available drawdown: $D_p - (D_{TW} + S_{30} + D) =$
 $35 - (15.61 + 0.96 + 4) = 14.43$

If answer to above calculation is negative, then either the pump has to be set lower or the well is not capable of supplying water for a house.



The Corporation of the Township of Langley

SCHEDULE "A"

PUMP TEST SUMMARY

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 7 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 06 07
 LOCATION: 238A St. & 62nd Ave. SHEET 6 OF 6
Township of Langley TEST NO. 1

WELL COMPLETION DATA		SCREEN DESIGN (mark one)	DESCRIPTION OF AQUIFER
Depth <u>36.88</u> (m)	<input type="checkbox"/> Open Hole	<input type="checkbox"/> Slotted Casing	<u>Sand and gravel</u>
Diameter <u>152</u> (mm)	<input checked="" type="checkbox"/> Screen	<input type="checkbox"/> Gravel Pack	
Static Water Level <u>15.6</u> (m)	<input type="checkbox"/> Other _____		
	Screen interval <u>38.46</u> m to <u>36.88</u> m		
PUMP TEST			
Start: Date <u>07 06 1988</u>	line <u>1400</u>		
	<u>d/m/yr</u>	<u>hr/min</u>	
Pump Type: <input checked="" type="checkbox"/> Electric submersible	<input type="checkbox"/> Jet	<input type="checkbox"/> Air Lift	
Other? Describe _____			
Test Pump Set at <u>35</u> m below ground			
Water level sounded by: <input checked="" type="checkbox"/> Electric tape	<input type="checkbox"/> Air bubbler	<input type="checkbox"/> Steel Tape	
<input type="checkbox"/> Other? Describe _____			
Flow measured by: <input checked="" type="checkbox"/> Container & watch	<input type="checkbox"/> Flow meter		
<input type="checkbox"/> Orifice & tube <input type="checkbox"/> Other? Describe _____			
TEST			
Constant rate of yield <u>40</u> Lpm	Test duration <u>2</u> hours		
Initial non-pumping level <u>15.61</u> m			
Drawdown in well at end of test <u>3.74</u> m			
Recommended pumping rate <u>10</u> Lpm			
WATER SAMPLES TAKEN DURING TEST			
Chemical Analysis <input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		
Bacterial Analysis <input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		
Water Temperature <u>9</u> °C			
Any particular gas smells noted <u>None</u>			
Comments on clarity of water <u>Clear and clean</u>			
Other _____			



The Corporation of the Township of Langley

SCHEDULE "A"

PRIVATE WELL CERTIFICATION

PURSUANT TO SCHEDULE "A" of the Subdivision and Development Control Bylaw, I hereby certify that each lot to be created and/or each existing lot forming part of the proposed development can be serviced with potable water in accordance with the requirements of the Bylaw for the development of:

LEGAL DESCRIPTION: Lot 8 (Phase 1)

PROJECT NO.: 87-111

I certify that a quantity of not less than 2,500 litres per day has been proven for each existing or proposed lot in the development.

I certify that water quality tests have been conducted and that the "B.C. Drinking Water Standards, 1982" can be met for each existing or proposed lot in the development.

M.L. Pearson
Certified By (Name of Professional Engineer)

1409 Beech Ave.
Address

North Vancouver, B.C. V7M 3C7

PROFESSIONAL
SEAL

See attachments as required pursuant to clause 2.2.18 of Schedule "A".

Subdivision Application No. 87-111
Lot B of Lots 2 and 3, Plan 13274 and Parcel A (Reference Plan 8562) of Lots 2, 3 and 4, Except Plan 17067, Plan 23779 and part of Lot 31, Plan 54464, all of North East 1/4 of Section 9, Township 11, N.W.D.


WTN 108028

GOODBRAND DEVELOPMENT CORPORATION
 62ND AVE., LANGLEY, BRITISH COLUMBIA
 Well on Lot 8 (N.E. Corner) (Phase 1)

Depth (Below Ground Surface) Metres	Feet	Description
0.00 - 0.31	0 - 1	Soil, sandy loam
0.31 - 1.52	1 - 5	Sand and gravel
1.52 - 6.71	5 - 22	Sand and gravel, silty brown
6.71 - 13.41	22 - 44	Sand and gravel with clay bed
13.41 - 17.07	44 - 56	Soil, Sand packed, open hole
17.07 - 24.08	56 - 79	Clay, sandy, stoney, grey tile-like
24.08 - 27.13	79 - 89	Sand and gravel water-bearing
27.13 - 29.57	89 - 97	Clay, grey
29.57 -	97 -	

Construction details - below ground surface

	Metres	Feet
152 mm (6 inch) diameter casing	+ 0.46 - 28.50	+ 1.5 - 93.5
152 mm (6 inch) telescopic screen	27.83 - 29.26	91.3 - 96.0 diameter
Screen - stainless steel, 20 slot with K-packer		
Top 3 m (10 feet) sealed with thick bentonite slurry outside of casing.		



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 8 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 06 07

LOCATION: 238A Street & 62 Ave.


SHEET 1 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
1	0	16.35	0				Static Water Level below M Pt. Measuring Point - Top of casing 0.46 m above ground
2	.5	17.22	0.87				
3	1.0	-					
4	1.5	17.60	1.25				
5	2.0	-					
6	2.5	17.86	1.51	0.5	20	40	
7	3.0	18.19	.84				
8	3.5	.20	.85				
9	4.0	.23	.88				
10	4.5	.23	.88				
11	5.0	.26	.91				
12	6.0	.29	.94				
13	7.0	.23	.88				
14	8.0	.31	.96				
15	9.0	.32	.97				
16	10	.32	.97				
17	12	.34	.99				
18	14	.40	2.05				
19	16	.43	.08				
20	18	.43	.08				
21	20	.43	.08				
22	25	.49	.14	0.5	20	40	Water clear and clean
23	30	.48	.13				
24	35	.51	.16				
25	40	.53	.18				
26	45	.54	.19				



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 8 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 05 27

LOCATION: 238A Street & 62 Ave.


SHEET 2 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
27	50	18.56	2.21				
28	60	.58	.23				
29	70	.60	.25				
30	80	.64	.29				
31	90	.65	.30				
32	100	.65	.30				
33	110	.65	.30				
34	120	.67	.32			Water Samples Collected	



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 8 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 05 27

LOCATION: 238A Street & 62 Ave.


SHEET 4 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery



Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
27	50	16.47	0.12				
28	60	.45	.10				
29	70	.42	.08				
30	80	.42	.07				
31	90	.42	.07				
32	100	.40	.05				
33	110	.39	.04				
34	120	.39	.04				



TIME - DRAWDOWN GRAPH FOR PUMP TEST

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 8 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 06 07
 LOCATION: 238A St. & 62 Ave. SHEET 5 OF 6
 DEPTH TO STATIC WATER LEVEL: 15.89 (m) TEST NO. 1

Below existing ground.



Pumping rate 10 Lpm Drawdown at 30 days (S_{30}) $3.23 \times 10/40 = 0.81$ (m)

Estimated minimum adjustment for seasonal decline (D): Use following figures if other local data or hydrogeologist's opinion is not available.

- Tests run in summer time: 2 m
- Tests run in winter time: 6 m
- Tests run in fall and spring: use intermediate values 2 m to 6 m

Depth to proposed pump suction (D_p) 27 m

Calculate minimum available drawdown: $D_p - (D_{TW} + S_{30} + D) =$
 $27 - (15.89 + 0.81 + 4) = 6.30$

If answer to above calculation is negative, then either the pump has to be set lower or the well is not capable of supplying water for a house.



The Corporation of the Township of Langley

SCHEDULE "A"

PUMP TEST SUMMARY

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 8 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 06 07
 LOCATION: 238A St. & 62 Ave. SHEET 6 OF 6
Township of Langley TEST NO. 1

WELL COMPLETION DATA		SCREEN DESIGN (mark one)		DESCRIPTION OF AQUIFER
Depth <u>29.57</u> (m)	<input type="checkbox"/> Open Hole	<input type="checkbox"/> Slotted Casing	<u>Sand & Gravel</u>	
Diameter <u>152</u> (mm)	<input checked="" type="checkbox"/> Screen	<input type="checkbox"/> Gravel Pack		
Static Water Level <u>15.89</u> (m)	<input type="checkbox"/> Other _____			
		Screen interval <u>27.83</u> to <u>29.26</u>		
PUMP TEST				
Start: Date <u>07 06 1988</u>	Time <u>0840</u>			
	<u>h/mo/yr</u>	<u>lit/min</u>		
Pump Type: <input checked="" type="checkbox"/> Electric submersible	<input type="checkbox"/> Jet	<input type="checkbox"/> Air Lift		
Other? Describe _____				
Test Pump Set at <u>27</u> m below ground				
Water level sounded by: <input type="checkbox"/> Electric tape	<input type="checkbox"/> Air bubbler	<input type="checkbox"/> Steel tape		
<input type="checkbox"/> Other? Describe _____				
Flow measured by: <input checked="" type="checkbox"/> Container & watch	<input type="checkbox"/> Flow meter			
<input type="checkbox"/> Orifice & tube <input type="checkbox"/> Other? Describe _____				
TEST				
Constant rate of yield <u>40</u> Lpm	Test duration <u>2</u> hours			
Initial non-pumping level <u>15.89</u> m				
Drawdown in well at end of test <u>2.32</u> m				
Recommended pumping rate <u>10</u> Lpm				
WATER SAMPLES TAKEN DURING TEST				
Chemical Analysis <input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No			
Bacterial Analysis <input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No			
Water Temperature <u>9</u> °C				
Any particular gas smells noted <u>None</u>				
Comments on clarity of water <u>Clear and Clean</u>				
Other _____				

GOODBRAND DEVELOPMENT CORPORATION
62ND AVE., LANGLEY, BRITISH COLUMBIA

Well on Lot 9 (Phase 1)

Depth (Below Ground Surface)		Description
Metres	Feet	

No Well was drilled on Lot 9.



The Corporation of the Township of Langley

SCHEDULE "A"

PRIVATE WELL CERTIFICATION

PURSUANT TO SCHEDULE "A" of the Subdivision and Development Control Bylaw, I hereby certify that each lot to be created and/or each existing lot forming part of the proposed development can be serviced with potable water in accordance with the requirements of the Bylaw for the development of:

LEGAL DESCRIPTION: Lot 10 (Phase 1)

PROJECT NO.: 87-111

I certify that a quantity of not less than 2,500 litres per day has been proven for each existing or proposed lot in the development.

I certify that water quality tests have been conducted and that the "B.C. Drinking Water Standards, 1982" can be met for each existing or proposed lot in the development.

B.L. Brown
Certified By (Name of Professional Engineer)

1404 Bowditch Ave
Address

North Vancouver, B.C. V7M 3C7

PROFESSIONAL
SEAL

See attachments as required pursuant to clause 2.2.18 of Schedule "A".

Subdivision Application No. 87-111
Lot B of Lots 2 and 3, Plan 13274 and Parcel A
(Reference Plan 8562) of Lots 2, 3 and 4, Except
Plan 17067, Plan 23779 and part of Lot 31, Plan
54464, all of North East 1/4 of Section 9, Township 1E, N.W.D.

WTN 108029

GOODBRAND DEVELOPMENT CORPORATION
62ND AVE., LANGLEY, BRITISH COLUMBIA


Well on Lot 10 (N.W. Corner) (Phase 1)

Depth (Below Ground Surface)		Description
Metres	Feet	
0.00 - 0.61	0 - 2	Soil sandy loam
0.61 - 3.66	2 - 12	Sand and gravel, silty
3.66 - 12.80	12 - 42	Sand, hard packed, brown
12.80 - 13.72	42 - 45	Clay, sandy
13.72 - 16.15	45 - 53	Sand and gravel
16.15 - 19.81	53 - 65	Sand, grey, dry
19.81 - 22.86	65 - 78	Sand, grey, <u>water bearing</u>
22.86 -	75	Clay, grey, sandy

Construction details - below ground surface

	Metres	Feet
152 mm (6-inch) diameter casing	+ 0.46 - 21.64	+ 1.5 - 71
152 mm (6-inch) telescopic diameter screen	21.43 - 22.86	70.3 - 75

Screen - stainless steel, 30 slot with K-packer
Top 3 m (10 feet) sealed with thick bentonite slurry outside of casing



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 10 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 05 27

LOCATION: 238A Street & 62 Ave.


SHEET 1 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
1	0	18.68	0				Static Water Level below Mpt.
2	.5	-	-				Measuring Point - top of casing 0.46 above ground
3	1.0	19.32	0.64	0.5	20	40	
4	1.5	.43	.75				
5	2.0	.43	.75				Discharge 40 m away from Well
6	2.5	.43	.75				
7	3.0	.44	.76				
8	3.0	.44	.76				
9	4.0	.44	.76				
10	4.5	.44	.76				
11	5.0	.44	.76				
12	6.0	-	-				
13	7.0	.45	.77				
14	8.0	-	-				
15	9.0	.44	.76				
16	10	.45	.77				
17	12	.46	.78				
18	14	.45	.77				
19	15	.46	.78				
20	18	.47	.79				
21	20	.47	.79				
22	25	.46	.78				
23	30	.47	.79				
24	35	.47	.79				
25	40	.49	.81				
26	45	.49	.81				



The Corporation of the Township of Langley


SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 10 (Phase 1)
 APPLICATION NO. 87-111 DATE: 1988 05 27
 LOCATION: 238A Street & 62 Ave. SHEET 2 of 6
Township of Langley TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
	(Min)	(M)	(M)	(Min)	L	LPM	
27	50	19.49	0.81				
28	60	.48	.80				
29	70	.48	.80				
30	80	.48	.80	0.5	20	40	
31	90	.49	.81				
32	100	.50	.82				Water clear and clean
33	110	.50	.82				Water Samples Collected
34	120	.50	.82				



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 10 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 05 27

LOCATION: 238A Street & 62 Ave.


SHEET 3 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
	(Min)	(M)	(M)	(Min)	L	LPM	
1	0	19.50	0.82				Pump off
2	.5	18.89	.21				
3	1.0	.77	.09				
4	1.5	.75	.07				
5	2.0	.74	.06				
6	2.5	.74	.06				
7	3.0	.74	.06				
8	3.5	.74	.06				
9	4.0	.74	.06				
10	4.5	.73	.05				
11	5.0	.73	.05				
12	6.0	.73	.05				
13	7.0	.73	.05				
14	8.0	.73	.05				
15	9.0	.73	.05				
16	10	.73	.05				
17	12	.73	.05				
18	14	.72	.04				
19	16	.72	.04				
20	18	.72	.04				
21	20	.72	.04				
22	25	.72	.04				
23	30	.71	.03				
24	35	.71	.03				
25	40	.71	.03				
26	45	.71	.03				



The Corporation of the Township of Langley

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 10 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 05 27

LOCATION: 238A Street & 62 Ave.

SHEET 4 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
	(Min)	(M)		(Min)	L	LPM	
27	50	18.71	.04				
28	60	.71	.03				
29	70	.70	.02				
30	80	.70	.02				
31	90	.70	.02				
32	100	.70	.02				
33	110	.70	.02				
34	120	.69	.01				

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 11 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 06 14

LOCATION: 238A Street & 62 Ave.

SHEET 1 of 6

Township of Langley

TEST NO. 1



Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
				(Min)	L	LPM	
1	0	17.11	0				Static Water Level below MPT Measuring Point - top of casing 0.46 m above ground
2	.5	18.00	0.89				
3	1.0	.61	1.50				
4	1.5	.87	.76				Discharge 30 m away from well
5	2.0	19.02	.91				
6	2.5	.14	2.03				
7	3.0	.17	.06				
8	3.5	.21	.10				
9	4.0	.21	.10				
10	4.5	.26	.15				
11	5.0	.26	.15				
12	6.0	.29	.18				
13	7.0	.30	.19				
14	8.0	.30	.19				
15	9.0	.32	.21				
16	10	.33	.22				
17	12	.35	.24				
18	14	.39	.28	0.45	20	44	
19	16	.39	.28				
20	18	.40	.29				
21	20	.42	.31				
22	25	.46	.35				
23	30	.49	.38				
24	35	.51	.40				
25	40	.54	.43				
26	45	19.60	2.49				



TIME - DRAWDOWN GRAPH FOR PUMP TEST

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 11, (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 06 14
 LOCATION: 238A & 62nd Ave. SHEET 5 OF 6
 DEPTH TO STATIC WATER LEVEL: 16.65 (m) TEST NO. 1
 Below existing ground



Pumping rate 5 Lpm Drawdown at 30 days (S_{30}) 3.8 $5/44 = 0.43$ (m)

Estimated minimum adjustment for seasonal decline (D): Use following figures if other local data or hydrogeologist's opinion is not available.


Tests run in summer time: 2 m
 Tests run in winter time: 6 m
 Tests run in fall and spring: use intermediate values 2 m to 6 m

Depth to proposed pump suction (D_p) 22 m

Calculate minimum available drawdown: $D_p - (D_{TW} + S_{30} + D) =$

$$\underline{22} - (\underline{16.65} + \underline{.43} + \underline{4}) = \underline{0.92}$$

If answer to above calculation is negative, then either the pump has to be set lower or the well is not capable of supplying water for a house.



The Corporation of the Township of Langley

SCHEDULE "A"

PUMP TEST SUMMARY

OWNER'S NAME: Goodbrand Development WELL NO. 11 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 06 14
 LOCATION: 238A Street & 62nd Ave. SHEET 6 OF 6
Township of Langley TEST NO. 1

WELL COMPLETION DATA		SCREEN DESIGN (mark one)	DESCRIPTION OF AQUIFER
Depth <u>25.30</u> (m)	<input type="checkbox"/> Open Hole	<input type="checkbox"/> Slotted Casing	<u>Sand & Gravel</u>
Diameter <u>152</u> (mm)	<input checked="" type="checkbox"/> Screen	<input type="checkbox"/> Gravel Pack	
Static Water Level <u>16.65m</u>	<input type="checkbox"/> Other _____		
	Screen interval <u>23.87</u> to <u>25.45</u> m		

PUMP TEST	
Start: Date <u>14 06 1988</u> time <u>1045</u>	
<small>d/mo/yr</small>	<small>hr/min</small>
Pump Type: <input checked="" type="checkbox"/> Electric submersible	<input type="checkbox"/> Jet <input type="checkbox"/> Air Lift
Other? Describe _____	
Test Pump Set at <u>20</u> m below ground	
Water level sounded by: <input checked="" type="checkbox"/> Electric tape	<input type="checkbox"/> Air bubbler <input type="checkbox"/> Steel tape
<input type="checkbox"/> Other? Describe _____	
Flow measured by: <input checked="" type="checkbox"/> Container & watch	<input type="checkbox"/> Flow meter
<input type="checkbox"/> Orifice & tube <input type="checkbox"/> Other? Describe _____	

TEST	
Constant rate of yield <u>44</u> Lpm	Test duration <u>2</u> hours
Initial non-pumping level <u>16.65</u> m	
Drawdown in well at end of test <u>2.75</u> m	
Recommended pumping rate <u>5</u> Lpm	

WATER SAMPLES TAKEN DURING TEST	
Chemical Analysis <input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Bacterial Analysis <input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Water Temperature <u>9</u> °C	
Any particular gas smells noted <u>None</u>	
Comments on clarity of water <u>Clean and Clear</u>	
Other _____	



The Corporation of the Township of Langley

SCHEDULE "A"

PRIVATE WELL CERTIFICATION

PURSUANT TO SCHEDULE "A" of the Subdivision and Development Control Bylaw, I hereby certify that each lot to be created and/or each existing lot forming part of the proposed development can be serviced with potable water in accordance with the requirements of the Bylaw for the development of:

LEGAL DESCRIPTION: Lot 12 (Phase 1)

PROJECT NO.: 87-111

I certify that a quantity of not less than 2,500 litres per day has been proven for each existing or proposed lot in the development.

I certify that water quality tests have been conducted and that the "B.C. Drinking Water Standards, 1982" can be met for each existing or proposed lot in the development.

P.L. Brown
Certified By (Name of Professional Engineer)

1409 Beechdale Ave
Address

North Vancouver, B.C. V7M 3C7

PROFESSIONAL
SEAL

See attachments as required pursuant to clause 2.2.18 of Schedule "A".

Subdivision Application No. 87-111
Lot B of Lots 2 and 3, Plan 13274 and Parcel A
(Reference Plan 8562) of Lots 2, 3 and 4, Except
Plan 17067, Plan 23779 and part of Lot 31, Plan
54464, all of North East 1/4 of Section 9, Township 11, N.W.D.

WTN 108031

GOODBRAND DEVELOPMENT CORPORATION
62ND AVE., LANGLEY, BRITISH COLUMBIA

Well on Lot 12 (S.W. Corner) (Phase 1)

Depth (Below Ground Surface)		Description
Metres	Feet	
0.00 - 0.30	0 - 1	Soil, sandy loam
0.30 - 7.93	1 - 26	Sand and gravel, silty
7.93 - 10.36	26 - 34	Sand, fined grained, silty
10.36 - 11.58	34 - 38	Sand and gravel
11.58 - 14.94	38 - 49	Sand, silty
14.94 - 17.07	49 - 56	Clay, sandy
17.07 - 17.98	56 - 59	Till-like, clayey
17.98 - 37.19	59 - 122	Clay with sand interbeds
37.19 - 39.62	122 - 130	Till-like, clayey
39.62 - 40.54	130 - 133	Sand, silty
40.54 - 42.37	133 - 139	Sand and gravel <u>water-bearing</u>

Construction details - below ground surface

	Metres	Feet
152 mm (6 inch) diameter casing	+ 0.46 - 41.30	+ 1.5 - 135.5
152 mm (6 inch) telescopic diameter screen	40.94 - 41.30	134.3 - 135.5
Screen - stainless steel, 20 slot with K-packer		
Top 3 m (10 feet) sealed with thick bentonite slurry outside of casing.		

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 12 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 06 13

LOCATION: 238A Street & 62 Ave.

SHEET 1 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
	(Min)	(M)	(M)	(Min)	L	LPM	
1	0	21.69	0				Static Water Level below MPT
2	.5	22.81	1.12				Measuring Point - top of casing 0.46 m above ground
3	1.0	23.94	2.25				
4	1.5	25.06	3.37				
5	2.0	.89	4.20				Discharge 30 m away from well
6	2.5	26.67	.98				
7	3.0	27.57	5.88				
8	3.5	28.16	6.47				
9	4.0	.78	7.09				
10	4.5	29.46	.77				
11	5.0	30.08	8.39	0.5	20	40	
12	6.0	31.00	9.31				
13	7.0	.83	10.14				
14	8.0	32.58	.89				
15	9.0	33.25	11.56				
16	10	.81	12.12				
17	12	34.71	13.02				
18	14	35.29	.60				
19	16	.84	14.15				
20	18	36.13	.44				
21	20	.40	.71				
22	25	.77	15.08				
23	30	37.02	.33				
24	35	.10	.41				
25	40	.16	.47				
26	45	.22	.53				

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 12 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 06 13

LOCATION: 238A Street & 62 Ave.


SHEET 3 of 6

Township of Langley

TEST NO. 1



Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
	(Min)	(M)	(M)	(Min)	L	LPM	
1	0	37.32	15.63				Pump Off
2	.5	36.18	14.49				
3	1.0	35.24	13.55				
4	1.5	34.36	12.67				
5	2.0	33.43	11.74				
6	2.5	32.60	10.91				
7	3.0	31.74	.05				
8	3.5	.15	9.46				
9	4.0	30.48	8.79				
10	4.5	29.87	.18				
11	5.0	.28	7.59				
12	6.0	28.28	6.59				
13	7.0	27.37	5.68				
14	8.0	26.61	4.92				
15	9.0	25.93	.24				
16	10	.37	3.68				
17	12	24.41	2.72				
18	14	23.77	.08				
19	16	.26	1.57				
20	18	22.85	.16				
21	20	.51	0.82				
22	25	.02	.33				
23	30	21.85	.16				
24	35	.72	.03				
25	40	.64	-0.05				
26	45	.60	-0.09				



TIME - DRAWDOWN GRAPH FOR PUMP TEST

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 12 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 06 13
 LOCATION: 238A & 62nd Ave. SHEET 5 OF 6
 DEPTH TO STATIC WATER LEVEL: 21.23 (m) TEST NO. 1
 Below existing ground



Pumping rate 10 Lpm Drawdown at 30 days (S_{30}) $18 \times 10 / 40$ (m) = 4.5

Estimated minimum adjustment for seasonal decline (D): Use following figures if other local data or hydrogeologist's opinion is not available.

Tests run in summer time: 2 m
 Tests run in winter time: 6 m
 Tests run in fall and spring: use intermediate values 2 m to 6 m
 40

Depth to proposed pump suction (D_p) _____ m

Calculate minimum available drawdown: $D_p - (D_{TW} + S_{30} + D) =$

$$40 - (21.23 + 4.5 + 4) = 10.27$$

If answer to above calculation is negative, then either the pump has to be set lower or the well is not capable of supplying water for a house.



The Corporation of the Township of Langley

SCHEDULE "A"

PUMP TEST SUMMARY

OWNER'S NAME: Goodbrand Development WELL NO. 12 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 06 13
 LOCATION: 238A & 62nd Ave. SHEET 6 OF 6
Township of Langley TEST NO. 1

WELL COMPLETION DATA

Depth 42.37 (m)
 Diameter 152 (mm)
 Static Water Level 21.22 (m)

SCREEN DESIGN (mark one)

Open Hole Slotted Casing
 Screen Gravel Pack
 Other _____
 Screen interval 40.94 to 41.30

DESCRIPTION OF AQUIFER
Sand & Gravel

PUMP TEST

Start: Date 13 06 1988 Time 0930
d/mo/yr hr/min

Pump Type: Electric submersible Jet Air Lift

Other? Describe _____

Test Pump Set at 40 m below ground

Water level sounded by: Electric tape Air bubbler Steel tape
 Other? Describe _____

Flow measured by: Container & watch Flow meter
 Orifice & tube Other? Describe _____

TEST

Constant rate of yield 40 Lpm Test duration 2 hours
 Initial non-pumping level 21.23 m
 Drawdown in well at end of test 15.63 m
 Recommended pumping rate 10 Lpm

WATER SAMPLES TAKEN DURING TEST

Chemical Analysis Yes No

Bacterial Analysis Yes No

Water Temperature 9 °C

Any particular gas smells noted None

Comments on clarity of water Clear and Clean

Other _____

Subdivision Application No. 87-111
Lot B of Lots 2 and 3, Plan 13274 and Parcel A
(Reference Plan 8562) of Lots 2, 3 and 4, Except
Plan 17067, Plan 23779 and part of Lot 31, Plan
54464, all of North East 1/4 of Section 9, Township 11, N.W.D.

See attachments as required pursuant to
clause 2.2.18 of Schedule "A".

North Township, O.C. 17th Sec
Address
1909 Beavertail Ave
Certified By (Name of Professional Engineer)
Art J. Brown

PROFESSIONAL
SEAL

I certify that a quantity of not less than 2,500 litres per day has been
proven for each existing or proposed lot in the development.
I certify that water quality tests have been conducted and that the "B.C.
Drinking Water Standards, 1982" can be met for each existing or proposed lot
in the development.


PROJECT NO.: 87-111

LEGAL DESCRIPTION:
Lot 13 (Phase 1)
PURSUANT TO SCHEDULE "A" of the Subdivision and Development Control Bylaw, I
hereby certify that each lot to be created and/or each existing lot forming
part of the proposed development can be serviced with potable water in
accordance with the requirements of the Bylaw for the development of:
Lot 13 (Phase 1)

PRIVATE WELL CERTIFICATION

SCHEDULE "A"

The Corporation of the Township of Langley



WTN 108032

GOODBRAND DEVELOPMENT CORPORATION
62ND AVE., LANGLEY, BRITISH COLUMBIA

Well on Lot 13 (S.E. Corner) (Phase 1)

Depth (Below Ground Surface)				Description
Metres	Feet			
0.00 - 0.61	0 - 2			Sandy loam
0.61 - 4.57	2 - 15			Sand and gravel, silty
4.57 - 16.46	15 - 54			Clay
16.46 - 17.68	54 - 58			Till-like
17.68 - 23.47	58 - 77			Gravel, very silty
23.47 - 27.43	77 - 90			Till with gravel beds
27.43 - 28.65	90 - 94			Sand, silty, fine grained
28.65 - 35.05	94 - 115			Till
35.05 - 35.97	115 - 118			Gravel, very silty
35.97 - 36.88	118 - 121			Sand, silty
36.88 - 38.10	121 - 125			Sand and gravel
38.10 - 41.15	125 - 135			Till, sandy
41.15 - 43.28	135 - 142			Till
43.28 - 45.42	142 - 149			Sand and gravel, <u>water-bearing</u>
45.42	149			Gravel, silty

Construction details - below ground surface

	Metres	Feet
152 mm (6-inch) diameter casing	+ 0.61 - 44.20 +	2 - 145
152 mm (6-inch) telescopic diameter screen	43.98 - 45.42	144.3 - 149.0

Screen - stainless steel, 18 slot with K-packer

Thick Bentonite Slurry seal around top 3m (10 feet) of casing

THE CORPORATION OF THE TOWNSHIP OF LANGLEY

SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp.

WELL NO. 13 (Phase 1)

APPLICATION NO. 87-111

DATE: 1988 06 30

LOCATION: 238A Street & 62 Ave.

SHEET 1 of 6

Township of Langley

TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start (Min)	Depth To Water (M)	Draw Down (M)	Flow Measurement Data			Comments
				(Min)	L	LPM	
1	0	21.47	0				Static Water Level below MPT
2	.5	22.17	0.07				Measuring Point - top of
3	1.0	-	-				casing 0.61 m above ground
4	1.5	23.34	1.87				
5	2.0	.91	2.44				Discharge 30 m from well
6	2.5	24.33	.86				
7	3.0	.55	3.08				Shallow 22 foot well at house
8	3.5	25.13	.66				
9	4.0	.48	4.01				
10	4.5	.86	.39				
11	5.0	26.16	.69				
12	6.0	.74	5.27				
13	7.0	-	-				
14	8.0	27.68	6.21				
15	9.0	28.07	.60				
16	10	.17	.70				
17	12	.95	7.48				
18	14	-	-				
19	16	29.95	8.48				
20	18	30.37	.90				
21	20	.60	9.13	0.83	20	24.1	
22	25	31.08	.61				
23	30	-	-				Water turbid
24	35	-	-				
25	40	32.59	11.12				
26	45	.96	.49				

THE CORPORATION OF THE TOWNSHIP OF LANGLEY


SCHEDULE "A"

WELL PUMP TEST - FIELD TEST

OWNER'S NAME: Goodbrand Development Corp. WELL NO. 13 (Phase 1)
 APPLICATION NO. 87-111 DATE: 1988 06 30
 LOCATION: 238A Street & 62 Ave. SHEET 3 of 6
Township of Langley TEST NO. 1

Drawdown Recovery

Rdg #	Time From Start	Depth To Water	Draw Down	Flow Measurement Data			Comments
	(Min)	(M)	(M)	(Min)	L	LPM	
1	0	36.21	14.74				Pump Off
2	.5	34.10	12.63				
3	1.0	33.53	.06				
4	1.5	.13	11.66				
5	2.0	32.67	.20				
6	2.5	.25	10.78				
7	3.0	31.90	.43				
8	3.5	.56	.09				
9	4.0	.17	9.70				
10	4.5	30.90	.43				
11	5.0	.66	.19				
12	6.0	29.97	8.50				
13	7.0	.72	.25				
14	8.0	.32	7.85				
15	9.0	28.92	.45				
16	10	.62	.15				
17	12	.08	6.61				
18	14	27.56	.09				
19	16	.20	5.73				
20	18	.15	.68				
21	20	26.51	.04				
22	25	28.87	4.40				
23	30	.45	3.98				
24	35	24.94	.47				
25	40	.59	.12				
26	45	.20	2.73				



The Corporation of the Township of Langley

SCHEDULE "A"

PUMP TEST SUMMARY

OWNER'S NAME: Goodbrand Development WELL NO. 13 (Phase 1)
 APPLICATION NO.: 87-111 DATE: 1988 06 30
 LOCATION: 238A Street & 62nd Ave. SHEET 6 OF 6
Township of Langley TEST NO. 1

WELL COMPLETION DATA	SCREEN DESIGN (mark one)	DESCRIPTION OF AQUIFER
Depth <u>45.42</u> (m)	<input type="checkbox"/> Open Hole <input type="checkbox"/> Slotted Casing	<u>Sand and Gravel</u>
Diameter <u>152</u> (mm)	<input checked="" type="checkbox"/> Screen <input type="checkbox"/> Gravel Pack	
Static Water Level <u>20.86</u> (m)	<input type="checkbox"/> Other _____	
	Screen interval <u>43.98</u> m to <u>45.42</u> m	

PUMP TEST

Start: Date 30 06 1988 Time 0930
d/mo/yr hr/min

Pump Type: Electric submersible Jet Air Lift
 Other? Describe _____

Test Pump Set at 40 m below ground

Water level sounded by: Electric tape Air bubbler Steel tape
 Other? Describe _____

Flow measured by: Container & watch Flow meter
 Orifice & tube Other? Describe _____

TEST

Constant rate of yield 24.1 Lpm Test duration 2 hours
 Initial non-pumping level 20.86 m
 Drawdown in well at end of test 14.74 m
 Recommended pumping rate 10 Lpm

WATER SAMPLES TAKEN DURING TEST

Chemical Analysis Yes No
 Bacterial Analysis Yes No

Water Temperature 10 °C

Any particular gas smells noted None

Comments on clarity of water Clear and Clean

Other _____

CHEMICAL ANALYSIS REPORT

ASL

Date: June 30, 1988
File No. 5675A AMENDED
Report On: Water Analysis - Goodbrand Property, Langley, B.C.
Report To: Brown Erdman & Turner Ltd.
1409 Bewicke Avenue
North Vancouver, B. C.
V7M 2W0

DATE OF SUBMISSION:

May 27, 1988

SAMPLE IDENTIFICATION

Labelled as shown in RESULTS section.

METHODOLOGY

Analysed in accordance with "Standard Methods for the Examination of Water and Wastewater" published by the American Public Health Association, 1985.

RESULTS OF ANALYSIS

Results are presented in the table(s) attached.



analytical service laboratories

CONSULTING CHEMISTS & ANALYSTS

1650 Pandora Street
Vancouver, B.C. • V5L 1L6
(604) 253-4188

REMARKS (Contd.)

File No. 5675A
Page 2 of 5

Sample I.D. Lot 1

The water as represented by the sample submitted can be characterized as moderate with respect to dissolved mineralization. The water sample met drinking water guidelines for all parameters analysed.

Sample I.D. Lot 2

The water as represented by the sample submitted can be characterized as moderate with respect to dissolved mineralization. The water sample met drinking water guidelines for all parameters analyzed. Total coliform was detected in this sample which should be resampled and confirmed.

Sample I.D. Lot 3

The water as represented by the sample submitted can be characterized as moderately high with respect to dissolved mineralization. The water sample met drinking water guidelines for all parameters analysed except for color and Manganese. These parameters are limited for aesthetic purposes (i.e., appearance, taste, etc.) rather than health considerations.

Sample I.D. Lot 4

The water as represented by the sample submitted can be characterized as moderately high with respect to dissolved mineralization. The water sample met drinking water guidelines for all parameters analysed except for color and Manganese. These parameters are limited for aesthetic purposes (i.e., appearance, taste, etc.) rather than health considerations. This sample should be resampled and tested for Total Coliform.

Sample I.D. Lot 5

The water as represented by the sample submitted can be characterized as moderate with respect to dissolved mineralization. The water sample met drinking water guidelines for all parameters analysed. This sample should be resample and tested for Total Coliform.

REMARKS (Contd.)


File No. 5675A
Page 3 of 5

Sample I.D. Lot 6 and Lot 10

The water as represented by the sample submitted can be characterized as moderate with respect to dissolved mineralization. The water sample met drinking water guidelines for all parameters analysed.

ASL ANALYTICAL SERVICE LABORATORIES LTD.


R. W. Deverall
Senior Partner


Christine M. Smith
Technologist

RWD/lc

RESULTS OF ANALYSIS

File No. 5675A

Page 4 of 5

	Lot 1 May 27/88	Lot 2 May 27/88	Lot 3 May 27/88	Lot 4 May 27/88	Drinking*1 Water Guidelines
--	--------------------	--------------------	--------------------	--------------------	-----------------------------------

Physical Tests

pH	7.50	8.05	8.20	8.20	6.5-8.5
Conductivity	118.	177.	252.	263.	-
Colour	<5.	<5.	22.	28.	15.
Turbidity NTU	<1.0	1.6	5.2	7.0	5.
Suspended Solids	<1.0	<1.0	3.3	<1.0	-
Dissolved Solids	99.3	141.	234.	238.	-
Hardness CaCO3	54.1	75.4	54.9	50.2	-*2

Anions

Alkalinity CaCO3	54.5	81.7	139.	141.	-
Sulphate SO4	3.5	5.4	5.4	6.0	500.
Chloride Cl	2.6	4.3	4.8	4.8	250.
Fluoride F	0.05	0.04	0.20	0.29	1.5
Silicate SiO2	14.6	12.5	21.1	19.8	-
NO3/NO2 N	1.80	2.80	<0.005	<0.005	10.0

Total Metals

Iron T Fe	0.04	0.06	0.23	0.15	0.30
Manganese T Mn	0.026	0.042	0.076	0.075	0.05

Dissolved Metals

Arsenic D As	0.0004	0.0014	0.010	0.012	0.05
Barium D Ba	<0.005	0.007	0.009	0.006	1.0
Cadmium D Cd	<0.0002	<0.0002	<0.0002	<0.0002	0.005
Chromium D Cr	<0.01	<0.01	0.01	<0.01	0.05
Copper D Cu	0.005	0.008	0.011	0.008	1.0
Iron D Fe	<0.03	<0.03	<0.03	<0.03	-
Lead D Pb	<0.001	<0.001	<0.001	<0.001	0.05
Manganese D Mn	<0.005	0.023	0.059	0.054	-
Zinc D Zn	0.005	<0.005	<0.005	<0.005	5.0
Calcium D Ca	12.7	19.4	13.2	12.2	-
Magnesium D Mg	5.44	6.56	5.34	4.79	-
Potassium D K	0.85	2.07	4.77	4.86	-
Sodium D Na	5.15	9.50	40.3	44.5	-*3

Microbiological Tests

Total Coliform	<2.	6.	<2	21.	-
Fecal Coliform	<2.	<2.	<2.	<2.	-

< = Less than

Results are expressed as milligrams per litre except for pH, Conductivity ($\mu\text{mhos/cm}$), Turbidity (NTU), Colour, Coliform Bacteria (Colonies/100ml), NO₃/NO₂ = nitrate/ nitrite nitrogen.

*1 "Maximum acceptable concentration" as published by Health & Welfare Canada, 1985 and B.C. Ministry of Health, 1982

*2 Maximum level not established - water supplies with a hardness exceeding 200 mg/L are considered poor but will be tolerated. Not a health consideration

*3 Maximum level not established - of concern to consumers with sodium restricted diet. Levels exceeding 20 mg/L may be of concern in this circumstance.

RESULTS OF ANALYSIS

File No. 5675A
Page 5 of 5

	Lot 5 May 27/88	Lot 6 May 27/88	Lot 10 May 27/88	Drinking*1 Water Guidelines
--	--------------------	--------------------	---------------------	-----------------------------------

Physical Tests

pH	7.93	8.11	8.11	6.5-8.5
Conductivity	145.	135.	131.	-
Colour	<5.	<5.	<5.	15.
Turbidity NTU	<1.0	<1.0	<1.0	5.
Suspended Solids	<1.0	3.3	<1.0	-
Dissolved Solids	109.	114.	110.	-
Hardness CaCO3	61.6	34.0	37.7	-*2

Anions

Alkalinity CaCO3	61.3	65.8	65.8	-
Sulphate SO4	3.8	4.7	5.1	500.
Chloride Cl	4.	3.3	1.9	250.
Fluoride F	0.05	0.07	0.06	1.5
Silicate SiO2	12.0	10.4	10.4	-
NO3/NO2 N	2.70	0.013	<0.005	10.0

Total Metals

Iron T Fe	0.04	0.06	0.05	0.30
Manganese T Mn	0.008	0.047	0.030	0.05

Dissolved Metals

Arsenic D As	0.0051	0.0047	0.0066	0.05
Barium D Ba	0.006	<0.005	0.006	1.0
Cadmium D Cd	<0.0002	<0.0002	<0.0002	0.005
Chromium D Cr	0.01	<0.01	<0.01	0.05
Copper D Cu	0.007	0.006	0.005	1.0
Iron D Fe	<0.03	<0.03	<0.03	-
Lead D Pb	<0.001	<0.001	<0.001	0.05
Manganese D Mn	<0.005	<0.005	0.016	-
Zinc D Zn	<0.005	<0.005	<0.005	5.0
Calcium D Ca	15.9	8.56	9.83	-
Magnesium D Mg	5.31	3.08	3.19	-
Potassium D K	1.62	2.39	2.57	-
Sodium D Na	5.47	16.0	11.7	-*3

Microbiological Tests

Total Coliform	17.	<2.	<2.	-
Fecal Coliform	<2.	<2.	<2.	-


< = Less than

Results are expressed as milligrams per litre except for pH, Conductivity ($\mu\text{mhos/cm}$), Turbidity (NTU), Colour, Coliform Bacteria (Colonies/100ml), NO₃/NO₂ = nitrate/ nitrite nitrogen.

*1 "Maximum acceptable concentration" as published by Health & Welfare Canada, 1985

*2 Maximum level not established - water supplies with a hardness exceeding 200 mg/L are considered poor but will be tolerated. Not a health consideration

*3 Maximum level not established - of concern to consumers with sodium restricted diet. Levels exceeding 20 mg/L may be of concern in this circumstance.



CHEMICAL ANALYSIS REPORT

Date: June 30, 1988
File No. 5738A
Report On: Goodbrand Property, Langley, B.C.
Report To: Brown Erdman & Turner Ltd.
1409 Bewicke Avenue
North Vancouver, B. C.
V7M 2W0

DATE OF SUBMISSION:

June 8, 1988

SAMPLE IDENTIFICATION

Labelled as shown in RESULTS section.

METHODOLOGY

Analysed in accordance with "Standard Methods for the Examination of Water and Wastewater" published by the American Public Health Association, 1985.

RESULTS OF ANALYSIS

Results are presented in the table(s) attached.

REMARKS

Lot #7 and Lot #8

The waters as represented by the samples submitted can be characterized as moderate with respect to dissolved mineralization.



analytical service laboratories

CONSULTING CHEMISTS & ANALYSTS

1650 Pandora Street
Vancouver, B.C. • V5L 1L6
(604) 253-4188

REMARKS (Contd.)

File No. 5738A

Page 2 of 3


Both water samples met Canadian and British Columbia drinking water guidelines for all parameters analysed with the exception of turbidity.

This parameter is limited for aesthetic purposes (i.e., appearance, taste, etc.) rather than health considerations and is often elevated in newly drilled wells. Continued pumping would result in lower values.

ASL ANALYTICAL SERVICE LABORATORIES LTD.



A. W. Maynard, M.Sc.
Senior Partner



Christine M. Smith
Technologist

CMS/AWM/mm

RESULTS OF ANALYSIS

File No. 5738A
Page 3 of 3

	Goodbrand Lot 7 June 7/88	Goodbrand Lot 8 June 7/88	Drinking *1 Water Guidelines
--	---------------------------------	---------------------------------	------------------------------------

Physical Tests

pH	8.36	8.21	6.5-8.5
Conductivity	241.	141.	-
Colour	14.	7.0	15.
Turbidity NTU	6.1	19.	5.
Suspended Solids	6.0	24.0	-
Dissolved Solids	192.	100.	-
Hardness CaCO ₃	17.7	54.7	- *2

Anions and Nutrients

Alkalinity CaCO ₃	127.	58.6	-
Sulphate SO ₄	<1.0	8.7	500.
Chloride Cl	5.4	4.1	250.
Fluoride F	0.33	0.05	1.5
Silicate SiO ₂	22.8	14.8	-
NO ₃ /NO ₂ N	<0.005	1.85	10.0

Total Metals

Iron T Fe	0.18	0.30	0.30
Manganese T Mn	0.039	0.019	0.05

Dissolved Metals

Arsenic D As	0.011	0.0025	0.05
Barium D Ba	0.008	0.010	1.0
Cadmium D Cd	0.0003	0.0004	0.005
Chromium D Cr	<0.02	<0.02	0.05
Copper D Cu	0.011	0.007	1.0
Iron D Fe	<0.03	<0.03	-
Lead D Pb	<0.001	<0.001	0.05
Manganese D Mn	0.017	0.015	-
Zinc D Zn	<0.005	<0.005	5.0
Calcium D Ca	4.49	14.9	-
Magnesium D Mg	1.57	4.26	-
Potassium D K	4.86	2.05	-
Sodium D Na	47.5	7.37	-*3

Microbiological Tests

Coliform Total	<2.	<2	-
Fecal	<2.	<2.	-

< = Less than

NO₃/NO₂ = Nitrate/nitrite nitrogen

Results expressed as milligrams per litre except for pH, Conductivity (µmhos/cm), Colour (CU) Turbidity (NTU) and Coliform Bacteria (colonies/100 ml)

*1 "Maximum acceptable concentration" as published by Health & Welfare Canada, 1985

*2 Maximum level not established - water supplies with a hardness exceeding 200 mg/L are considered poor but will be tolerated. Not a health consideration

*3 Maximum level not established - of concern to consumers with sodium restricted diet. Levels exceeding 20 mg/L may be of concern in this circumstance.

CHEMICAL ANALYSIS REPORT

ASL

Date: June 30, 1988
File No. 5781A AMENDED July 12, 1988
Report On: Water Analysis - Goodbrand Property, Langley, B.C.
Report To: Brown Erdman & Turner Ltd.
1409 Bewicke Avenue
North Vancouver, B. C.
V7M 2W0

DATE OF SUBMISSION:

June 15, 1988

SAMPLE IDENTIFICATION

Labelled as shown in RESULTS section.

METHODOLOGY

Analysed in accordance with "Standard Methods for the Examination of Water and Wastewater" published by the American Public Health Association, 1985.

RESULTS OF ANALYSIS

Results are presented in the table(s) attached.

REMARKS



analytical service laboratories ltd.

CONSULTING CHEMISTS & ANALYSTS
1650 Pandora Street
Vancouver, B.C. • V5L 1L6
Fax (604) 253-6700 • Tel. (604) 253-4188

Lot #11

The water as represented by the sample submitted can be characterized as moderate with respect to dissolved mineralization.

The water sample met Canadian and B. C. drinking water guidelines for all parameters analysed with the exception of colour, turbidity and iron.

These parameters are related and limited for aesthetic purposes (i.e., appearance, taste, etc.) rather than health considerations. They may be high due to the well being insufficiently pumped.

Lot #12


The water as represented by the sample submitted can be characterized as moderately high with respect to dissolved mineralization.

The water sample met Canadian and B.C. drinking water guidelines for all parameters analysed.

ASL ANALYTICAL SERVICE LABORATORIES LTD.



A. W. Maynard, M.Sc.
Senior Partner



Christine M. Smith
Technologist

CMS/AWM/mm

RESULTS OF ANALYSIS

File No. 5781A
Page 3 of 3

	Lot #11 June 14/88	Lot #12 June 14/88	Lot #4 June 14/88	Drinking*1 Water Guidelines
<u>Physical Tests</u>				
pH	8.28	8.18	-	6.5-8.5
Conductivity	138.	281.	-	-
Colour	19.	9.	-	15.
Turbidity NTU	28.0	<1.0	-	5.
Suspended Solids	12.0	<1.0	-	-
Dissolved Solids	120.	240.	-	-
Hardness CaCO3	51.6	52.2	-	-#2
<u>Anions and Nutrients</u>				
Alkalinity CaCO3	66.0	148.	-	-
Sulphate SO4	4.79	10.4	-	500.
Chloride Cl	3.2	2.3	-	250.
Fluoride F	0.05	0.27	-	1.5
Silicate SiO2	12.1	21.5	-	-
NO3/NO2 N	0.40	<0.005	-	10.0
<u>Total Metals</u>				
Iron T Fe	0.40	<0.03	-	0.30
Manganese T Mn	<0.005	0.047	-	0.05
<u>Dissolved Metals</u>				
Arsenic D As	0.0059	0.0007	-	0.05
Barium D Ba	0.009	0.027	-	1.0
Cadmium D Cd	0.0004	0.0005	-	0.005
Chromium D Cr	<0.02	<0.02	-	0.05
Copper D Cu	0.010	<0.005	-	1.0
Iron D Fe	0.03	<0.03	-	-
Lead D Pb	<0.001	<0.001	-	0.05
Manganese D Mn	<0.005	0.005	-	-
Zinc D Zn	<0.005	0.019	-	5.0
Calcium D Ca	11.2	19.7	-	-
Magnesium D Mg	3.69	0.73	-	-
Potassium D K	4.86	2.79	-	-
Sodium D Na	11.3	52.1	-	-*3
<u>Microbiological Tests</u>				
Total Coliform	<2.	<2.	<2.	-
Fecal Coliform	<2.	<2.	<2.	-


< = Less than

Results expressed as milligrams per litre except for pH, Conductivity (μ mhos/cm), Colour (CU) and Turbidity (NTU) Coliform Bacteria (colonies/100 ml)

*1 "Maximum acceptable concentration" as published by Health & Welfare Canada, 1985

*2 Maximum level not established - water supplies with a hardness exceeding 200 mg/L are considered poor but will be tolerated. Not a health consideration

*3 Maximum level not established - of concern to consumers with sodium restricted diet. Levels exceeding 20 mg/L may be of concern in this circumstance.



CHEMICAL ANALYSIS REPORT

Date: June 30, 1988
File No. 5800A
Report On: Goodbrand Property, Langley, B.C.
Report To: Brown Erdman & Turner Ltd.
1409 Bewicke Avenue
North Vancouver, B. C.
V7M 2W0

DATE OF SUBMISSION:

June 17, 1988

SAMPLE IDENTIFICATION

Labelled as shown in RESULTS section.

METHODOLOGY

Analysed in accordance with "Standard Methods for the Examination of Water and Wastewater" published by the American Public Health Association, 1985.

RESULTS OF ANALYSIS

Results are presented in the table(s) attached.

REMARKS

Lot #1

The water as represented by the sample submitted can be characterized as high with respect to dissolved mineralization.

The water sample met Canadian and B.C. drinking water guidelines for all parameters analysed. The pH is slightly outside the guidelines but this would be of no concern.



analytical service laboratories

CONSULTING CHEMISTS & ANALYSTS

1650 Pandora Street
Vancouver, B.C. • V6L 1L6
(604) 253-4188

METHODOLOGY

File No. 5800A

Page 2 of 3

Lot #5

The water as represented by the sample submitted can be characterized as moderately high with respect to dissolved mineralization.


The water sample met Canadian and B.C. drinking water guidelines for all parameters analysed except for manganese.

This parameter is limited for aesthetic purposes (i.e., appearance, taste, etc.) rather than health considerations.

ASL ANALYTICAL SERVICE LABORATORIES LTD.



A. W. Maynard, M.Sc.
Senior Partner



Christine M. Smith
Technologist

CMS/AWM/mm

RESULTS OF ANALYSIS

File No. 5800A
Page 3 of 3

	Lot #1 June 16/88	Lot #5 June 17/88	Drinking* Water Guidelines
pH	8.78	8.20	6.5-8.5
Conductivity	371.	307.	-
Colour	12	10.	15.
Turbidity NTU	4.6	8.4	5.
Suspended Solids	2.0	6.7	-
Dissolved Solids	324.	272.	-
Hardness CaCO3	9.12	47.7	-*2
<u>Anions and Nutrients</u>			
Alkalinity CaCO3	185.	158.	-
Sulphate SO4	7.49	8.68	500.
Chloride Cl	8.48	8.18	250.
Fluoride F	0.37	0.40	1.5
Silicate SiO2	16.9	26.8	-
NO3/NO2 N	<0.005	<0.005	10.0
<u>Total Metals</u>			
Iron T Fe	0.12	0.18	0.30
Manganese T Mn	0.011	0.067	0.05
<u>Dissolved Metals</u>			
Arsenic D As	0.012	0.013	0.05
Barium D Ba	0.005	0.014	1.0
Cadmium D Cd	0.0002	0.0002	0.005
Chromium D Cr	<0.02	<0.02	0.05
Copper D Cu	0.010	<0.005	1.0
Iron D Fe	<0.03	<0.03	-
Lead D Pb	<0.001	<0.001	0.05
Manganese D Mn	0.006	0.060	-
Zinc D Zn	0.007	<0.005	5.0
Calcium D Ca	1.92	11.2	-
Magnesium D Mg	1.05	4.79	-
Potassium D K	4.11	5.21	-
Sodium D Na	99.1	48.7	-*3
<u>Microbiological Tests</u>			
Coliform Total	<2.	<2.	-
Fecal	<2.	<2.	-

< = Less than

NO₃/NO₂ = Nitrate/nitrite nitrogen

Results expressed as milligrams per litre except for pH, Conductivity (µmhos/cm), Colour (CU) Turbidity (NTU) and Coliform Bacteria (colonies/100 ml)

*1 "Maximum acceptable concentration" as published by Health & Welfare Canada, 1985

*2 Maximum level not established - water supplies with a hardness exceeding 200 mg/L are considered poor but will be tolerated. Not a health consideration

*3 Maximum level not established - of concern to consumers with sodium restricted diet. Levels exceeding 20 mg/L may be of concern in this circumstance.

CHEMICAL ANALYSIS REPORT

ASL

Date: July 14, 1988
File No. 5872A - Report 1
Report On: Water Samples - Goodbrand Property, Langley, B.C.
Report To: Brown Erdman & Turner Ltd.
1409 Bewicke Avenue
North Vancouver, B. C.
V7M 2W0

DATE OF SUBMISSION:

June 30, 1988

SAMPLE IDENTIFICATION

Labelled as shown in RESULTS section.

METHODOLOGY

Analysed in accordance with "Standard Methods for the Examination of Water and Wastewater" published by the American Public Health Association, 1985.

RESULTS OF ANALYSIS

Results are presented in the table(s) attached.

REMARKS

Lot 13, Phase 1

The water as represented by the sample submitted can be characterized as moderate with respect to dissolved mineralization.

The water sample met B. C. and Canadian drinking water guidelines for all parameters analysed except for Colour and Iron.



analytical service laboratories ltd.

CONSULTING CHEMISTS & ANALYSTS
1650 Pandora Street
Vancouver, B.C. • V5L 1L6
Fax (604) 253-6700 • Tel. (604) 253-4188


These parameters are limited for aesthetic purposes (i.e., appearance, taste, etc.) rather than health considerations.

ASL ANALYTICAL SERVICE LABORATORIES LTD.



A. W. Maynard, M.Sc.
Senior Partner

CMS/AWM/mm



Christine M. Smith
Technologist

RESULTS OF ANALYSIS

File No. 5872A

Page 3 of 3

	Lot 13 Phase #1 Jun 30/88	Lot 2 Phase #1 Jun 30/88	Drinking*1 Water Guidelines
<u>Physical Tests</u>			
pH	8.28	-	6.5-8.5
Conductivity	227.	-	-
Colour	30.	-	15.
Turbidity NTU	8.6	-	5.
Suspended Solids	8.7	-	-
Dissolved Solids	190.	-	-
Hardness CaCO3	44.8	-	-*2
<u>Anions and Nutrients</u>			
Alkalinity CaCO3	109.	-	-
Sulphate SO4	13.1	-	500.
Chloride Cl	7.43	-	250.
Fluoride F	0.37	-	1.5
Silicate SiO2	23.3	-	-
NO3/NO2 N	0.005	-	10.0
<u>Total Metals</u>			
Iron T Fe	0.80	-	0.30
Manganese T Mn	0.039	-	0.05
<u>Dissolved Metals</u>			
Arsenic D As	0.018	-	0.05
Barium D Ba	0.032	-	1.0
Cadmium D Cd	<0.001	-	0.005
Chromium D Cr	<0.02	-	0.05
Copper D Cu	<0.005	-	1.0
Iron D Fe	<0.03	-	-
Lead D Pb	<0.001	-	0.05
Manganese D Mn	0.031	-	-
Zinc D Zn	<0.005	-	5.0
Calcium D Ca	9.47	-	-
Magnesium D Mg	5.15	-	-
Potassium D K	8.10	-	-
Sodium D Na	30.6	-	-*3
<u>Microbiological Tests</u>			
Coliform Total	<2.	<2.	
Fecal	<2.	<2.	

< = Less than


Results expressed as milligrams per litre except for pH, Conductivity (μ mhos/cm), Colour (CU), Turbidity (NTU) and Coliform Bacteria (colonies/100 ml)

*1 "Maximum acceptable concentration" as published by Health & Welfare Canada, 1985

*2 Maximum level not established - water supplies with a hardness exceeding 200 mg/L are considered poor but will be tolerated.

Not a health consideration

#3 Maximum level not established - of concern to consumers with sodium restricted diet. Levels exceeding 20 mg/L may be of concern in this circumstance.



NEW WESTMINSTER
CANADA-UNITED STATES OF AMERICA

Scale 1:50,000 Échelle




FIG 1
JUNE 15 1988 W L BROWN

