

926 - 7-22

# COPY

February 12, 1992

MacLeod Geotechnical Ltd.  
Suite G - 1451 Marine Drive  
West Vancouver, B.C.  
V7T 1B8

Attention: Mr. Ernie Naesgaard, P. Eng.

Subject: Lakeside Terrace Development  
Lot A, 1189 Westwood  
Coquitlam, British Columbia  
Dewatering Testing and System Design

Dear Sirs:

An 8-inch diameter dewatering test well has been drilled, screened, developed (cleaned) and tested. This well is located in the centre and slightly inside of the north boundary of the subject site. It was drilled to a depth of 46 feet. Please see the log of this well attached.

A 550 minute pump test was conducted at a constant rate of 143 U.S. gpm. Water level drawdown measurements were taken and recorded during pumping and recovery water levels were measured and recorded for 100 minutes after pumping was terminated. Semi-logarithmic plots of the readings taken in the pumping well and in six piezometers located in the northern part of the site showed that the effective transmissivity (field permeability) of the main water-bearing zone lying between depths of 20 and 38 feet was approximately:

Transmissivity     $T = 20,000 \text{ U.S. gallons per day per foot}$   
Permeability       $K = 20,000/18 \times 4.716 \times 10^{-5}$   
                       $= 0.052 \text{ centimeters per second}$

Much higher transmissivities in the 50,000 to 100,000 U.S. gpd/ft range were present within the first hour of the test before the drawdown cone of influence around the pumping well was widely established.

The drawdown water levels in the piezometer located approximately 32 feet from the pumping well showed that the storativity of the water-bearing zone was 0.12. This shows that the effective porosity and water content of the water-bearing zone approximates 12%.

The construction dewatering system must produce a groundwater drawdown of 12.5 feet as calculated below:

Measurements of groundwater levels taken during the winters of 1990-91 and 1991-92 indicate:

Rain Conditions	Groundwater Elevations Feet		
	North-east Corner	North Central	North-west Corner
Winter Storm (estimate)	106	106	103
Winter Rainy Season (measured)	104	104	101
Summer-Fall Season	Below 98	Below 98	Below 98

From the above the required drawdowns can be calculated:

Winter Storm Groundwater Level Top of Floor Slab	Elevation Elevation	Feet	106.0 <u>98.5</u>
Maximum Depth of Winter Storm Caused Groundwater			7.5
Plus - Thickness Floor Slab and drainage layer		1.0	
- Depth of drainage trench		4.0	5.0
Total Drawdown required after Winter Storms		Feet	12.5

The transmissivity and storativity calculations derived from the pump test data indicate that seven dewatering wells each discharging at a rate of 106 U.S. gpm for a total discharge of 742 U.S. gpm (618 Igpm or 47 l/sec.) will achieve the 12.5 feet of drawdown required after winter storms.

The drawdown required during the winter rainy season will be two feet shorter at 10.5 feet. The discharge needed to achieve this amount of groundwater lowering will be:

Each Well	89 U.S. gpm
Seven Well System	623 U.S. gpm (519 Igpm or 39 l/sec.)

A further refinement of these discharge figures can be made by assuming that the drawdowns required from the three western dewatering wells will be three feet lower than those required for the four eastern wells (please see estimated and measured groundwater elevations above). Thus to obtain the 12.5 feet of drawdown from the four eastern wells and 9.5 feet of drawdown from the three western wells the total discharge from the system would become:

$$\begin{array}{rcl} 106.0 \times 4 & = & 424.0 \\ 80.5 \times 3 & = & 241.5 \\ \hline \end{array}$$

Total            665.5 U.S. gpm (555 Igpm or 42 l/sec.)

We do not believe that existing hydrogeologic data is sufficient to warrant the use of the above 665.5 U.S. gpm figure. For planning purposes the 742 U.S. gpm figure should be used until the result of construction dewatering becomes available.

The 12.5 feet of drawdown with a total discharge of 742 U.S. gpm ( $106 \times 7$ ) during storm high groundwater levels assumes that the transmissivity (field permeability) of the water-bearing zone along the north boundary is constant at 20,000 U.S. gpd/ft. It would be prudent to locate the first two wells of the construction dewatering system at each end of the north side of the site to evaluate any hydrogeologic changes so that the number and locations of the remaining wells can be set to conform with the actual detailed field conditions across the full width of the site.

Based upon information and data presently available seven wells each discharging at a rate of 106 U.S. gpm for a total discharge of 742 U.S. gpm will lower the winter storm caused high groundwater level the required 12.5 feet and provide a "workably dry" excavation including five foot deep trenches.

Drainage pipes located five feet below the floor slab will keep the basement "dry" on a "permanent" basis. The drainage pipes should be contained within three, drain gravel filled trenches located close to the north boundary and on one hundred foot

centres south of the boundary of the site. This spacing might change after groundwater conditions and the transmissivity (field permeability) across the whole north side of the site are known.

After the drainage trench and piping systems are in place and operating properly the required winter storm induced drawdown to the Floor Slab will drop to 7.5 feet. The discharge rate needed to maintain this groundwater level has been calculated to be:

445 U.S. qpm (371 Iqpm or 28 l/sec.)

This should be the total maximum discharge from the long term "permanent" dewatering system required to control the groundwater levels caused by winter rain storms.

The drilling and testing of the next two wells and the drilling of the remaining four wells will take an estimated one month to complete on a one rig one shift per day basis.

If any of the above needs amplification or clarification please do not hesitate to call the writer at 926-0184.

Yours truly,

BROWN, ERDMAN & ASSOCIATES

W.L. Brown, P. Eng.

WLB/mt  
Encl.

WIN 106060

LAKESIDE TERRACE DEVELOPMENT

DEWATERING WELL

COQUITLAM, BRITISH COLUMBIA

Ground Surface Elevation: 107.2 feet

**Depth Feet**

**Lithology**

0 - 20

Sand and gravel

20 - 38

Sand, medium to coarse grained  
and gravel, fine, water-bearing  
static water level 6.1 feet  
below ground

38 - 46

Sand, fine to medium, silty  
water-bearing

Casing and Screen Record

**Depth Feet**

**Casing and Screen**

+2 to 28.25

8-inch diameter casing

28.25 to 30.25

7-inch diameter casing

30.25 to 35.50

8-inch telescopic diameter  
screen with 60/1000 inch slots

35.50 to 38.50

7-inch diameter casing

38.50 to 43.75

8-inch telescopic diameter  
screen with 10/1000 inch slots

Feb 10-11, 1992

LAKESIDE TERRACE

Pump Test Feb 6, 1992.

Use  $T = 20,000 \text{ US gpd/ft}^2$

$$S = 0.12$$

$$Q = 100 \text{ US gpm}$$

$$t = 10 \text{ days}$$

Sp Cap  $5.3 \text{ USgpm/ft}^{1/2}$

$$s/T = 0.12/20000 = 6 \times 10^{-6}$$

$$Q/T = 100/20000 = 0.005$$

$n$	$K$	$D_D$
1	1520	7.6
10	1000	5.0
100	470	2.9

Use  $T = 10000 \text{ US gpd/ft}^2$

$$S = 0.1$$


$$Q = 100 \text{ US gpm}$$

$$t = 10 \text{ days}$$


$$s/T = 0.1/10000 = 1 \times 10^{-5}$$

$$Q/T = 100/10000 = 0.01$$

$n$	$K$	$D_D$
1	1450	14.5
10	920	9.2
100	390	3.9



SEMI-LOGARITHMIC 5 CYCLES x 70 DIVISIONS



1.0


$10^{100}$   
LAKE SIDE TERRACE

1000

WLB Feb 11/92

# LAKESIDE TERRACE

Scale 1" = 125 ft



	$T = 20,000$	$T = 10,000$
1 @ 100	2.4	4.0
1 @ 200	1.6	2.4
1 @ 300	1.2	1.6
1 @ 400	0.8	0.8
1 @ 500	0.6	0.4
1 @ 600	0.4	0.0
	<u>7.0 ft</u>	<u>9.2 ft</u>

CW elev.

Gd Elev 109.101

A

B

X

Y

Z

#4

#5

#6

Gd ELEV 109 104 GW

W 1

W 2

Gd Elev

112  
104 GW  
elev.

A	2 @ 0.6 inches x 125 scale	2 @ 75 ft	2 x 2.7 = 5.4
1@	1.9 x 125	238	1.4
1@	3.1 x 125	388	0.8
1@	4.3 x 125	538	0.4
			<u>8.0 ft.</u>

8/600 at 100 NSqpm

5/600 W.T - 104 ft  
f/100v  
98.5  
5.5 ft

Feb. 10, 1992

High G.W.T  
f/100v  
- 106.5 (104 + 2.5)  
98.5  
8.0 ft.

LAKE SIDE  
TERRACE

Trench 5ft

5  
13.0 ft

Scale 1" = 1250 "

High Groundwater Elevation	<u>106.5 feet</u>
Elevation <del>Floor</del> Top Floor Slab	<u>98.5</u>
Depth Groundwater above Floor Slab	<u>8.0 feet</u>
Thickness Floor slab and drainage layer	<u>2.0 foot</u>
Depth of Drainage Tract	<u>5.0</u>
Total Amount Draw down	<u><u>15.0 feet</u></u>

Discharge per well

$$T = 20,000 \quad 15/11.8 \times 100 = 127 \text{ USgpm}$$

$$T = 10,000 \quad 15/19.0 \times 100 = 79 \text{ USgpm}$$

TOTAL DISCHARGE

From 7 wells.  $T = 20000 \quad 7 \times 127 = 889 \text{ USgpm}$

$T = 10000 \quad 7 \times 79 = 553 \text{ USgpm}$

Average 720 USgpm

$K \text{ cm/sec.} \quad 20000/18 \times 4.716 \times 10^{-5} = 0.052 \text{ cm/sec}$

$10,000/18 \times 4.716 \times 10^{-5} = 0.026 \text{ cm/sec}$



**BROWN, ERDMAN & ASSOCIATES LTD.**

NORTH VANCOUVER, BRITISH COLUMBIA

## WELL RECORD

OWNER LAKE SIDE TERRACE

**LOCATION** \_\_\_\_\_

**ADDRESS** \_\_\_\_\_

---

DATE: Start JAN 28 Complete

ELEVATION \_\_\_\_\_

**FORMATION LOG**

**CASING TALLY**

PACKER: Depth Top \_\_\_\_\_ Type \_\_\_\_\_

RISER: Dia. \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_

**SAND PACK** \_\_\_\_\_

**CEMENT** ——————

DEVELOPERS

#### STATIC WATER LEVEL

## SCREEN

TYPE	S5	S5		
LENGTH	5' 2"	5' 3"		
DIA.	8" TS	8" TS		
SLOT	60	10		
FROM	30' 3"	38' 6"		
TO	35' 5"	43' 9"		

**CONTRACTOR** \_\_\_\_\_

**DRILLER** DRILLING & CUTTING SYSTEMS

RIG \_\_\_\_\_

## **HYDROGEOLOGIST** \_\_\_\_\_

LAKESIDE TERRACE 6/2/92 PUMPING TEST  
SUMMARY

Obs	Drawdown T USgpd/ft	Recovery T USgpd/ft	Storage
We 11	151,000 140,600 25,000 ← <u>18,000 ←</u>	80,800 36,300	
P <sub>1</sub>	13,600 ←	X north side	
P <sub>2</sub>	125,000 14,200 ←	X north side	$1.2 \times 10^{-1}$ $1.3 \times 10^{-3}$
P <sub>3</sub>	58,000 ←	X north side	$4.1 \times 10^{-3}$
P <sub>4</sub>	20,700 ←		
P <sub>5</sub>	68,600 ←		
P <sub>6</sub>	44,400		

AVERAGE T = 56,100 USgpd

$$S \text{ in lower material} = 1.2 \times 10^{-1} \text{ (Water table)}$$

$$S \text{ in upper material} = 1.3 \times 10^{-3} \approx 4.1 \times 10^{-3} \text{ (Confined)}$$



BROWN, ERDMAN & ASSOCIATES LTD.  
NORTH VANCOUVER, BRITISH COLUMBIA

WELL #1  
PROJECT LAKESIDE TERRACE

6 2 72  
DAY MO YR

TIME	ELAPSED TIME MINUTES	DEPTH TO WATER <input checked="" type="checkbox"/> FEET <input type="checkbox"/> METERS	DRAWDOWN <input type="checkbox"/> FEET <input type="checkbox"/> METERS	RATE <input checked="" type="checkbox"/> USOPM <input type="checkbox"/> 10PM <input type="checkbox"/> LPS	REMARKS						
					P <sub>1</sub>	P <sub>2</sub>	P <sub>4</sub>	P <sub>5</sub>	P <sub>6</sub>	P <sub>7</sub>	
08:00		7.85	SW, L 5/2/72	8.30	7.50	20.41	19.62	11.95	11.12		
08:30	0	8.10		9.06	8.13	21.16	20.12	12.58	11.83		
	.5	29.50									
08:31	1	31.10									
	1.5	32.20									
08:32	2	32.40									
	2.5	32.40									
08:33	3	32.45									
	3.5	32.54									
08:34	4	32.50		143							
	4.5	32.60		(							
08:35	5	32.64									
08:36	6	32.70			9.70						
08:37	7	32.70									
08:38	8	32.72									
08:39	9	32.75									
08:40	10	32.76									
08:42	12	32.77									
08:44	14	32.80			9.75						
08:46	16	32.80									
08:48	18	32.84									
08:50	20	32.80		143							
08:55	25	32.84		(							
09:00	30	32.90			9.85						
09:05	35	32.88									
09:10	40	32.88			9.89						
09:15	45	33.00									
09:20	50	33.00									
09:30	60	33.04			9.95	8.30	21.65	20.15	12.66	12.70	
09:40	70	33.20									
09:50	80	33.18									
10:00	90	33.21									
10:10	100	33.28									
10:35	125	33.31									
11:00	150	33.41			10.50	8.50	21.32	20.16	12.64	12.70	



BROWN, ERDMAN & ASSOCIATES LTD.  
NORTH VANCOUVER, BRITISH COLUMBIA

WELL #1  
PROJECT LAKESIDE TERRACE

6 2 92  
DAY MO YR

TIME	ELAPSED TIME MINUTES	DEPTH TO WATER <input checked="" type="checkbox"/> FEET <input type="checkbox"/> METERS	DRAWDOWN <input type="checkbox"/> FEET <input type="checkbox"/> METERS	RATE <input checked="" type="checkbox"/> USGPM <input type="checkbox"/> 10PM <input type="checkbox"/> LPS	$P_2$	$P_3$	REMARKS			
							$P_1$	$P_5$	$P_6$	$P_8$
11:50	200	33.56		143						
12:40	250	33.67			10.74	8.51	21.18	20.10	12.71	12.71
13:30	300	33.72								
14:20	350	33.90			11.06	8.68	21.23	20.16	12.84	13.00
15:10	400	33.92								
16:00	450	34.13			11.30	8.73	21.30	20.20	12.91	13.24
16:50	500	34.16								
17:40	550	34.24			11.50	8.76	21.32	20.25	13.00	13.36

### ELEVATIONS

GROUND 107.2

TOP OF CASING 109.3

M.P. 109.9



**BROWN, ERDMAN & ASSOCIATES LTD.**  
NORTH VANCOUVER, BRITISH COLUMBIA

WELL #1  
PROJECT LAKE SIDE TERRACE

PAGE 3

6 2 92  
DAY MO YE

TIME	ELAPSED TIME MINUTES	DEPTH TO WATER <input checked="" type="checkbox"/> FEET <input type="checkbox"/> METERS	DRAWDOWN <input type="checkbox"/> FEET <input type="checkbox"/> METERS	RATE <input checked="" type="checkbox"/> USGPM <input type="checkbox"/> 10FPM <input type="checkbox"/> LPS			REMARKS
17:40	550	34.24		143			
		PUMP OFF	T/T				
	5.5	14.80	1101				
17:41	1	10.92	551				
	1.5	10.32	368				
17:42	2	10.24	276				
	2.5	10.12	221				
17:43	3	10.08	184				
	3.5	10.02	158				
17:44	4	10.00	138				
	4.5	9.94	123				
17:45	5	9.94	111				
17:46	6	9.92	93				
17:47	7	9.90	79				
17:48	8	9.88	70				
17:49	9	9.86	62				
17:50	10	9.82	56				
17:52	12	9.82	47				
17:54	14	9.78	40				
17:56	16	9.80	35				
17:58	18						
18:00	20	9.75	28				
18:05	25	9.71	23				
18:10	30	9.68	19				
18:15	35	9.66	17				
18:20	40	9.64	15				
18:25	45	9.62	13				
18:30	50	9.60	12				
18:40	60	9.56	10				
18:50	70	9.54	8.8				
19:00	80	9.50	7.9				
19:10	90	9.48	7.0				
19:20	100	9.46	6.5				

LAKE SIDE TERRACE

WATER LEVELS (static 6-2-92) ELEVATIONS

P <sub>1</sub>	101.77'	
P <sub>2</sub>	101.64'	$n = 32\text{ ft}$ to pumped well
P <sub>3</sub>	97.67'	$n = 27\text{ m}$ to pumped well
P <sub>4</sub>	84.64'	
P <sub>5</sub>	86.78'	
P <sub>6</sub>	98.67'	
well	101.8'	

LAKESIDE TOWNSHIP, OREGON

PROGRESSIVE DRILLING COMPANY - January 5, 1952


Depth from collar to surface level.

Percussion Drill	Line	Fence				Progressive Drilling Company			
		Depth at S.E.	Depth 13' S.E.	Depth 23' S.E.	Depth 33' S.E.	Depth at S.E.	Depth 13' S.E.	Depth 23' S.E.	Depth 33' S.E.
1	115.5	5.25	5.35	5.35	5.35	11.35	10.35	10.35	10.35
2	110.7	6.57	6.83	6.83	6.83	9.17	9.03	9.03	9.03
3	105.9	4.88	5.23	7.33	7.33	10.82	10.82	10.82	10.82
4	106.4	9.33	9.25	13.00	13.00	10.82	10.82	10.82	10.82
5	112.9	11.23	11.67	18.67	18.67	95.57	95.57	95.57	95.57
6	110.3	9.17	9.42	n/a	n/a	101.04	101.04	101.04	101.04

Well Ground 102.2


Top of casing 109.8

Measuring point 109.9




NO. 340-L410 DIETZGEN GRAPH PAPER  
SEMI-LOGARITHMIC  
4 CYCLES X 10 DIVISIONS PER INCH

DIETZGEN CORPORATION  
MADE IN U.S.A.



NO. 340-L410 DIETZGEN GRAPH PAPER  
SEMI-LOGARITHMIC  
4 CYCLES X 10 DIVISIONS PER INCH

DIETZGEN CORPORATION  
MADE IN U.S.A.




NO. 340-L410 DIETZGEN GRAPH PAPER  
SEMI-LOGARITHMIC  
4 CYCLES X TO DIVISIONS PER INCH

DIETZGEN CORPORATION  
MADE IN U. S. A.

A graph on grid paper showing a curve labeled "S" and a straight line labeled "T". The x-axis is labeled "Dep. H" and the y-axis is labeled "Dep. L". The curve starts at (0,0), dips slightly, and then rises to approximately (1.5, 1.3). The straight line starts at (0,0) and passes through approximately (1.5, 1.3).

NO. 340-L410 DIETZGEN GRAPH PAPER  
SEMI-LOGARITHMIC  
4 CYCLES X 10 DIVISIONS PER INCH

DIETZGEN CORPORATION  
MADE IN U.S.A.



NO. 340-L410 DIETZGEN GRAPH PAPER  
SEMI-LOGARITHMIC  
4 CYCLES X 10 DIVISIONS PER INCH

DIETZGEN CORPORATION  
MADE IN U.S.A.

NO. 340-L410 DIETZGEN GRAPH PAPER  
SEMI-LOGARITHMIC  
4 CYCLES X 10 DIVISIONS PER INCH

DIETZGEN CORPORATION  
MADE IN U. S. A.

Graph showing the relationship between  $T$  and  $N$ .

Approximate data points:

$T$	$N$
18.5	60
19.0	70
19.5	80
20.0	90
20.5	100

The graph shows a strong positive linear correlation.