

PROJECT NUMBER G709102

**SUITABILITY OF A WATER WELL  
PROPOSED TO SUPPLY A GREENHOUSE  
AT CAMPBELL VALLEY FARM LTD.  
AT 22950 - 16<sup>TH</sup> AVENUE, LANGLEY, B.C.**

Prepared for:

GREAT WALL CANADIAN VENTURES LTD.  
895 East 58<sup>th</sup> Avenue  
VANCOUVER, B.C. V5X 1W6

Prepared by:

PACIFIC HYDROLOGY CONSULTANTS LTD.  
201 - 1537 West 8th Avenue  
VANCOUVER, B.C. V6J 1T5

SEPTEMBER 9, 1999

**PACIFIC HYDROLOGY CONSULTANTS LTD.** Consulting Hydrogeologists

---

Suite 201, 1537 West 8<sup>th</sup> Avenue, VANCOUVER, B.C. V6J 1T5  
Telephone: (604) 730-6990 Facsimile: (604) 730-6931

September 9, 1999

Project No. G709102

Great Wall Canadian Ventures Ltd.  
895 East 58<sup>th</sup> Avenue  
VANCOUVER, B.C. V5X 1W6

Attention: Michelle Wu  
                    Manager                    

Subject: **Suitability of a Water Well Proposed to Supply a Greenhouse at Campbell Valley Farm Ltd. at 22950 - 16<sup>th</sup> Avenue, Langley**

---

Dear Ms. Wu:

## 1.0 INTRODUCTION

This letter is further to a telephone discussion on August 20, 1999 between you (M. Wu), of Great Wall Canadian Ventures Ltd., and Ann Badry, P. Geo., of Pacific Hydrology Consultants Ltd. (PHCL) and, in particular, to a meeting with Ed Livingston, P. Eng., and Mark Bolton, both of PHCL, at PHCL's office on August 23, about obtaining a permit for a greenhouse operation at Campbell Valley Farm at 22950 - 16th Avenue in Langley. From these discussions, and from documents which you presented at the meeting, we understand the following:

1. District of Langley requires assurance, before issuing a permit, that the water supply for the proposed greenhouse facility is adequate with respect to quantity and quality and that the rate of groundwater withdrawal will not impact other area water well users.
2. The owner proposes to use a well, located near the middle of the lot, to supply the greenhouse. The owner estimates that the greenhouse will require a maximum of 68,140±5 litres (15,000 imperial gallons) per day on a warm summer day.
3. A well, believed to be the existing well which is being proposed to supply the greenhouse facility, was constructed by Columbia Water Wells in 1976; the property owner at that time was John Jacobs. The driller's log and other information about the well are included in the attachments to this letter. Driller's records for several other nearby wells are on file with Groundwater Section of B.C. Environment but there is no record for a second well located near the east boundary of the subject property. We have not been able to obtain any information about the second well but we understand that there are no plans to use it.

Included in the attachments to this letter are area and well/site locations plans.

## 2.0 PUMPING TEST

### 2.1 Test Procedure and Results

The well proposed to serve the greenhouse was tested for capacity on July 22, 1999 by Union Pumps, with pumping continued at a constant rate of 1.89 lps (25 igpm) for 240 minutes. The data from this pumping test, which were provided to PHCL for analysis, are attached to this letter. Also attached are plots of the drawdown of the water level in the well during pumping and the recovery of the water level after pumping stopped (Figures 3 and 4); the pumping test data have been plotted using standard straight-line methods for analyzing such data.

The drawdown data plot (Figure 3) shows that the water level in the well was still drawing down at the end of the test, 240 minutes after the start, but the rate of drawdown during the last 60 minutes was decreasing, with an indication of approximate stability. At the end of pumping, the final drawdown was 3 m (10 ft), which is only about 16% of the total available drawdown. Figure 4, the plot of the recovery data, in which residual drawdown is plotted vs log of the ratio, time in minutes since pumping started/time in minutes since pumping stopped, shows that the water level had recovered by 82% within two hours, with full recovery indicated by the trend of the data plot.

### 2.2 Well Capacity Rating

The capacity of the subject Campbell Valley Farm Ltd. well is clearly greater than the test-pumping rate of 1.89 lps (25 igpm) which utilized only a small percentage of the available drawdown; however, because of the prevailing hydrogeologic conditions, the well should not be pumped at a rate greater than 1.89 lps without first test pumping the well at a higher rate to ensure that the well and aquifer can sustain higher rates of withdrawal.

## 3.0 GEOLOGY AND HYDROGEOLOGY

Examination of the records for ten wells at properties with street addresses close to the subject well, indicate that the aquifer supplying water to the Campbell Valley Farm well is part of a mass of ice contact deposits. Ice contact deposits, which are made up of an heterogenous mixture of various sediments of glacial origin and which consist of sediments with various grain sizes and permeability, were deposited by or in contact with ice at the end of a glacial event. The aquifers are masses or patches of permeable sand and gravel enclosed in less permeable sediments. For instance, the depths of the ten wells vary from 39.3 to 134.1 m (129 to 440 ft). Under these

conditions, it is essential to keep a record of the water level in the greenhouse supply well, observing and recording the level at more or less regular intervals.

#### 4.0 WATER QUALITY

Water samples for chemical and bacteriological analyses were taken at the end of the four hour pumping test carried out in July 1999 and submitted to Norwest Labs. The laboratory report with the results, along with a table comparing the constituents with the **Guidelines for Canadian Drinking Water Quality (GCDWQ)**, Health Canada, Sixth Edition, 1996), are attached to this letter. The groundwater represented by the Norwest Analysis is a moderately mineralized and rather soft water which is quite high in sodium. The water should be suitable for the intended use as a source of irrigation water. The analysis showed a high total coliform bacteria count but it is most unlikely that an aquifer under the prevailing conditions would contain coliform bacteria. No faecal coliform were detected. The second sample for a recheck of bacteria, which was collected on September 3 and submitted to Analytical Service Laboratories Ltd. (ASL), also showed total coliform but at a much reduced level. If coliform bacteria persist, after thorough disinfection and resampling, assurance that the water is safe for drinking can be achieved by ultraviolet treatment or some other form of purification. We do not, however, recommend such treatment without first carrying out further disinfection and resampling. As shown by the driller's litholog, the aquifer from which the well withdraws water is naturally protected by overlying sediments of low permeability which extend to a depth of 36.0 m (118 ft).

#### 5.0 CONCLUSIONS AND RECOMMENDATIONS

From our understanding of conditions and the results of the pumping test of the existing Campbell Valley Farm Ltd. Well, which is proposed as a source of water for a greenhouse facility, and taking into account the fact that the pumping rate during the test was considerably greater than the maximum estimated greenhouse requirement, it is our opinion that the well is a satisfactory source of water for the greenhouse operation and that use of the well for the intended purpose will not impact existing well water users. However, having said this, from our present understanding of the situation as outlined in this letter, we make the following recommendations:

1. If the well is to be used for domestic consumption, disinfect the well and resample the water for coliform bacteria. Consider ultraviolet or other treatment only if coliform bacteria persist.
2. Equip the well with a ¾" (19 mm) diameter PVC measuring tube, which extends at least to the top of the pump, and an electric water level indicator which displays the water level in the well at all times.

3. Equip the well with a totalizing water meter and an hour meter to show the running time of the pump.
4. Read the water meter and water level indicator about once each week and record the data on a simple spreadsheet. These data will record and indicate the ongoing condition of the well, the pump and, possibly, also the aquifer.
5. About once each year, review the data to detect any changes.
6. Be aware of any irrigation or commercial wells which may be installed in the immediate vicinity.

## 6.0 CLOSURE

This letter presents our evaluation of information provided by others.

We trust that the letter contains the information required by District of Langley. However, please do not hesitate to call the undersigned or Ann Badry for further discussion.

Yours truly,


PACIFIC HYDROLOGY CONSULTANTS LTD.



Ed Livingston, P. Eng.  
Associate Consultant


*Attachments - Area and Well/Site Location Maps  
Litholog and Well Construction Details  
Pumping Test Data and Plots  
Chemical Quality Table and Laboratory Reports*

**ATTACHMENTS**



Notes:

The base map is prepared from B.C. Ministry of Crown Lands, Surveys and Resource Mapping Branch, TRIM Maps 92G.007 and 92G.008, of 1:20,000 scale and with a 20 metre contour interval.

 denotes approximate locations of Chu's Farm (B.C.) Ltd. and Campbell Valley Farm Ltd. proposed greenhouse facilities; for site layout and approximate well locations, see Figure 2 for the respective projects.

PROJECT NO.: G709101/G709102

PROJECT:

GREAT WALL CANADIAN VENTURES LTD.  
 CHU'S FARM (B.C.) LTD.  
 AND CAMPBELL VALLEY FARM LTD.

LOCATION: District of Langley

PACIFIC HYDROLOGY CONSULTANTS LTD.  
 CONSULTING HYDROGEOLOGISTS

AREA LOCATIONS OF PROPOSED GREENHOUSES

DATE:


09/09/1999

DRAWN BY:


ab

FIGURE:

1



**Notes:**

1. The base map is a survey plan by G.R. Williams Land Surveying Ltd.; the approximate reduced scale of the plan is 1:1,060.
2.  denotes approximate locations of onsite wells, with proposed greenhouse well, as identified.
3. Legal property description: Lot 17, Township 10, Section 8, N.W.D., Plan 41661; for area location, see Figure 1.

PROJECT NO.: G709102

PROJECT:

GREAT WALL CANADIAN VENTURES LTD.  
CAMPBELL VALLEY FARM LTD.

LOCATION: 22950 - 16th Avenue, Langley

**PACIFIC HYDROLOGY CONSULTANTS LTD.**  
CONSULTING HYDROGEOLOGISTS

**SITE LAYOUT AND WELL LOCATIONS**

DATE:  
09/09/99

DRAWN BY:  
ab

FIGURE:  
2



WTN 35697

## WATER SUPPLY WELL AT CAMPBELL VALLEY FARM

Location: 22950 - 16<sup>th</sup> Avenue, Langley, B.C. (former owner, John Jacobs).

Legal description: Lot 17, Township 10, Section 8, New Westminster District, Plan 41661.

Contractor: Columbia Water Wells Ltd.

Date of installation: September 15, 1976.

### Driller's litholog:

0.0 - 0.6 m ( 0 - 2 ft)	topsoil
0.6 - 24.4 m ( 2 - 80 ft)	stoney clay with some small boulders
24.4 - 36.0 m ( 80 - 118 ft)	sandy clay with stones
36.0 - 39.3 m (118 - 129 ft)	coarse silty gravel.

Completed depth: 38.9 m (127.5 ft)

Diameter: 150 mm (6") diameter.

Static water level: 15.2 m (50 ft) reported by the driller at the time of well completion in September 1976; 18.5 m (60.7 ft) at the time of the pumping test on July 22, 1999.

Well completion: The well is completed with a 1.5 m (5 ft) long well screen assembly containing 1.2 m (4 ft) of 0.5 mm (0.020") slot Johnson stainless steel well screen, with the assembly set from 37.3 to 38.9 m (122.5 to 127.5 ft).


Well performance: Constant-rate pumping for 4 hours at 1.89 lps (25 igpm) on July 22, 1999 caused maximum drawdown of 3.0 m (10.0 ft), for a specific capacity of 0.63 lps/m (2.5 igpm/ft).

Well capacity: The capacity of the Campbell Valley Farm well is greater than the test pumping rate of 1.89 lps (25 igpm) which utilized only about 16% of the available drawdown. However, due to the hydrogeologic conditions, the well should not be pumped at a rate greater than 1.89 lps without first confirming that the well and aquifer can sustain higher rate pumping.





**Figure 3. Time-Drawdown Plot for July 1999 Pumping Test of Campbell Valley Farm Well at 22950 - 16<sup>th</sup> Avenue, Langley**



**Figure 4. Time-Recovery Plot for July 1999 Pumping Test of Campbell Valley Farm Well at 22950 - 16<sup>th</sup> Avenue, Langley**




Table 1. Chemical Quality of Groundwater from Campbell Valley Farm Well and Comparison to Drinking Water Quality Limits

Parameter	Campbell Valley Farm Well		Drinking Water Limit (3)
	July 1999 (1)	September 1999 (2)	
<b>Physical Tests</b>			
Colour (CU)	35	-	15.
Total Dissolved Solids (mg/l)	387	-	500
Total Hardness (mg/l) CaCO <sub>3</sub>	53.9	-	-
pH	8.35	-	6.5 - 8.5
Turbidity (NTU)	4	-	1/5 (4)
<b>Dissolved Anions (mg/l)</b>			
Alkalinity CaCO <sub>3</sub>	285	-	-
Alkalinity calculated HCO <sub>3</sub>	347.5	-	-
Chloride Cl	18.9	-	250.
Fluoride F	<0.5	-	1.5
Sulphate SO <sub>4</sub>	<0.5	-	500.
<b>Nutrients (mg/l)</b>			
Nitrate (NO <sub>3</sub> ) N	<0.05	-	10.
Nitrite (NO <sub>2</sub> ) N	<0.5	-	1.0
<b>Total Metals (mg/l)</b>			
Aluminum Al	0.18	-	-
Arsenic As	<0.02	-	0.025
Barium Ba	0.015	-	1.0
Cadmium Cd	<0.0005	-	0.005
Chromium Cr	<0.001	-	0.05
Copper Cu	0.003	-	1.0
Iron Fe	0.208	-	0.3
Lead Pb	<0.005	-	0.01
Manganese Mn	0.0421	-	0.05
Sodium Na	136	-	200.
Uranium U	<0.06	-	0.10
Zinc Zn	0.003	-	5.0
<b>Bacteriological</b>			
Faecal Coliform (colony counts/100 m/s)	<1	<1	0
Total Coliform (colony counts/100 m/s)	>200.5	27	- (5)

Sources of Information and Notes:


1. Norwest Labs Work Order 46112; dated July 29, 1999 for a sample collected on July 22, 1999.
2. Analytical Service Laboratories Ltd. File K9284 dated September 8, 1999 for a sample collected on September 3, 1999.
3. Maximum acceptable concentration as specified in **Guidelines for Canadian Drinking Water Quality (GCDWQ, Health Canada, Sixth Edition, 1996)**, which have been adopted by B.C. Ministry of Health as the basis for assessing water potability.
4. At the point of consumption, as per **GCDWQ**, a turbidity of 5 NTU is permitted, but maximum acceptable source turbidity is 1 NTU, with some relaxation permitted for groundwater sources.
5. No sample should contain more than 10 total coliform organisms per 100 ml, none of which should be faecal, and no consecutive samples should be positive.

08-31-1999 10:33AM

FROM UNION PUMPS

TO

7306931 P.04



**NORWEST  
LABS**

Langley Ph (604) 514-3322 FAX (604) 514-3323  
Edmonton Ph (403) 438-5522 FAX (403) 438-0396  
Calgary Ph (403) 291-2022 FAX (403) 291-2021  
Lethbridge Ph (403) 329-9266 FAX (403) 327-8527  
Winnipeg Ph (204) 982-8630 FAX (204) 275-6019

Work Order Number: 46112

Date Issued: July 29, 1999

## ANALYSIS FAILURE SHEET

Sample Id: CAMPBELL VALLEY FARM

Your water sample failed to qualify for a potability certificate for the following reason (s):


Total Coliforms High  
Colour High

If you have any questions concerning your analysis please contact the laboratory manager. High coliform count require treatment of the well with bleach (procedure is included) followed by a repeat coliform test (\$25.00 charge). A water purifier may be required if any of the chemicals exceed the guidelines, which are shown on the attached Water Analysis Report.

Sincerely,

A handwritten signature in black ink, appearing to read 'John Davidson', is written over a horizontal line.

John Davidson, Dipl. T., C.P.H.I. (C)  
Supervisor, Inorganics Lab



# NORWEST LABS

Surrey Ph (604) 514-3322 FAX (604) 514-3323  
 Edmonton Ph (403) 438-5522 FAX (403) 438-0396  
 Calgary Ph (403) 291-2022 FAX (403) 291-2021  
 Lethbridge Ph (403) 329-9266 FAX (403) 327-8527  
 Winnipeg Ph (204) 982-8630 FAX (204) 275-6019

Name: UNION PUMPS  
 Address: BOX 3446, 23191 FRASER HWY.  
 LANGLEY  
 BC  
 V3A 4R8  
 Attention: Saul Hock  
 Phone: 604 533-3727  
 Fax: 604 533-4358

WO (Surrey): 46112  
 Quote No.:  
 WO (Other):  
 PO Num:  
 Project: CAMPBELL VALLEY FARM  
 Date Sampled: Jul 22, 1999  
 Date Received: Jul 22, 1999  
 Date Reported: Jul 29, 1999

## ANALYTICAL REPORT

46112-1 CAMPBELL VALLEY FARM

M99

Analyte	Result	Detection Limit	Units
Total Coliforms	>200.5	1	MPN/100 mL
Standard Plate Count	100	1	cfu/mL
Facal Coliforms	<1	1	MPN/100 mL


Guidelines / Recommendations  
Drinking Water  
 Below 1/100 mL acceptable. Conditional pass 10 / 100mL.  
 Below 500 CFU/mL acceptable  
 Below 1/100 mL acceptable

46112-1 CAMPBELL VALLEY FARM

W99-Water Potability

Analyte	Result	Detection Limit	Units
pH	8.35		
Colour	35	5	TCU
Turbidity	4	1	NTU
Total Dissolved Solids	387	1	mg/L
Hardness (CaCO3 equiv)	53.9	1	mg CaCO3/L
Chloride	18.9	0.1	mg/L
Fluoride	<0.5	0.5	mg/L
Nitrite-N	<0.5	0.5	mg/L
Nitrate-N	<0.05	0.05	mg/L
Sulfate	<0.5	0.5	mg/L
Aluminum	0.18	0.01	mg/L
Arsenic	<0.02	0.02	mg/L
Barium	0.015	0.0005	mg/L
Cadmium	<0.0005	0.0005	mg/L
Chromium	<0.001	0.001	mg/L
Copper	0.003	0.002	mg/L
Iron	0.208	0.003	mg/L
Lead	<0.005	0.005	mg/L
Manganese	0.0421	0.0005	mg/L
Sodium	136	0.05	mg/L
Uranium	<0.06	0.06	mg/L
Zinc	0.003	0.001	mg/L
Total Alkalinity	285	5	mg CaCO3/L

Guidelines / Recommendations  
Drinking Water  
 pH values between 6.5 & 8.5 considered acceptable  
 Aesthetic limit 15 TCU  
 Below 5 NTU acceptable at point of use.  
 Objective level 500 mg/L; higher values indicate high salts  
 Soft waters are less than 75 mg/L; hard waters are above 150  
 Aesthetic limit 250 mg/L  
 Values up to 1.2 mg/L desirable; under 1.5 mg/L acceptable  
 Below 10 mg/L acceptable; objective level below 1.0 mg/L  
 Below 0.025 mg/L acceptable  
 Below 1 mg/L acceptable  
 Below 0.005 mg/L acceptable  
 Below 0.05 mg/L acceptable  
 Aesthetic limit 1.0 mg/L; objective below 0.01 mg/L  
 >0.3 mg/L may cause staining; objective level below 0.05 mg/L  
 Below 0.01 mg/L acceptable  
 Aesthetic limit 0.05 mg/L; objective below 0.01 mg/L  
 Aesthetic limit 200 mg/L; below 20 mg/L for low sodium diets  
 Below 0.1 mg/L acceptable  
 Aesthetic limit 5.0 mg/L; objective below 1.0 mg/L

Approved By:   
 John Davidson, Dipl. T., C.P.H.I. (C)  
 Supervisor, Inorganics Lab



## CHEMICAL ANALYSIS REPORT

---

**Date:** September 8, 1999  
**ASL File No.** K9284  
**Report On:** GW Canadian Ven. Ltd.  
Water Analysis  
**Report To:** **Cash Customer**  
1988 Triumph Street  
Vancouver, BC  
V5L 1K5  
**Received:** September 7, 1999

---

**ASL ANALYTICAL SERVICE LABORATORIES LTD.**  
per:

*Miles Gropen*  
Miles Gropen, B.Sc. - Project Chemist  
Sarena McHugh, B.Sc. - Project Chemist





## Appendix 1 - REGULATORY CRITERIA

File No. K9284

### Health Canada

Guidelines for Canadian Drinking Water Quality, Sixth Ed., 1996.  
All limits are Maximum Acceptable Concentration (MAC) unless  
otherwise indicated.  
Limits expressed as milligrams per litre except pH, Turbidity,  
Colour, and Coliform Bacteria.

	Upper Limit	Notes
<b><u>Bacteriological Tests</u></b>		
Coliform Bacteria - Fecal	0	
Coliform Bacteria - Total	-	1

---

1 No sample should contain more than 10 organisms per 100mL and  
no consecutive samples should be positive (MAC).



## **Appendix 2 - METHODOLOGY**

File No. K9284

Outlines of the methodologies utilized for the analysis of the samples submitted are as follows:

### **Conventional Parameters in Water**

These analyses are carried out in accordance with procedures described in "Methods for Chemical Analysis of Water and Wastes" (USEPA), "Manual for the Chemical Analysis of Water, Wastewaters, Sediments and Biological Tissues" (BCMOE), and/or "Standard Methods for the Examination of Water and Wastewater" (APHA). Further details are available on request.

**End of Report**